




User's manual



FLIR B series
FLIR T series

Publ. No.	1558792
Revision	a474
Language	English (EN)
Issue date	October 7, 2010

User's manual



Legal disclaimer

All products manufactured by FLIR Systems are warranted against defective materials and workmanship for a period of one (1) year from the delivery date of the original purchase, provided such products have been under normal storage, use and service, and in accordance with FLIR Systems instruction.

Products which are not manufactured by FLIR Systems but included in systems delivered by FLIR Systems to the original purchaser, carry the warranty, if any, of the particular supplier only. FLIR Systems has no responsibility whatsoever for such products.

The warranty extends only to the original purchaser and is not transferable. It is not applicable to any product which has been subjected to misuse, neglect, accident or abnormal conditions of operation. Expendable parts are excluded from the warranty.

In the case of a defect in a product covered by this warranty the product must not be further used in order to prevent additional damage. The purchaser shall promptly report any defect to FLIR Systems or this warranty will not apply.

FLIR Systems will, at its option, repair or replace any such defective product free of charge if, upon inspection, it proves to be defective in material or workmanship and provided that it is returned to FLIR Systems within the said one-year period.

FLIR Systems has no other obligation or liability for defects than those set forth above.

No other warranty is expressed or implied. FLIR Systems specifically disclaims the implied warranties of merchantability and fitness for a particular purpose.

FLIR Systems shall not be liable for any direct, indirect, special, incidental or consequential loss or damage, whether based on contract, tort or any other legal theory.

This warranty shall be governed by Swedish law.

Any dispute, controversy or claim arising out of or in connection with this warranty, shall be finally settled by arbitration in accordance with the Rules of the Arbitration Institute of the Stockholm Chamber of Commerce. The place of arbitration shall be Stockholm. The language to be used in the arbitral proceedings shall be English.

Copyright

© 2010, FLIR Systems. All rights reserved worldwide. No parts of the software including source code may be reproduced, transmitted, transcribed or translated into any language or computer language in any form or by any means, electronic, magnetic, optical, manual or otherwise, without the prior written permission of FLIR Systems.

This documentation must not, in whole or part, be copied, photocopied, reproduced, translated or transmitted to any electronic medium or machine readable form without prior consent, in writing, from FLIR Systems.

Names and marks appearing on the products herein are either registered trademarks or trademarks of FLIR Systems and/or its subsidiaries. All other trademarks, trade names or company names referenced herein are used for identification only and are the property of their respective owners.

Quality assurance

The Quality Management System under which these products are developed and manufactured has been certified in accordance with the ISO 9001 standard.

FLIR Systems is committed to a policy of continuous development; therefore we reserve the right to make changes and improvements on any of the products described in this manual without prior notice.

Patents

One or several of the following patents or design patents apply to the products and/or features described in this manual:

0002258-2; 000279476-0001; 000439161; 000499579-0001; 000653423; 000726344; 000859020; 000889290; 001106306-0001; 0101577-5; 0102150-0; 0200629-4; 0300911-5; 0302837-0; 1144833; 1182246; 1182620; 1188086; 1263438; 1285345; 1287138; 1299699; 1325808; 1336775; 1365299; 1678485; 1732314; 200530018812.0; 200830143636.7; 2106017; 235308; 3006596; 3006597; 466540; 483782; 484155; 518836; 60004227.8; 60122153.2; 602004011681.5-08; 6707044; 68657; 7034300; 7110035; 7154093; 7157705; 7237946; 7312822; 7332716; 7336823; 7544944; 75530; 7667198; D540838; D549758; D579475; D584755; D599.392; D16702302-9; D16703574-4; D16803572-1; D16803853-4; DM/057692; DM/061609; ZL00809178.1; ZL01823221.3; ZL01823226.4; ZL02331553.9; ZL02331554.7; ZL200480034894.0; ZL200530120994.2; ZL200630130114.4; ZL200730151141.4; ZL200730339504.7; ZL200830128581.2

EULA Terms

- You have acquired a device ("INFRARED CAMERA") that includes software licensed by FLIR Systems AB from Microsoft Licensing, GP or its affiliates ("MS"). Those installed software products of MS origin, as well as associated media, printed materials, and "online" or electronic documentation ("SOFTWARE") are protected by international intellectual property laws and treaties. The SOFTWARE is licensed, not sold. All rights reserved.
- IF YOU DO NOT AGREE TO THIS END USER LICENSE AGREEMENT ("EULA"), DO NOT USE THE DEVICE OR COPY THE SOFTWARE. INSTEAD, PROMPTLY CONTACT FLIR Systems AB FOR INSTRUCTIONS ON RETURN OF THE UNUSED DEVICE(S) FOR A REFUND. **ANY USE OF THE SOFTWARE, INCLUDING BUT NOT LIMITED TO USE ON THE DEVICE, WILL CONSTITUTE YOUR AGREEMENT TO THIS EULA (OR RATIFICATION OF ANY PREVIOUS CONSENT).**
- **GRANT OF SOFTWARE LICENSE.** This EULA grants you the following license:
 - You may use the SOFTWARE only on the DEVICE.

-
- **NOT FAULT TOLERANT.** THE SOFTWARE IS NOT FAULT TOLERANT. FLIR Systems AB HAS INDEPENDENTLY DETERMINED HOW TO USE THE SOFTWARE IN THE DEVICE, AND MS HAS RELIED UPON FLIR Systems AB TO CONDUCT SUFFICIENT TESTING TO DETERMINE THAT THE SOFTWARE IS SUITABLE FOR SUCH USE.
 - **NO WARRANTIES FOR THE SOFTWARE.** THE SOFTWARE is provided "AS IS" and with all faults. THE ENTIRE RISK AS TO SATISFACTORY QUALITY, PERFORMANCE, ACCURACY, AND EFFORT (INCLUDING LACK OF NEGLIGENCE) IS WITH YOU. ALSO, THERE IS NO WARRANTY AGAINST INTERFERENCE WITH YOUR ENJOYMENT OF THE SOFTWARE OR AGAINST INFRINGEMENT. **IF YOU HAVE RECEIVED ANY WARRANTIES REGARDING THE DEVICE OR THE SOFTWARE, THOSE WARRANTIES DO NOT ORIGINATE FROM, AND ARE NOT BINDING ON, MS.**
 - **No Liability for Certain Damages.** **EXCEPT AS PROHIBITED BY LAW, MS SHALL HAVE NO LIABILITY FOR ANY INDIRECT, SPECIAL, CONSEQUENTIAL OR INCIDENTAL DAMAGES ARISING FROM OR IN CONNECTION WITH THE USE OR PERFORMANCE OF THE SOFTWARE. THIS LIMITATION SHALL APPLY EVEN IF ANY REMEDY FAILS OF ITS ESSENTIAL PURPOSE. IN NO EVENT SHALL MS BE LIABLE FOR ANY AMOUNT IN EXCESS OF U.S. TWO HUNDRED FIFTY DOLLARS (U.S.\$250.00).**
 - **Limitations on Reverse Engineering, Decompilation, and Disassembly.** You may not reverse engineer, decompile, or disassemble the SOFTWARE, except and only to the extent that such activity is expressly permitted by applicable law notwithstanding this limitation.
 - **SOFTWARE TRANSFER ALLOWED BUT WITH RESTRICTIONS.** You may permanently transfer rights under this EULA only as part of a permanent sale or transfer of the Device, and only if the recipient agrees to this EULA. If the SOFTWARE is an upgrade, any transfer must also include all prior versions of the SOFTWARE.
 - **EXPORT RESTRICTIONS.** You acknowledge that SOFTWARE is subject to U.S. export jurisdiction. You agree to comply with all applicable international and national laws that apply to the SOFTWARE, including the U.S. Export Administration Regulations, as well as end-user, end-use and destination restrictions issued by U.S. and other governments. For additional information see <http://www.microsoft.com/exporting/>.

Table of contents

1	Warnings & Cautions	1
2	Notice to user	3
3	Customer help	4
4	Documentation updates	5
5	Important note about this manual	6
6	Quick Start Guide	7
7	Parts lists	8
7.1	Contents of the transport case	8
7.2	List of accessories	9
8	A note about ergonomics	10
9	Camera parts	11
9.1	View of the rear	11
9.2	View of the front	14
9.3	View of the bottom side	16
9.4	Battery condition indicator	17
9.5	Laser pointer	18
10	Toolbars and work areas	20
10.1	Work areas	20
10.1.1	Operation mode area	20
10.1.2	Main work area	22
10.1.3	Sketch work area	23
10.1.4	Text annotation and image description work area	25
10.2	Toolbars	28
10.2.1	Measurement toolbar	28
10.2.2	Documentation toolbar	30
10.2.3	Image marker toolbar	32
10.2.4	Voice annotation toolbar	33
10.2.5	Video recording toolbar	34
10.2.6	Periodic save toolbar	35
10.2.7	Work folder toolbar	36
11	Navigating the menu system	37
12	External devices and storage media	38
12.1	Connecting external devices	39
12.2	Inserting SD Memory Cards	40
13	Pairing Bluetooth® devices	41
14	Fetching data from external Extech meters	42
14.1	Typical moisture measurement and documentation procedure	44
15	Handling the camera	45

15.1	Charging the battery	45
15.1.1	Using the combined power supply and battery charger to charge the battery when it is inside the camera	46
15.1.2	Using the combined power supply and battery charger to charge the battery when it is outside the camera	47
15.1.3	Using the stand-alone battery charger to charge the battery	48
15.2	Inserting the battery	49
15.3	Removing the battery	51
15.4	Turning on the camera	53
15.5	Turning off the camera	53
15.6	Entering standby mode	53
15.7	Exiting standby mode	53
15.8	Adjusting the angle of lens	54
15.9	Mounting an additional infrared lens	55
15.10	Removing an additional infrared lens	57
15.11	Attaching the sunshield	59
15.12	Using the laser pointer	61
16	Working with images and folders	62
16.1	Adjusting the infrared camera focus	62
16.2	Previewing an image	63
16.3	Saving an image	64
16.4	Periodically saving an image	65
16.5	Opening an image	66
16.6	Using the Panorama function	67
16.7	Adjusting an image manually	69
16.8	Hiding overlay graphics	72
16.9	Deleting an image	73
16.10	Deleting all images	74
16.11	Working with folders	75
16.12	Copy images to a USB memory stick	78
16.13	Creating an Adobe® PDF report	79
17	Working with fusion	80
18	Recording video clips	85
19	Working with measurement tools and isotherms	86
19.1	Setting up measurement tools	86
19.2	Setting up measurement tools (advanced mode)	87
19.3	Setting up a difference calculation	88
19.4	Setting up isotherms	89
19.5	Screening of elevated facial temperatures	91
19.6	Removing measurement tools	93
19.7	Moving measurement tools	94
19.8	Resizing areas	95
19.9	Changing object parameters	96
20	Annotating images	98
20.1	Adding a digital photo	99
20.2	Adding a voice annotation	100
20.3	Adding a text annotation	101
20.4	Adding an image description	104
20.5	Adding a sketch	105

20.6	Adding an image marker	106
21	Changing settings	107
21.1	Changing image settings	107
21.2	Changing regional settings	108
21.3	Changing camera settings	109
22	Cleaning the camera	110
22.1	Camera housing, cables, and other items	110
22.2	Infrared lens	111
22.3	Infrared detector	112
23	Technical data	113
24	Pin configurations	114
25	Dimensions	119
25.1	Camera	119
25.1.1	Camera dimensions	119
25.1.2	Camera dimensions, continued	120
25.1.3	Camera dimensions, continued	121
25.1.4	Camera dimensions, continued (with 30 mm/15° lens)	122
25.1.5	Camera dimensions, continued (with 10 mm/45° lens)	123
25.2	Battery	124
25.3	Stand-alone battery charger	125
25.4	Stand-alone battery charger with the battery	126
25.5	Infrared lens (30 mm/15°)	127
25.6	Infrared lens (10 mm/45°)	128
26	Application examples	129
26.1	Moisture & water damage	129
26.2	Faulty contact in socket	130
26.3	Oxidized socket	131
26.4	Insulation deficiencies	132
26.5	Draft	133
27	Introduction to building thermography	134
27.1	Disclaimer	134
27.1.1	Copyright notice	134
27.1.2	Training & certification	134
27.1.3	National or regional building codes	134
27.2	Important note	134
27.3	Typical field investigations	135
27.3.1	Guidelines	135
27.3.1.1	General guidelines	135
27.3.1.2	Guidelines for moisture detection, mold detection & detection of water damages	135
27.3.1.3	Guidelines for detection of air infiltration & insulation deficiencies ...	136
27.3.2	About moisture detection	137
27.3.3	Moisture detection (1): Low-slope commercial roofs	137
27.3.3.1	General information	137
27.3.3.2	Safety precautions	138
27.3.3.3	Commented building structures	139
27.3.3.4	Commented infrared images	140

27.3.4	Moisture detection (2): Commercial & residential façades	142
27.3.4.1	General information	142
27.3.4.2	Commented building structures	142
27.3.4.3	Commented infrared images	144
27.3.5	Moisture detection (3): Decks & balconies	144
27.3.5.1	General information	144
27.3.5.2	Commented building structures	145
27.3.5.3	Commented infrared images	147
27.3.6	Moisture detection (4): Plumbing breaks & leaks	147
27.3.6.1	General information	147
27.3.6.2	Commented infrared images	148
27.3.7	Air infiltration	150
27.3.7.1	General information	150
27.3.7.2	Commented building structures	150
27.3.7.3	Commented infrared images	152
27.3.8	Insulation deficiencies	153
27.3.8.1	General information	153
27.3.8.2	Commented building structures	153
27.3.8.3	Commented infrared images	155
27.4	Theory of building science	157
27.4.1	General information	157
27.4.2	The effects of testing and checking	158
27.4.3	Sources of disruption in thermography	159
27.4.4	Surface temperature and air leaks	161
27.4.4.1	Pressure conditions in a building	161
27.4.5	Measuring conditions & measuring season	167
27.4.6	Interpretation of infrared images	167
27.4.7	Humidity & dew point	169
27.4.7.1	Relative & absolute humidity	169
27.4.7.2	Definition of dew point	169
27.4.8	Excerpt from Technical Note 'Assessing thermal bridging and insulation continuity' (UK example)	169
27.4.8.1	Credits	169
27.4.8.2	Introduction	170
27.4.8.3	Background information	170
27.4.8.4	Quantitative appraisal of thermal anomalies	171
27.4.8.5	Conditions and equipment	174
27.4.8.6	Survey and analysis	175
27.4.8.7	Reporting	176
28	Introduction to thermographic inspections of electrical installations	178
28.1	Important note	178
28.2	General information	178
28.2.1	Introduction	178
28.2.2	General equipment data	179
28.2.3	Inspection	180
28.2.4	Classification & reporting	180
28.2.5	Priority	181
28.2.6	Repair	181
28.2.7	Control	182
28.3	Measurement technique for thermographic inspection of electrical installations	183
28.3.1	How to correctly set the equipment	183
28.3.2	Temperature measurement	183

28.3.3	Comparative measurement	185
28.3.4	Normal operating temperature	186
28.3.5	Classification of faults	187
28.4	Reporting	189
28.5	Different types of hot spots in electrical installations	191
28.5.1	Reflections	191
28.5.2	Solar heating	191
28.5.3	Inductive heating	192
28.5.4	Load variations	192
28.5.5	Varying cooling conditions	193
28.5.6	Resistance variations	194
28.5.7	Overheating in one part as a result of a fault in another	194
28.6	Disturbance factors at thermographic inspection of electrical installations	196
28.6.1	Wind	196
28.6.2	Rain and snow	196
28.6.3	Distance to object	197
28.6.4	Object size	198
28.7	Practical advice for the thermographer	200
28.7.1	From cold to hot	200
28.7.2	Rain showers	200
28.7.3	Emissivity	200
28.7.4	Reflected apparent temperature	201
28.7.5	Object too far away	201
29	About FLIR Systems	202
29.1	More than just an infrared camera	203
29.2	Sharing our knowledge	204
29.3	Supporting our customers	204
29.4	A few images from our facilities	204
30	Glossary	206
31	Thermographic measurement techniques	210
31.1	Introduction	210
31.2	Emissivity	210
31.2.1	Finding the emissivity of a sample	211
31.2.1.1	Step 1: Determining reflected apparent temperature	211
31.2.1.2	Step 2: Determining the emissivity	213
31.3	Reflected apparent temperature	214
31.4	Distance	214
31.5	Relative humidity	214
31.6	Other parameters	214
32	History of infrared technology	215
33	Theory of thermography	219
33.1	Introduction	219
33.2	The electromagnetic spectrum	219
33.3	Blackbody radiation	220
33.3.1	Planck's law	221
33.3.2	Wien's displacement law	222
33.3.3	Stefan-Boltzmann's law	224
33.3.4	Non-blackbody emitters	225
33.4	Infrared semi-transparent materials	227

34	The measurement formula	229
35	Emissivity tables	235
35.1	References	235
35.2	Important note about the emissivity tables	235
35.3	Tables	236

1

Warnings & Cautions

WARNING

- This equipment generates, uses, and can radiate radio frequency energy and if not installed and used in accordance with the instruction manual, may cause interference to radio communications. It has been tested and found to comply with the limits for a Class A computing device pursuant to Subpart J of Part 15 of FCC Rules, which are designed to provide reasonable protection against such interference when operated in a commercial environment. Operation of this equipment in a residential area is likely to cause interference in which case the user at his own expense will be required to take whatever measures may be required to correct the interference.
 - (Applies only to cameras with laser pointer:) Do not look directly into the laser beam. The laser beam can cause eye irritation.
 - Applies only to cameras with battery:
 - Do not disassemble or do a modification to the battery. The battery contains safety and protection devices which, if they become damaged, can cause the battery to become hot, or cause an explosion or an ignition.
 - If there is a leak from the battery and the fluid gets into your eyes, do not rub your eyes. Flush well with water and immediately get medical care. The battery fluid can cause injury to your eyes if you do not do this.
 - Do not continue to charge the battery if it does not become charged in the specified charging time. If you continue to charge the battery, it can become hot and cause an explosion or ignition.
 - Only use the correct equipment to discharge the battery. If you do not use the correct equipment, you can decrease the performance or the life cycle of the battery. If you do not use the correct equipment, an incorrect flow of current to the battery can occur. This can cause the battery to become hot, or cause an explosion and injury to persons.
 - Make sure that you read all applicable MSDS (Material Safety Data Sheets) and warning labels on containers before you use a liquid: the liquids can be dangerous.
-

CAUTION

- Do not point the infrared camera (with or without the lens cover) at intensive energy sources, for example devices that emit laser radiation, or the sun. This can have an unwanted effect on the accuracy of the camera. It can also cause damage to the detector in the camera.
- Do not use the camera in a temperature higher than +50°C (+122°F), unless specified otherwise in the user documentation. High temperatures can cause damage to the camera.
- (Applies only to cameras with laser pointer:) Protect the laser pointer with the protective cap when you do not operate the laser pointer.
- Applies only to cameras with battery:
 - Do not attach the batteries directly to a car's cigarette lighter socket, unless a specific adapter for connecting the batteries to a cigarette lighter socket is provided by FLIR Systems.
 - Do not connect the positive terminal and the negative terminal of the battery to each other with a metal object (such as wire).
 - Do not get water or salt water on the battery, or permit the battery to get wet.

- Do not make holes in the battery with objects. Do not hit the battery with a hammer. Do not step on the battery, or apply strong impacts or shocks to it.
 - Do not put the batteries in or near a fire, or into direct sunlight. When the battery becomes hot, the built-in safety equipment becomes energized and can stop the battery charging process. If the battery becomes hot, damage can occur to the safety equipment and this can cause more heat, damage or ignition of the battery.
 - Do not put the battery on a fire or increase the temperature of the battery with heat.
 - Do not put the battery on or near fires, stoves, or other high-temperature locations.
 - Do not solder directly onto the battery.
 - Do not use the battery if, when you use, charge, or store the battery, there is an unusual smell from the battery, the battery feels hot, changes color, changes shape, or is in an unusual condition. Contact your sales office if one or more of these problems occurs.
 - Only use a specified battery charger when you charge the battery.
 - The temperature range through which you can charge the battery is $\pm 0^{\circ}\text{C}$ to $+45^{\circ}\text{C}$ ($+32^{\circ}\text{F}$ to $+113^{\circ}\text{F}$), unless specified otherwise in the user documentation. If you charge the battery at temperatures out of this range, it can cause the battery to become hot or to break. It can also decrease the performance or the life cycle of the battery.
 - The temperature range through which you can discharge the battery is -15°C to $+50^{\circ}\text{C}$ ($+5^{\circ}\text{F}$ to $+122^{\circ}\text{F}$), unless specified otherwise in the user documentation. Use of the battery out of this temperature range can decrease the performance or the life cycle of the battery.
 - When the battery is worn, apply insulation to the terminals with adhesive tape or similar materials before you discard it.
 - Remove any water or moisture on the battery before you install it.
 - Do not apply solvents or similar liquids to the camera, the cables, or other items. This can cause damage.
 - Be careful when you clean the infrared lens. The lens has a delicate anti-reflective coating.
 - Do not clean the infrared lens too vigorously. This can damage the anti-reflective coating.
 - In furnace and other high-temperature applications, you must mount a heatshield on the camera. Using the camera in furnace and other high-temperature applications without a heatshield can cause damage to the camera.
 - (Applies only to cameras with an automatic shutter that can be disabled.) Do not disable the automatic shutter in the camera for a prolonged time period (typically max. 30 minutes). Disabling the shutter for a longer time period may harm, or irreparably damage, the detector.
 - The encapsulation rating is valid only when all openings on the camera are sealed with their designated covers, hatches, or caps. This includes, but is not limited to, compartments for data storage, batteries, and connectors.
-

2

Notice to user

Typographical conventions

This manual uses the following typographical conventions:

- **Semibold** is used for menu names, menu commands and labels, and buttons in dialog boxes.
 - *Italic* is used for important information.
 - `Monospace` is used for code samples.
 - UPPERCASE is used for names on keys and buttons.
-

User-to-user forums

Exchange ideas, problems, and infrared solutions with fellow thermographers around the world in our user-to-user forums. To go to the forums, visit:

<http://www.infraredtraining.com/community/boards/>

Calibration

(This notice only applies to cameras with measurement capabilities.)

We recommend that you send in the camera for calibration once a year. Contact your local sales office for instructions on where to send the camera.

Accuracy

(This notice only applies to cameras with measurement capabilities.)

For very accurate results, we recommend that you wait 5 minutes after you have started the camera before measuring a temperature.

For cameras where the detector is cooled by a mechanical cooler, this time period excludes the time it takes to cool down the detector.

Disposal of electronic waste

10742803.a1



As with most electronic products, this equipment must be disposed of in an environmentally friendly way, and in accordance with existing regulations for electronic waste.

Please contact your FLIR Systems representative for more details.

3

Customer help

General

For customer help, visit:

<http://support.flir.com>

Submitting a question

To submit a question to the customer help team, you must be a registered user. It only takes a few minutes to register online. If you only want to search the knowledge-base for existing questions and answers, you do not need to be a registered user.

When you want to submit a question, make sure that you have the following information to hand:

- The camera model
 - The camera serial number
 - The communication protocol, or method, between the camera and your PC (for example, HDMI, Ethernet, USB™, or FireWire™)
 - Operating system on your PC
 - Microsoft® Office version
 - Full name, publication number, and revision number of the manual
-

Downloads

On the customer help site you can also download the following:

- Firmware updates for your infrared camera
 - Program updates for your PC software
 - User documentation
 - Application stories
 - Technical publications
-

4

Documentation updates

General

Our manuals are updated several times per year, and we also issue product-critical notifications of changes on a regular basis.

To access the latest manuals and notifications, go to the Download tab at:

<http://support.flir.com>

It only takes a few minutes to register online. In the download area you will also find the latest releases of manuals for our other products, as well as manuals for our historical and obsolete products.

5

Important note about this manual

General

FLIR Systems issues generic manuals that cover several cameras within a model line.

This means that this manual may contain descriptions and explanations that do not apply to your particular camera model.

NOTE

FLIR Systems reserves the right to discontinue models, software, parts or accessories, and other items, or to change specifications and/or functionality at any time without prior notice.

6

Quick Start Guide

Procedure

Follow this procedure to get started right away:

1	Charge the battery for four hours.
2	Insert the battery into the camera.
3	Insert an SD Memory Card into the card slot at the top of the camera.
4	Push the On/Off button to turn on the camera.
5	Set the correct object temperature range.
6	Aim the camera toward your target of interest.
7	Use the Focus button to focus the camera.
8	Push and hold down the Preview/Save button for more than one second to save the image.
9	To move the image to a computer, do one of the following: <ul style="list-style-type: none">■ Remove the SD Memory Card and insert it into a card reader connected to a computer.■ Connect a computer to the camera using a USB Mini-B cable.
10	Move the image from the card or camera using a drag-and-drop operation.

SEE

- Section 15.1 – Charging the battery on page 45
 - Section 15.2 – Inserting the battery on page 49
 - Section 12.2 – Inserting SD Memory Cards on page 40
 - Section 15.4 – Turning on the camera on page 53
 - Section 21.1 – Changing image settings on page 107
 - Section 19 – Working with measurement tools and isotherms on page 86
 - Section 12.1 – Connecting external devices on page 39
-

7

Parts lists

7.1

Contents of the transport case

Contents

- Battery
 - Battery charger
 - Bluetooth® USB micro adapter
 - Calibration certificate
 - FLIR QuickReport™ PC software CD-ROM
 - Headset
 - Infrared camera with lens
 - Mains cable
 - Memory card with adapter
 - Power supply
 - Printed Getting Started Guide
 - Sunshield
 - USB cable
 - User documentation CD-ROM
 - Video cable
 - Warranty extension card or Registration card
-

NOTE

- FLIR Systems reserves the right to discontinue models, parts or accessories, and other items, or to change specifications at any time without prior notice.
 - The inclusion of some items is dependent on camera model.
-

7.2 *List of accessories*

General

This section contains a list of accessories that you can purchase for your camera.

Accessories

- 1123970 Sun shield
- 1124544 Neck strap
- 1124545 Pouch
- 1196398 Battery
- 1196497 Cigarette lighter adapter kit, 12 VDC, 1.2 m/3.9 ft.
- 1196724 IR lens $f = 30$ mm, 15°
- 1196725 IR lens $f = 10$ mm, 45°
- 1196818 Lens cap camera
- 1196895 Hard transport case for ThermoCAM™ T Series
- 1196960 IR lens $f = 10$ mm, 45° incl. case
- 1196961 IR lens $f = 30$ mm, 15° incl. case
- 1910423 USB cable Std A <-> Mini-B, 2 m/6.6 ft.
- 1910475 Adapter, SD memory card to USB
- 1910489 Headset, 3.5 mm plug
- 1910496 SD memory card, 1 GB
- 1910582 Video cable
- EX845 CLAMP METER + IR THERM TRMS 1000A AC/DC
- MO297 MOISTURE METER, PINLESS WITH MEMORY
- T197209 FLIR Reporter Ver. 8.3 Professional (Sec. device)
- T197210 FLIR Reporter Ver. 8.3 Professional
- T197211 FLIR Reporter Ver. 8.3 Standard (Sec. device)
- T197212 FLIR Reporter Ver. 8.3 Standard
- T197214 Close-up $2\times$ ($50\ \mu\text{m}$) incl. case
- T197215 Close-up $4\times$ ($100\ \mu\text{m}$) incl. case
- T197408 Lens 76 mm (6°) with case and mounting support for T/B-200/400
- T197412 Lens 4 mm (90°) with case and mounting support for T/B-200/400
- T197453 FLIR ResearchIR
- T197454 FLIR QuickPlot
- T197613 FLIR BuildIR
- T197650 2-bay battery charger, incl. power supply with multi plugs
- T197667 Battery package
- T197716 FLIR Reporter Ver. 8.5 Standard
- T197717 FLIR Reporter Ver. 8.5 Professional
- T199800 One year extended warranty for T-Series
- T910737 Memory card micro-SD with adapters
- T910750 Power supply, incl. multi plugs

NOTE

FLIR Systems reserves the right to discontinue models, parts or accessories, and other items, or to change specifications at any time without prior notice.

8

A note about ergonomics

General

To prevent strain injuries, it is important that you hold the camera ergonomically correct. This section gives advice and examples on how to hold the camera.

NOTE


Please note the following:

- Always adjust the angle of the lens to suit your work position.
 - When you hold the camera, make sure that you support the camera housing with your left hand too. This decreases the strain on your right hand.
-

Figure


10758503.a1

10758603.a1



10758803.a1

10758703.a1



SEE ALSO


- Section 15.8 – Adjusting the angle of lens on page 54
-

9 Camera parts

9.1 View of the rear

Figure

10758903.a1



Explanation

This table explains the figure above:

1	Touch screen LCD
2	Cover for SD Memory Card slot


3	<p>Zoom button</p> <ul style="list-style-type: none"> ■ The zoom button has the following functions on live images: <ul style="list-style-type: none"> ■ Push to enter the zoom state. ■ Use the joystick to zoom into or out of an image. ■ Push the zoom button once again to reset to 1× zoom factor. ■ Push the A/M button, the joystick, or the Preview/Save button to confirm the zoom factor and leave the zoom state. ■ The zoom button has the following functions on still images: <ul style="list-style-type: none"> ■ Zooming: <ul style="list-style-type: none"> ■ Push to enter the zoom state. ■ Use the joystick to zoom into or out of an image. ■ Push the zoom button once again to reset to 1× zoom factor. ■ Push the A/M button or the Preview/Save button to confirm the zoom factor and leave the zoom state. ■ Panning: <ul style="list-style-type: none"> ■ Push to enter the zoom state. ■ Push the joystick to enter the pan state. ■ Use the joystick to pan over an image. ■ Push the joystick to confirm the pan position and leave the pan state.
4	<p>Stylus pen</p> <p>Note: Push the stylus pen firmly into its holder when not in use.</p>
5	<p>Camera button</p> <p>The camera button has the following functions:</p> <ul style="list-style-type: none"> ■ On live images: Switch between the infrared camera and the digital camera (IR > DC). ■ On live fusion images: Switch between fusion and infrared imagery. Switching between fusion and infrared imagery enables you to accurately focus the infrared image (IR > DC > fusion). <p>You can set up the behavior of this button under Setup.</p>
6	<p>Joystick</p> <p>The joystick has the following functions:</p> <ul style="list-style-type: none"> ■ In live infrared manual mode, and in still infrared mode: <ul style="list-style-type: none"> ■ Push up/down to adjust the level. ■ Push left/right to adjust the span. ■ In menus, in dialog boxes, and in the image archive: <ul style="list-style-type: none"> ■ Push up/down or left/right to navigate. ■ Push to confirm choices.

7	<p>A/M button</p> <p>The A/M button has the following functions:</p> <ul style="list-style-type: none"> ■ Push to switch between automatic and manual adjustment modes. ■ Push and hold down for more than one second to perform a non-uniformity correction. ■ In still infrared mode: Switch user focus between the documentation toolbar and the temperature scale. ■ In still infrared mode and in recall mode: Push and hold down for more than one second to perform a one-shot auto-adjust.
8	<p>Measure button</p> <p>The Measure button has the following functions:</p> <ul style="list-style-type: none"> ■ In live infrared mode: Push to display/hide the measurement menu. ■ In still infrared mode: Push to display/hide the measurement toolbar.
9	<p>Info button</p> <p>The function of the Info button is to display different levels of information on the screen.</p>
10	<p>Setup button</p> <p>The function of the Setup button is to display/hide the setup menu. In the setup mode you can change image settings, camera settings, and regional settings.</p>
11	<p>Archive button</p> <p>The Archive button has the following functions:</p> <ul style="list-style-type: none"> ■ Push to open the image archive. ■ Push to close the image archive.
12	<p>Mode button</p> <p>The function of the mode button is to display/hide the mode selector.</p>
13	<p>On/Off button.</p> <p>The On/Off button has the following functions:</p> <ul style="list-style-type: none"> ■ To turn on the camera, push the On/Off button. ■ To turn off the camera, push and hold down the On/Off button for more than 2 seconds. ■ To enter the standby mode, push and hold down the On/Off button for approx. 0.2 seconds. ■ To exit the standby mode, push and hold down the On/Off button for approx. 0.2 seconds. <p>The On/Off button is also a power indicator that shows when the camera is on.</p>
14	<p>Hand strap</p>

9.2 View of the front

Figure

10759003.a1



Explanation

This table explains the figure above:

1	<p>Laser pointer button</p> <p>The laser pointer button has the following functions:</p> <ul style="list-style-type: none"> ■ Push the laser pointer button to turn on the laser pointer. ■ Release the laser pointer button to turn off the laser pointer.
2	<p>Preview/Save button</p> <p>The Preview/Save button has the following functions:</p> <ul style="list-style-type: none"> ■ Push the Preview/Save button to preview an image. At this point you can annotate the image with a digital photo, a text annotation, a voice annotation, image markers, etc. ■ Push and hold down the Preview/Save button for more than one second to save an infrared image in the infrared camera mode (without previewing). ■ Push and hold down the Preview/Save button for more than one second to save a digital photo in the digital camera mode (without previewing).

3	Focus button The focus button has the following functions: <ul style="list-style-type: none">■ Move the Focus button left for far focus.■ Move the Focus button right for close focus.■ Briefly push the Focus button to autofocus. Note: It is important that you hold the camera steady while autofocusing.
4	Protective edge for the focus button
5	Attachment point for the neck strap
6	Video lamp
7	Digital camera lens
8	Release button for additional infrared lenses
9	Laser pointer
10	Infrared lens
11	Lens cap for the infrared lens


NOTE

The laser pointer may not be enabled in all markets.

9.3 View of the bottom side

Figure

10759103.a1



Explanation


This table explains the figure above:

1	Tripod mount 1/4"-20
2	Release button for the cover to the connector bay
3	Cover for the connector bay
4	Release button for the battery compartment cover
5	Cover for the battery compartment

9.4 Battery condition indicator

General The battery has a battery condition indicator.

Figure 10715703.a3



Explanation

This table explains the battery condition indicator:

Type of signal	Explanation
The green light flashes.	The power supply or the stand-alone battery charger is charging the battery.
The green light is continuous.	The battery is fully charged.
The green light is off.	The camera is using the battery (instead of the power supply).

9.5 *Laser pointer*


General

The camera has a laser pointer. When the laser pointer is on, you can see a laser dot approximately 40 mm (1.57 in.) above the target.

Figure

This figure shows the difference in position between the laser pointer and the optical center of the infrared lens:

10759203.a1



-
- WARNING** Do not look directly into the laser beam. The laser beam can cause eye irritation.
-
- CAUTION** Protect the laser pointer with the protective cap when you are not using the laser pointer.
-
- NOTE**
- A laser warning symbol is displayed on the screen when the laser pointer is on.
 - The laser pointer may not be enabled in all markets.
-

Laser warning label

A laser warning label with the following information is attached to the camera:



Laser rules and regulations

Wavelength: 635 nm. Max. output power: 1 mW.

This product complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50, dated June 24, 2007.

10

Toolbars and work areas

10.1

Work areas

10.1.1


Operation mode area

NOTE

- The operation mode area becomes visible when you push the Mode button.
- To navigate in the area, use either the joystick or the stylus pen.

Figure

10765803.a3



Explanation

This table explains the figure above:


1	<p>Camera mode</p> <p>This is the most commonly used operation mode of the camera.</p> <p>You select this mode to save an infrared image to the SD Memory Card.</p> <p>If you push the Preview/Save button, the documentation toolbar will be displayed.</p>
----------	--

2	<p>Video mode</p> <p>If you select this mode, you can record video clips with the camera. You start and stop the recording by pushing the Preview/Save button.</p> <p>For more information about this, see section 10.2.5 – Video recording toolbar on page 34 and section 18 – Recording video clips on page 85.</p>
3	<p>Simultaneous snapshot mode</p> <p>If you select this mode, and push and hold down the Preview/Save button for more than one second, the camera will automatically save a digital photo at the same time as it saves the infrared image.</p> <p>Note: The simultaneous snapshot mode only works when you take an infrared image. If you take a digital photo, no infrared image will be saved.</p>
4	<p>Program mode</p> <p>If you select this mode, you can periodically save images at a specified time interval.</p>
5	<p>Panorama mode</p> <p>If you select this mode, you can create large images by stitching normal images together.</p>

10.1.2 Main work area

Figure

10760703.a1



Explanation

This table explains the figure above:

1	Measurement results table (in °C or °F, depending on the settings)
2	Measurement menu. To open and close this menu, push the Measure button.
3	Indicator for the automatic adjustment mode or the manual adjustment mode (A/M)
4	Spotmeter
5	Temperature scale
6	Measurement area
7	Limit indicator for the temperature scale


10.1.3 Sketch work area

NOTE

- The sketch work area becomes visible when you add a sketch to an infrared image. You do this from the documentation toolbar.
- To navigate in the area, use either the joystick or the stylus pen.
- To draw the sketch, use the stylus pen.

Figure

10762203.a1



Explanation

This table explains the figure above:

1	Canvas You draw your sketch in this area, using the stylus pen.
2	OK button You select this button to confirm the sketch and leave the sketch mode.
3	Clear button You select this button to clear the whole canvas.
4	Pen button You select this button to enable the pen.
5	Eraser button You select this button to enable the eraser.
6	Color palette You select this color swatch to switch between colors.

SEE ALSO

For information about adding a sketch to an infrared image, see section 20.5 – Adding a sketch on page 105.

10.1.4 Text annotation and image description work area


NOTE

- The text annotation and image description work area becomes visible when you add a text annotation or an image description to an infrared image. You do this from the documentation toolbar. To display the documentation toolbar, push the Preview/Save button.
- To navigate in the area, use either the joystick or the stylus pen.

Figure

This figure shows the text annotation work area:

10765603.a2



Explanation

This table explains the figure above:

1	OK button You select this button to confirm and save the text annotation.
2	Tab for the text annotation work area (to select from pre-defined strings)
3	Tab for the image description work area (to enter the free text mode, using the stylus pen)
4	Filename indicator for the text annotation file
5	Text annotation label
6	Text annotation value
7	Submenu displaying additional text annotation values

8	Keyboard button You select this button to go to the keyboard and enter text using the stylus pen.
9	Clear button You select this button to clear all input data from the selected tab.


SEE ALSO

For information about adding a text annotation to an infrared image, see section 20.3 – Adding a text annotation on page 101.

Figure

This figure shows the image description work area:

10765703.a1



Explanation

This table explains the figure above:

1	OK button You select this button to confirm and save the text annotation.
2	Tab for the text annotation work area (to select from pre-defined strings)
3	Tab for the image description work area (to enter the free text mode, using the stylus pen)
4	Preview window for the image description
5	Keyboard
6	Clear button You select this button to clear all input data from the selected tab.

SEE ALSO

For information about adding an image description to an infrared image, see section 20.4 – Adding an image description on page 104.

10.2 Toolbars


10.2.1 Measurement toolbar

NOTE

- The measurement toolbar becomes visible when you push the Measure button and select **Advanced**.
- You use the measurement toolbar to set up measurement tools in the advanced mode, or when editing a saved image in the archive mode.
- To navigate on the toolbar, use either the joystick or the stylus pen.

Figure

10760803.a3



Explanation

This table explains the figure above:

1	<p>You select this toolbar button to do one or more of the following:</p> <ul style="list-style-type: none"> ■ Move measurement tools ■ Remove measurement tools ■ Turn on and turn off alarms (only for spotmeters and areas). ■ Set alarm levels (only for spotmeters and areas).
2	<p>Isotherm toolbar button</p> <p>You select this toolbar button to set up different types of isotherms. The isotherm command colors all pixels with a temperature above, below, or between one or more preset temperature levels.</p>
3	<p>Spotmeter toolbar button</p> <p>You select this toolbar button to create a spotmeter.</p>
4	<p>Area toolbar button</p> <p>You select this toolbar button to create a measurement area.</p>
5	<p>Difference calculation toolbar button</p> <p>You select this toolbar button to set up a difference calculation.</p>
6	<p>Object parameters toolbar button</p> <p>You select this toolbar button to change object parameters. Setting the correct object parameters is important if precise measurement results are required.</p>

7	<p>OK toolbar button</p> <p>You use this button if you arrive at this toolbar from the documentation toolbar. Selecting this toolbar button after you have changed the desired parameter returns you to the documentation toolbar.</p> <p>This toolbar button will only be displayed if you arrive at this toolbar from the documentation toolbar.</p>
----------	---


10.2.2 Documentation toolbar

NOTE

- The documentation toolbar becomes visible when you preview an image, or when you edit an image from the image archive.
- To preview an image, push and hold down the Save button for more than one second.
- To navigate on the toolbar, use either the joystick or the stylus pen.

Figure

10760903.a2



Explanation

This table explains the figure above:

1	<p>Delete image toolbar button</p> <p>You select this toolbar button to discard the image that you are previewing.</p>
2	<p>Add markers toolbar button</p> <p>You select this tool to add arrow markers to points of interest in an infrared image. The arrow marker will be saved in the infrared image.</p>
3	<p>Measurement toolbar button</p> <p>You select this tool to go to the measurement toolbar, where you can change a variety of parameters before you save the image.</p>
4	<p>Add sketch toolbar button</p> <p>You select this toolbar button to add a freehand sketch to an infrared image. The sketch will be linked to the infrared image.</p>
5	<p>Add voice annotation toolbar button</p> <p>You select this toolbar button to add a voice annotation to an infrared image. The voice annotation will be saved in the infrared image.</p>
6	<p>Add text annotation toolbar button</p> <p>You select this toolbar button to add text annotations and/or image descriptions to an infrared image. Text annotations and image descriptions will be saved in the infrared image.</p>
7	<p>Add digital photo toolbar button</p> <p>You select this toolbar button to add a digital photo to the infrared image. The digital photo will be linked to the infrared image.</p>

8	Save toolbar button You select this toolbar button to save the infrared image after you have added any of the previous five annotations. If you have opened an image from the image archive, this toolbar button says Close instead of Save .
----------	---


10.2.3 Image marker toolbar

NOTE

- The image marker toolbar becomes visible when you add an image marker. You do this from the documentation toolbar.
- To navigate on the toolbar, use either the joystick or the stylus pen.

Figure

10762303.a2



Explanation

This table explains the figure above:

1	You select this toolbar button to move and remove any markers you have previously added to the image.
2	<p>Marker toolbar button</p> <p>You select this toolbar button to create a marker. Tap gently on the toolbar button using the stylus pen, and then draw a line on the image.</p>
3	<p>OK toolbar button</p> <p>You select this toolbar button to confirm any markers you have added to the image before leaving this work mode.</p>


10.2.4 Voice annotation toolbar

NOTE

- The voice annotation toolbar becomes visible when you record or listen to a voice comment. You do this from the documentation toolbar.
- To navigate on the toolbar, use either the joystick or the stylus pen.
- Some buttons have more than one function, and the symbols on the buttons will change depending on the context.

Figure

10763803.a2



Explanation

This table explains the figure above:

1	Discard recording toolbar button You select this toolbar button to delete a voice comment that you have made.
2	Adjust volume toolbar button You select this toolbar button and move the joystick up/down to adjust the volume when you play back voice comments.
3	Start/stop recording toolbar button You select this toolbar button to start and stop the recording of a voice comment.
4	Start/stop playback toolbar button You select this toolbar button to start and stop the playback of a previously recorded voice comment.
5	Go to beginning toolbar button You select this toolbar button to go back to the beginning of the recording.
6	OK toolbar button You select this toolbar button to confirm and save the previously recorded voice comment.
7	Time indicator (X/Y seconds, where X = elapsed recording time and Y = total recording time)


10.2.5 Video recording toolbar

NOTE

- The video recording toolbar becomes visible when you have recorded a video clip
- To navigate on the toolbar, use either the joystick or the stylus pen.
- Some buttons have more than one function, and the symbols on the buttons will change depending on the context.

Figure

T630231:a2



Explanation

This table explains the figure above:

1	Discard recording toolbar button You select this toolbar button to delete the video recording that you have made.
2	Start/stop playback toolbar button You select this toolbar button to start and stop the playback of the video recording.
3	Go to beginning toolbar button You select this toolbar button to go back to the beginning of the recording.
4	OK toolbar button You select this toolbar button to confirm and save the recorded video recording that you have made.
5	Time indicator (X/Y seconds, where X = elapsed recording time and Y = total recording time)

SEE ALSO

For more information about this, see section 10.1.1 – Operation mode area on page 20 and section 18 – Recording video clips on page 85.


10.2.6 Periodic save toolbar

NOTE

- The periodic save toolbar becomes visible when you go to **Program** mode.
- To navigate on the toolbar, use either the joystick or the stylus pen.

Figure

T630370.a1



Explanation

This table explains the figure above:

1	<p>Setup toolbar button</p> <p>You select this toolbar button to set up the camera for periodic saving.</p>
2	<p>Start periodic save toolbar button</p> <p>You select this toolbar button to start the periodic save.</p>

SEE ALSO

For more information about this, see section 16.4 – Periodically saving an image on page 65.


10.2.7 Work folder toolbar

NOTE

- The work folder toolbar becomes visible when you select a work folder in Setup mode.
- To navigate on the toolbar, use either the joystick or the stylus pen.

Figure

T630371:a1



Explanation

This table explains the figure above:

1	Create new folder toolbar button
2	Delete folder toolbar button
3	Close toolbar button


SEE ALSO

For more information about this, see section 16.11 – Working with folders on page 75.

11

Navigating the menu system

Figure



Explanation

The figure above shows the two ways to navigate the menu system in the camera:

- Using the stylus pen to navigate the menu system (left).
- Using the joystick to navigate the menu system (right).

You can also use a combination of the two.

In this manual it is assumed that the joystick is used, but most tasks can also be carried out using the stylus pen.

General


You can connect the following external devices and storage media to the camera:

- A power supply.
 - A video monitor.
 - A computer to move images and other files to and from the camera.
 - An external USB device, such as a USB keyboard or USB memory stick.
 - A Bluetooth® USB micro adapter, in order to capture measurement results from an Extech® external meter (such as a clamp meter or a moisture meter).
 - A headset to record and listen to voice comments.
 - An SD Memory Card.
-

12.1 Connecting external devices

Figure

10759303.a3



Explanation

This table explains the figure above:

1	To connect a headset to the camera to record and listen to voice comment, use a headset cable and this socket.
2	To connect a video monitor to the camera, use a CVBS cable (a composite video cable) and this socket.
3	To connect a computer to the camera to move images and files to and from the camera, use a USB Mini-B cable and this socket.
4	One of the following: <ul style="list-style-type: none"> ■ To connect a Bluetooth® USB micro adapter to the camera, in order to capture measurement results from an Extech® external meter (such as a clamp meter or a moisture meter), use this socket. ■ To connect an external USB device, such as a USB memory stick, use this socket.


Supported Extech® meters

- Extech® Moisture Meter MO297
- Extech® Clamp Meter EX845

12.2 Inserting SD Memory Cards

Figure

10759503.a1



Procedure

Follow this procedure to insert an SD Memory Card:

1	Open the rubber cover that protects the card slot.
2	Push the SD Memory Card firmly into the card slot, until a clicking sound is heard.

13

Pairing Bluetooth® devices

General

Before you can use a Bluetooth® device with the camera, you need to pair the devices.

Procedure

Follow this procedure:

1	Insert a Bluetooth® USB micro adapter into the USB connector.
2	Turn on the camera.
3	Push the Setup button.
4	Go to the Connect tab.
5	To select Add device , move the joystick up/down.
6	Push the joystick. At this stage you need to refer to the user documentation for your Bluetooth® device. During the pairing sequence you may need to refresh the dialog box by clicking Refresh .

14


Fetching data from external Extech meters

General

You can fetch data from an external Extech meter and merge this data into the result table in the infrared image.

Figure

T638370,a1



Supported Extech meters

- Extech Moisture Meter MO297
- Extech Clamp Meter EX845

Technical support for Extech meters

support@extech.com

This support is for Extech meters only. For technical support for infrared cameras, go to <http://support.flir.com>.

NOTE

- This procedure assumes that you have paired the Bluetooth devices.
- For more information about products from Extech Instruments, go to <http://www.extech.com/instruments/>.

Procedure

Follow this procedure:

1	Turn on the camera.
2	Turn on the Extech meter.

3	On the meter, enable Bluetooth mode. Refer to the user documentation for the meter for information on how to do this.
4	On the meter, choose the quantity that you want to use (voltage, current, resistance, etc.). Refer to the user documentation for the meter for information on how to do this. Results from the meter will now automatically be displayed in the result table in the top left corner of the infrared camera screen.
5	Do one of the following: <ul style="list-style-type: none"><li data-bbox="353 400 1004 472">■ To preview an image, push the Preview/Save button. At this stage, you can add additional values. To do so, take a new measurement with the meter and select Add on the infrared camera screen.<li data-bbox="353 480 1004 528">■ To save an image without previewing, push and hold down the Preview/Save button.<li data-bbox="353 536 1004 632">■ To add a value to a recalled image, turn on the meter after you have recalled the image, then select Add on the infrared camera screen. A maximum of eight values can be added, but note that some values are broken into two lines.

14.1 *Typical moisture measurement and documentation procedure*

General

The following procedure can form the basis for other procedures using Extech meters and infrared cameras.

Procedure

Follow this procedure:

1	Use the infrared camera to identify any potential damp areas behind walls and ceilings.
2	Use the moisture meter to measure the moisture levels at various suspect locations that may have been found.
3	When a spot of particular interest is located, store the moisture reading in the moisture meter's memory and identify the measurement spot with a handprint or other thermal identifying marker.
4	Recall the reading from the meter memory. The moisture meter will now continuously transmit this reading to the infrared camera.
5	Use the camera to take a thermal image of the area with the identifying marker. The stored data from the moisture meter will also be saved on the image.

15

Handling the camera

15.1 *Charging the battery*

NOTE You must charge the battery for four hours before you start using the camera for the first time.

General You must charge the battery when a low battery voltage warning is displayed on the screen.

Follow one of these procedures to charge the battery:

- Use the combined power supply and battery charger to charge the battery when it is inside the camera.
 - Use the combined power supply and battery charger to charge the battery when it is outside the camera.
 - Use the stand-alone battery charger to charge the battery
-

SEE For information on how to charge the battery, see the following sections:

- Section 15.1.1 – Using the combined power supply and battery charger to charge the battery when it is inside the camera on page 46
 - Section 15.1.2 – Using the combined power supply and battery charger to charge the battery when it is outside the camera on page 47
 - Section 15.1.3 – Using the stand-alone battery charger to charge the battery on page 48
-

15.1.1 Using the combined power supply and battery charger to charge the battery when it is inside the camera

NOTE For brevity, the 'combined power supply and battery charger' is called the 'power supply' below.

Procedure Follow this procedure to use the power supply to charge the battery when it is inside the camera:

1	Open the battery compartment lid.
2	Connect the power supply cable plug to the connector on the battery.
3	Connect the power supply mains-electricity plug to a mains socket.
4	Disconnect the power supply cable plug when the green light of the battery condition indicator is continuous.

SEE ALSO For information about the battery condition indicator, see section 9.4 – Battery condition indicator on page 17.

15.1.2 Using the combined power supply and battery charger to charge the battery when it is outside the camera

NOTE For brevity, the 'combined power supply and battery charger' is called the 'power supply' below.

Procedure Follow this procedure to use the power supply to charge the battery when it is outside the camera:

1	Put the battery on a flat surface.
2	Connect the power supply cable plug to the connector on the battery.
3	Connect the power supply mains-electricity plug to a mains socket.
4	Disconnect the power supply cable plug when the green light of the battery condition indicator is continuous.

SEE ALSO For information about the battery condition indicator, see section 9.4 – Battery condition indicator on page 17.

15.1.3 Using the stand-alone battery charger to charge the battery

Procedure

Follow this procedure to use the stand-alone battery charger to charge the battery:

1	Put the battery in the stand-alone battery charger.
2	Connect the power supply cable plug to the connector on the stand-alone battery charger.
3	Connect the power supply mains-electricity plug to a mains socket.
4	Disconnect the power supply cable plug when the green light of the battery condition indicator is continuous.

SEE ALSO

For information about the battery condition indicator, see section 9.4 – Battery condition indicator on page 17.



15.2 Inserting the battery

NOTE

Use a clean, dry cloth to remove any water or moisture on the battery before you insert it.

Procedure

Follow this procedure to insert the battery:

1	<p>Push the release button on the battery compartment cover to unlock it.</p> <p>10759603.a:1</p> 
2	<p>Open the cover to the battery compartment.</p> <p>10759703.a:1</p> 
3	<p>Push the battery into the battery compartment until the battery locking mechanism engages.</p> <p>10759803.a:1</p> 

4 Close the cover to the battery compartment.



10759903.a:1



15.3 Removing the battery


Procedure

Follow this procedure to remove the battery:

1	<p>Push the release button on the battery compartment cover to unlock it.</p> <p>10759603:a1</p> 
2	<p>Open the cover to the battery compartment.</p> <p>10763903:a1</p> 
3	<p>Push the red release button in the direction of the arrow to unlock the battery.</p> <p>10760003:a2</p> 

4 Pull out the battery from the battery compartment.

10760103.a:1



15.4 *Turning on the camera*

Procedure To turn on the camera, push and release the On/Off button.

15.5 *Turning off the camera*

Procedure To turn off the camera, push and hold down the On/Off button for more than 2 second.

15.6 *Entering standby mode*

Procedure To enter the standby mode, push and hold down the On/Off button for approx. 0.2 seconds.

15.7 *Exiting standby mode*

Procedure To exit the standby mode, push and hold down the On/Off button for approx. 0.2 seconds.


15.8 *Adjusting the angle of lens*

General

To make your working position as comfortable as possible, you can adjust the angle of the lens.

Figure

10760203.a1



Procedure

To adjust the angle, tilt the lens up or down.




15.9



Mounting an additional infrared lens**NOTE**

Do not touch the lens surface when you mount an infrared lens. If this happens, clean the lens according to the instructions in section 22.2 – Infrared lens on page 111.

Procedure

Follow this procedure to mount an additional infrared lens:

1	<p>Push the lens release button to unlock the lens cap.</p> <p>10764003.a:1</p>  <p>A line drawing showing a hand holding a camera. The index finger is pressing a small button on the lens cap. A thick black arrow points downwards from the button.</p>
2	<p>Rotate the lens cap 30° counter-clockwise (looking at the front of the lens).</p> <p>10764103.a:1</p>  <p>A line drawing showing a hand holding a camera. The index finger is rotating the lens cap. A thick black curved arrow indicates a counter-clockwise rotation.</p>
3	<p>Carefully pull out the lens cap from the bayonet ring.</p> <p>10764203.a:1</p>  <p>A line drawing showing a hand holding a camera. The index finger is pulling the lens cap away from the lens. A thick black arrow points upwards from the cap.</p>

<p>4</p>	<p>Correctly position the lens in front of the bayonet ring.</p> <p>10764303.a:1</p> 
<p>5</p>	<p>Carefully push the lens into position.</p> <p>10764403.a:1</p> 
<p>6</p>	<p>Rotate the lens 30° clockwise (looking at the front of the lens).</p> <p>10764503.a:1</p> 



15.10 Removing an additional infrared lens




NOTE

- Do not touch the lens surface when you remove an infrared lens. If this happens, clean the lens according to the instructions in section 22.2 – Infrared lens on page 111.
- When you have removed the lens, put the lens caps on the lens immediately, to protect it from dust and fingerprints.

Procedure

Follow this procedure to remove an additional infrared lens:

<p>1</p> <p>Push the lens release button to unlock the lens.</p> <p><small>10764603.a:1</small></p>	
<p>2</p> <p>Rotate the lens counter-clockwise 30° (looking at the front of the lens).</p> <p><small>10764703.a:1</small></p>	
<p>3</p> <p>Carefully pull out the lens from the bayonet ring.</p> <p><small>10764803.a:1</small></p>	

<p>4</p>	<p>Correctly position the lens cap in front of the bayonet ring.</p> <p>10764903.a:1</p> 
<p>5</p>	<p>Carefully push the lens cap into position.</p> <p>10765003.a:1</p> 
<p>6</p>	<p>Rotate the lens cap 30° clockwise (looking at the front of the lens).</p> <p>10765103.a:1</p> 




15.11

Attaching the sunshield**General**

You can attach a sunshield to the camera to make the LCD screen easier to see in sunlight.


Procedure

Follow this procedure to attach the sunshield to the camera:

<p>1</p> <p>10765203;a:1</p>	<p>Align the two front tabs of the sunshield with the corresponding two notches at the top of the screen.</p> 
<p>2</p> <p>10765303;a:1</p>	<p>Push the front part of the sunshield into position. Make sure that the two tabs mate with the corresponding notches.</p> 
<p>3</p> <p>10765403;a:1</p>	<p>Carefully hold together the two rear wings of the sunshield.</p> 

- 4** Push the rear part of the sunshield toward the screen, and then release your grip. Make sure that the two tabs mate with the corresponding notches.


10765503.a1



15.12 Using the laser pointer

Figure

10760303.a1



Procedure

Follow this procedure to use the laser pointer:

1	To turn on the laser pointer, push and hold the laser pointer button.
2	To turn off the laser pointer, release the laser pointer button.

NOTE

The laser pointer may not be enabled in all markets.

16

Working with images and folders

16.1

Adjusting the infrared camera focus

Procedure

To adjust the infrared camera focus, do one of the following:

- Push the focus button left for far focus.
 - Push the focus button right for near focus.
 - Briefly push the focus button toward the camera button to autofocus.
-

NOTE

It is important that you hold the camera steady while autofocusing.

16.2 *Previewing an image*

General

In preview mode, you can add various types of annotations to the image before you save it. You do this by using the documentation toolbar that is automatically displayed when you preview an image.

In preview mode you can also check that the image contains the required information before you save it to the SD Memory Card.

Procedure

To preview an image, push Preview/Save button.

SEE ALSO

- For more information about the documentation toolbar, see section 10.2.2 – Documentation toolbar on page 30.
 - For more information about adding annotations, see section 20 – Annotating images on page 98.
-

16.3 Saving an image

General

You can save one or more images to the SD Memory Card.

Formatting memory cards

For best performance, memory cards should be formatted to the FAT (FAT16) file system. Using FAT32-formatted memory cards may result in inferior performance. To format a memory card to FAT (FAT16), follow this procedure:

1	Insert the memory card into a card reader that is connected to your computer.
2	In Windows® Explorer, select My Computer and right-click the memory card.
3	Select Format .
4	Under File system , select FAT .
5	Click Start .

Image capacity

This table gives information on the *approximate* number of images that can be saved on SD Memory Cards:

Card size	No voice annotation	Incl. 30 seconds voice annotation
256 MB	500	250
512 MB	1000	500
1 GB	2000	1000

Procedure

To save an image without previewing, push and hold down the Preview/Save button for more than one second.

16.4 Periodically saving an image

General

You can periodically save images at a specified time interval.

Procedure

Follow this procedure to periodically save an image:

1	Push the Mode button.
2	Use the joystick to select Program .
3	Push the joystick.
4	Move the joystick to the  toolbar button, then push the joystick. This will display a setup menu.
5	Use the joystick to set the desired parameters.
6	To start the periodic save, move the joystick to the  toolbar button, then push the joystick. The periodic save has now started, and the following toolbar is displayed: 
7	To stop the recording, move the joystick to the  toolbar button, then push the joystick.

16.5 *Opening an image*

General

When you save an image, it is stored on the SD Memory Card. To display the image again, you can recall it from the SD Memory Card.

Procedure

Follow this procedure to open an image:

1	Push the Archive button to open the most recently saved image.
2	If you want to open another image, do one of the following: <ul style="list-style-type: none">■ 1 Move the joystick upwards. This will display the images as thumbnails.■ 2 Select the image you want to open by using the joystick.■ 3 Push the Select button to open this image.■ Move the joystick left/right. This will display the next/previous image in the full image mode.

NOTE

To leave archive mode, push the Archive button.

16.6 Using the Panorama function

General

The camera has a **Panorama** function. This means that you can create larger images by stitching normal images together.

The images are stored in the camera using a special mode. The actual stitching takes place in FLIR Systems PC software for post-processing, for example FLIR Reporter or .


NOTE

- When you enter this mode, all graphics are removed from the screen.
- When you enter this mode, all measurement tools are disabled, but will be enabled when you leave the mode.
- In thumbnail view, the images that are created using this function display the icon



Procedure

To create a **Panorama** image, follow this procedure:

1	Push the Mode button.
2	Use the joystick to select Panorama .
3	<p>Push the joystick. This will display the following screen:</p>  <p>T630364.a1</p> <p>The screen is divided into nine areas using four guidelines. In the tools pane, a blue rectangle indicates which section of the screen you will save when saving an image at this time.</p> <p>Note that the guidelines are only intended as an aid when you move the camera to the next area for which you want to save an image. Thus, the guidelines make it easy for you to align the images.</p>

<p>4</p>	<p>To save an image, push and hold down the Preview/Save button for more than one second.</p> <p>The saved image will now be displayed in the corresponding area in the tools pane. You can also see that the left-most area on the screen shows the image you just saved (indicated here in red):</p>  <p>The screenshot shows a dark grey grid interface. On the left side, there is a vertical red bar. In the bottom right corner of the grid, there is a small menu with two options: 'Direction' (with a four-way arrow icon) and 'New' (with a circular arrow icon). Below these options, there is a small red and blue bar.</p>
<p>5</p>	<p>Using the joystick, you can now decide in which area you want to save the next image, and then save the image by pushing the Preview/Save button.</p> <p>Continue using this procedure until you have created your complete image.</p>
<p>6</p>	<p>To finish and leave this mode, push the Mode button.</p>

16.7 Adjusting an image manually

General

An image can be adjusted *automatically* or *manually*.


These two modes are indicated in the top right corner of the screen by the letters A and M. You use the A/M button to switch between these two modes

Example 1

This figure shows two infrared images of cable connection points. In the left image a correct analysis of the circled cable is difficult if you only auto-adjust the image. You can analyze this cable in more detail if you

- change the temperature scale level
- change the temperature scale span.

In the image, the image is auto-adjusted. In the right image the maximum and minimum temperature levels have been changed to temperature levels near the object. On the temperature scale to the right of each image you can see how the temperature levels were changed.




Example 2

This figure shows two infrared images of an isolator in a power line.

In the left image, the cold sky and the power line structure are recorded at a minimum temperature of -26.0°C (-14.8°F). In the right image the maximum and minimum temperature levels have been changed to temperature levels near the isolator. This makes it easier to analyze the temperature variations in the isolator.

10742503.a3



A (automatic)

M (manual)

Changing temperature the scale level

Follow this procedure to change the temperature scale level:

1	Make sure that the camera displays a live infrared image. To do this, select Camera mode using the Mode button and the joystick.
2	Make sure that the camera is in the manual adjustment mode. This is indicated by the letter M in the top right corner of the screen. If not, push the A/M button once.
3	To change the temperature scale level, move the joystick up/down. Note that this changes both the minimum and maximum scale level temperature by the same amount.

Changing temperature the scale span

Follow this procedure to change the temperature scale span:

1	Make sure that the camera displays a live infrared image.
2	Make sure that the camera is in the manual adjustment mode. This is indicated by the letter M in the top right corner of the screen. If not, push the A/M button once.
3	To change the temperature scale span, move the joystick left/right.

16.8 *Hiding overlay graphics*

General Overlay graphics provide information about an image. You can choose to hide overlay graphics incrementally in steps.

Procedure To hide overlay graphics in steps, push the Info button.

16.9 *Deleting an image*

General

You can delete one or more images from the SD Memory Card.

Procedure

Follow this procedure to delete an image:

1	Push the Archive button.
2	Do one of the following: <ul style="list-style-type: none"> ■ Move the joystick left/right to select the image you want to delete, then go to Step 5 below. ■ Move the joystick upwards to display the images as thumbnails, then go to Step 3 below.
3	Select the image you want to delete by using the joystick.
4	Push the joystick to open the image.
5	Push the joystick to display a menu.
6	On the menu, select Delete image by using the joystick.
7	Push the joystick to confirm.

16.10 *Deleting all images*

General You can delete all images from the SD Memory Card.

Procedure Follow this procedure to delete all images:

1	Push the Archive button.
2	Push the joystick to display a menu.
3	On the menu, select Delete all by using the joystick.
4	Push the joystick to confirm.

16.11 Working with folders

General

You can arrange your images in different folders, and delete folders that you do not use.

Procedure

Follow this procedure to create a new folder:

1	Push the Setup button.
2	Go to the Camera tab.
3	Select Work folder .
4	Push the joystick.
5	To create a new folder, move the joystick to the right to select the  toolbar button, then push the joystick. A new folder has now been created.
6	Push the Mode button to leave the dialog box.

NOTE

Using an Eye-Fi® memory card will automatically create and populate a DCIM folder and let you upload the infrared images and visual photos to Flickr, Facebook, Picasa, MobileMe, YouTube, FTP, etc.

For more information, go to <http://www.eye.fi>

Procedure

Follow this procedure to delete a folder:

1	Push the Setup button.
2	Go to the Camera tab.
3	Select Work folder .
4	Push the joystick.
5	To delete a folder, select the folder using the joystick.
6	Move the joystick to the right to select the  toolbar button, then push the joystick. The folder has now been deleted.
7	Push the Mode button to leave the dialog box.

NOTE

Using an Eye-Fi® memory card will automatically create and populate a DCIM folder and let you upload the infrared images and visual photos to Flickr, Facebook, Picasa, MobileMe, YouTube, FTP, etc.

For more information, go to <http://www.eye.fi>

Procedure

Follow this procedure to set a folder as a work folder:

1	Push the Setup button.
2	Go to the Camera tab.
3	Select Work folder .
4	Push the joystick.
5	(This step assumes that you have more than one work folder.) To set another folder as a work folder, select the folder using the joystick, then push the joystick. The new folder is now set as a work folder.
6	Push the Mode button to leave the dialog box.

NOTE

Using an Eye-Fi® memory card will automatically create and populate a DCIM folder and let you upload the infrared images and visual photos to Flickr, Facebook, Picasa, MobileMe, YouTube, FTP, etc.

For more information, go to <http://www.eye.fi>

16.12 Copy images to a USB memory stick

General

You can copy images from the camera to a USB memory stick.

Procedure

Follow this procedure:

1	Insert a USB memory stick into the USB connector.
2	Push the Archive button.
3	Do one of the following: <ul style="list-style-type: none">■ Move the joystick left/right to select the image you want to delete, then go to Step 6 below.■ Move the joystick upwards to display the images as thumbnails, then go to Step 4 below.
4	Select the image you want to delete by using the joystick.
5	Push the joystick to open the image.
6	Push the joystick to display a menu.
7	On the menu, do one of the following: <ul style="list-style-type: none">■ Select Copy USB drive by using the joystick.■ Select Copy folder to USB drive by using the joystick.

16.13

Creating an Adobe® PDF report**General**

You can create an Adobe® PDF report about any image on the SD Memory Card. The report includes the following:

- The infrared image, including any associated visual image.
- A list of text annotations.
- A list of measurement results.
- A list of object parameters.
- A sketch.
- An image description.

Procedure

Follow this procedure:

1	Insert a USB memory stick into the USB connector.
2	Push the Archive button.
3	Do one of the following: <ul style="list-style-type: none"> ■ Move the joystick left/right to select the image for which you want to create a report, then go to Step 6 below. ■ Move the joystick upwards to display the images as thumbnails, then go to Step 4 below.
4	Select the image for which you want to create a report.
5	Push the joystick to open the image.
6	Push the joystick to display a menu.
7	On the menu, select Create report page by using the joystick.

NOTE

To view the report on the PC, you need Adobe® Reader. This software can be downloaded for free from:

<http://get.adobe.com/reader/>

What is fusion?

Fusion is a function that lets you display part of a digital photo as an infrared image.

For example, you can set the camera to display all areas of an image that have a certain temperature in infrared, with all other areas displayed as a digital photo. You can also set the camera to display an infrared image frame on top of a digital photo. You can then move around the infrared image frame, or change the size of the image frame.




Fusion types

Depending on camera model, up to four different types of fusion are available. These are:

- **Above:** All areas in the digital photo with a temperature above the specified temperature level are displayed in infrared.
 - **Below:** All areas in the digital photo with a temperature below the specified temperature level are displayed in infrared.
 - **Interval:** All areas in the digital photo with a temperature between two specified temperature levels are displayed in infrared.
 - **Picture in Picture:** An infrared image frame is displayed on top of the digital photo.
-

Image examples

This table explains the four different types of fusion:

Fusion type	Image
Above	
Below	
Interval	
Picture in Picture	

General

Before you can activate fusion, you must set up a fusion type.

How to set up a fusion type

Follow this procedure to set up a fusion type:

1	Push the Setup button.
2	On the menu, select Fusion , using the joystick.
3	Push the joystick.
4	In the Fusion box, select one of the following: <ul style="list-style-type: none">■ Above■ Below■ Interval■ Picture in Picture
5	Push the joystick to confirm the choice.
6	Push the Setup button.

7	<p>Do one or more of the following:</p> <ul style="list-style-type: none"> ■ If you chose Above or Below, move the joystick up or down to adjust the temperature level. The temperature level is displayed as a 'flag' that slides along the temperature scale. See the figure below. <div data-bbox="381 244 516 317" data-label="Image"> </div> ■ If you chose Interval, do one or more of the following: <ul style="list-style-type: none"> ■ Push the joystick up/down to move the interval up/down. ■ Push the joystick left/right to increase/decrease the interval. ■ If you chose Picture in Picture, do one or more of the following: <ul style="list-style-type: none"> ■ Push the joystick once. This displays a blue indicator in the middle of the infrared image frame. You can now use the joystick to move the image frame. See the figure below. <div data-bbox="409 541 676 740" data-label="Image"> </div> ■ Push the joystick twice. This displays four blue indicators around the infrared image frame. You can now use the joystick to resize the image frame. See the figure below. <div data-bbox="409 831 676 1031" data-label="Image"> </div>
8	To deactivate Fusion, repeat Step 4 above and select Off .

General Before you can activate fusion, you must set up a fusion type. See the previous page for information on how to do this.

How to activate fusion To activate fusion, push the Camera button until the word Fusion is displayed on the screen.

- NOTE**
- When using fusion, you can change temperature levels, and the size and position of the infrared image frame, after you have saved the image. You can also do this in FLIR Reporter.
 - When you activate fusion, any palettes currently set to gray will be set to one of the color palettes. This step is taken to increase contrast.
 - When you activate fusion, the visual camera is set to display b/w video, instead of color video. This step is taken to increase contrast.
-

18

Recording video clips

General

You can record non-radiometric infrared or visual video clips. In this mode, the camera can be regarded as an ordinary digital video camera.

The video clips can be played back in Windows® Media Player, but it will not be possible to retrieve radiometric information from the video clips.

Procedure

Follow this procedure to record a video clip:

1	Push the Mode button.
2	Use the joystick to select Video .
3	To start the video recording, push the joystick. This will display a notification indicating that the recording has started.
4	To stop the video recording, push the joystick again. When you stop the video recording you can play back the recording in the camera, using the tools on the video recording toolbar. See section section 10.2.5 – Video recording toolbar on page 34 for more information.

NOTE

- You can only view the most recently recorded video clips in this mode. To view another video clip, go to the archive mode.
 - You can play back the video clips in, for example, Windows® Media Player. However, to do so you must also buy, download, and install the 3ivx D4 Decoder, which is an MPEG-4 toolkit that supports MPEG-4 Video, MPEG-4 Audio, and the MP4 file format. You can download the 3ivx D4 Decoder from <http://www.3ivx.com/>.
 - Other video players may also work, for example ffdshow from <http://sourceforge.net/projects/ffdshow>.
 - Codecs may also be available from <http://www.free-codecs.com/>.
 - FLIR Systems does not take any responsibility for the functionality of third-party video players and codecs.
-

19

Working with measurement tools and isotherms

19.1

Setting up measurement tools

General

To measure the temperature, you use one measurement tools or several. This section describes how you set up a spotmeter or an area.

Procedure

Follow this procedure to set up a spotmeter, or use an area:

1	Push the Measure button.
2	On the menu, select one of the following commands, using the joystick: <ul style="list-style-type: none">■ Measure spot■ Measure area.
3	Push the joystick to confirm the choice. For the area tool, you must also set if the maximum or minimum temperature should be displayed.
4	Push the Measure button to leave the menu. The temperature of the measurement tool is displayed in the top left corner of the screen.

NOTE

The area inside the center of the spotmeter must be covered by the object of interest, to display a correct temperature.

For accurate measurements, you must set the object parameters. See section 19.9 – Changing object parameters on page 96.

SEE ALSO

You can also set up measurement tools using the advanced mode, allowing more complex setups. For more information, see section 19.2 – Setting up measurement tools (advanced mode) on page 87.

19.2

Setting up measurement tools (advanced mode)**General**

You can use the advanced mode to set up measurement tools. This mode allows you to combine several tools, and to place them arbitrarily on the screen.

Procedure

Follow this procedure to set up a measurement tool using the advanced mode:

1	Push the Measure button.
2	On the menu, select Advanced .
3	Push the joystick. This will display a measurement toolbar at the bottom of the screen.
4	<p>Do one or more of the following:</p> <ul style="list-style-type: none"> ■ To create an isotherm, select the  toolbar button. This will display a menu on which you can select the type of isotherm you want to use. ■ To create a spotmeter, select the  toolbar button and push the joystick. ■ To create an area, select the  toolbar button and push the joystick.

SEE ALSO

- For more information on isotherms, see section 19.4 – Setting up isotherms on page 89.
- For more information on the measurement toolbar, see section 10.2.1 – Measurement toolbar on page 28.

19.3 *Setting up a difference calculation*

General

You can let the camera calculate the temperature difference between, for example, a spotmeter, or an area, and the reference temperature.

Procedure

Follow this procedure to set up a difference calculation:

1	Push the Measure button.
2	Set up a spotmeter or an area, according to the previous section.
3	On the menu, select Advanced .
4	Push the joystick. This will display a measurement toolbar at the bottom of the screen.
5	Using the joystick, select the difference calculation toolbar button (indicated by the capital delta symbol Δ).
6	Using the joystick, activate the difference calculation by selecting On and pushing the joystick. The camera will now calculate the difference between the spotmeter (or area) result and the reference temperature. The result of the calculation will be displayed on the screen.

19.4

Setting up isotherms

General

You can make the camera display an isotherm color when certain measurement conditions are met. The following isotherms can be set up:

- An isotherm color that is displayed when a temperature rises above a preset value.
- An isotherm color that is displayed when a temperature falls below a preset value.
- An isotherm color that is displayed when the camera detects an area where there may be a risk of humidity in a building structure.
- An isotherm color that is displayed when the camera detects what may be an insulation deficiency in a wall.

Setting up a high-temperature isotherm

Follow this procedure to set up an isotherm color that is displayed when a temperature rises above a preset value:

1	Push the Measure button.
2	On the menu, select Detect high temperature .
3	Push the joystick three times.
4	Move the joystick up/down to set the temperature at which you want the isotherm color to be displayed.
5	Push the joystick to confirm.
6	Push the Measure button to leave the main menu. The screen will now display the isotherm color when the temperature exceeds the set temperature level.

Setting up a low-temperature isotherm

Follow this procedure to set up an isotherm color that is displayed when a temperature falls below a preset value:

1	Push the Measure button.
2	On the menu, select Detect low temperature .
3	Push the joystick three times.
4	Move the joystick up/down to set the temperature at which you want the isotherm color to be displayed.
5	Push the joystick to confirm.
6	Push the Measure button to leave the main menu. The screen will now display an isotherm color when the temperature falls below the set level.

Setting up a humidity isotherm

Follow this procedure to set up an isotherm color that is displayed when the camera detects an area where there may be a risk of humidity in a building structure:

1	Push the Measure button.
2	On the menu, select Detect humidity .
3	Push the joystick twice.
4	Use the joystick to set the following parameters: <ul style="list-style-type: none"> ■ Rel. humidity limit: The critical limit of relative humidity that you want to detect in a building structure. For example, mold will grow in areas where the relative humidity is less than 100%, and you may want to find such areas. ■ Rel. hum. limit: The current relative humidity at the inspection site. ■ Atm. temp.: The current atmospheric temperature at the inspection site.
5	Push the joystick to confirm each choice.
6	Push the Measure button to leave the main menu. The screen will now display an isotherm color when the relative humidity exceeds the set level.

Setting up an insulation isotherm

Follow this procedure to set up an isotherm color that is displayed when the camera detects what may be an insulation deficiency in a wall:

1	Push the Measure button.
2	On the menu, select Detect insulation .
3	Push the joystick twice.
4	Use the joystick to set the following parameters: <ul style="list-style-type: none"> ■ Inside temp.: The temperature inside the building you are inspecting. ■ Outside temp.: The temperature outside the building you are inspecting. ■ Thermal index: The accepted energy loss through the wall. Different building codes recommend different values, but typical values are 60–80 for new buildings. Refer to your national building code for recommendations.
5	Push the joystick to confirm each choice.
6	Push the Measure button to leave the main menu. The screen will now display an isotherm color when the camera detects an area with an energy loss higher than the set value.

19.5 Screening of elevated facial temperatures

General

The screening function allows you to screen a large number of persons for facial temperatures that lie above a set reference temperature.

When an elevated temperature is detected, the camera will trigger a visible and audible alarm. You can disable the audible alarm.

NOTE

Remove any spectacles from the person whose facial temperature you are screening.

Procedure

Follow this procedure:

1	Turn on the camera, and wait at least 30 minutes before taking any measurements.
2	Set the emissivity to 0.98.
3	Push the Measure button to display a menu.
4	Move the joystick up/down to select Screen , then push the joystick.
5	Use the joystick to set the Alarm difference . This value is the difference between the reference temperature (described later) and the temperature at which the camera will trigger the alarm. A typical value is 2°C/3.6°F.
6	Use the joystick to enable/disable the audible alarm (Beep).
7	Push the Measure button and review the information about maintaining screening accuracy.
8	<p>Now aim the camera at a face having a supposedly normal temperature (portrait orientation, distance not more than that the face covers at least 75% of the image width.) Push the laser button to store a temperature sample.</p> <p>Repeat this procedure on at least 10 faces with supposedly normal temperatures. You have now set the reference temperature.</p> <p>Note: If you are sure about the reference temperature, you can push and hold down the laser button to set a fixed reference temperature at once.</p>
9	<p>You can now begin the screening. Aim the camera at the face of the person whose facial temperatures you want to screen.</p> <p>If a person's facial temperature is more than 2°C/3.6°F (or the value you have set in Step 4) above the reference temperature, an alarm will be triggered (red background for the difference value, and a 'beep', if enabled).</p>
10	Update the reference temperature on a regular basis (every 10–15 minutes) by pushing the laser button for less than 2 seconds when a face that is not triggering the alarm is screened.

NOTE

- To leave the temperature screening mode, push the **Measure** button and select another measurement function.

- If you turn off the camera when you are in temperature screening mode, and then turn on the camera, a tilde (~) will be displayed after the Area Max. value. The Area Max. temperature will not be recalculated until the tilde disappears.
-

19.6

Removing measurement tools**NOTE**

The easiest way to remove a measurement tool is to select another menu command on the measurement menu. However, if you wish to remove all measurement tools you must follow the procedures in this section.

Removing spotmeters and areas

Follow this procedure to remove a spotmeter or an area:

1	Push the Measure button.
2	On the menu, select Advanced . This will display the measurement menu.
3	Select the  toolbar button. This will display a menu listing all currently active measurement tools.
4	On the menu, select the measurement tool that you wish to remove. This will display a submenu.
5	On the submenu, select Remove and push the joystick.

Removing isotherms

Follow this procedure to remove an isotherm:

1	Push the Measure button.
2	On the menu, select Advanced . This will display the measurement menu.
3	Select the  toolbar button. This will display a menu listing all currently active isotherms.
4	On the submenu, select Off and push the joystick.

19.7

Moving measurement tools

Procedure

Follow this procedure to move a measurement tool:

1	Push the Measure button.
2	On the menu, select Advanced . This will display the measurement menu.
3	Select the  toolbar button. This will display a menu listing all currently active measurement tools.
4	On the menu, select the measurement tool that you wish to move. This will display a submenu.
5	On the submenu, select Move and push the joystick. This will make the measurement tool turn blue. You can now move the measurement tool using the joystick.

19.8

Resizing areas

Procedure

Follow this procedure to resize an area:

1	Push the Measure button.
2	On the menu, select Advanced . This will display the measurement menu.
3	Select the  toolbar button. This will display a menu listing all currently active measurement tools.
4	On the menu, select the area. This will display a submenu.
5	On the submenu, select Resize and push the joystick. This will create resizing handles for the area. You can now resize the area using the joystick.

19.9 Changing object parameters

General

For accurate measurements, you must set the object parameters. This procedure describes how to change the parameters.

Types of parameters

The camera can use these object parameters:

- **Emissivity**, which determines how much of the radiation originates from the object as opposed to being reflected by it.
- **Reflected apparent temperature**, which is used when compensating for the radiation from the surroundings reflected by the object into the camera. This property of the object is called reflectivity.
- **Object distance**, i.e. the distance between the camera and the object of interest.
- **Atmospheric temperature**, i.e. the temperature of the air between the camera and the object of interest.
- **Relative humidity**, i.e. the relative humidity of the air between the camera and the object of interest.
- **External optics temperature**, i.e., the temperature of any protective windows etc. that are set up between the camera and the object of interest. If no protective window or protective shield is used, this value is irrelevant.
- **External optics transmission**, i.e., the optical transmission of any protective windows, etc. that are set up between the camera and the object of interest.

Recommended values

If you are unsure about the values, the following are recommended:

Atmospheric temperature	+20°C (+69°F)
Emissivity	0.95
Object distance	1.0 m (3.3 ft.)
Reflected apparent temperature	+20°C (+69°F)
Relative humidity	50%

Procedure

Follow this procedure to change the object parameters globally:

1	Push the Measure button.
2	On the menu, select Parameters .
3	Push the joystick.
4	Go to the parameter that you want to change, using the joystick.
5	Push the joystick.
6	Move the joystick up/down to change the value.
7	Push the joystick to confirm.
8	Push the Measure button to leave the menu.

NOTE

- Of the five parameters above, *emissivity* and *reflected apparent temperature* are the two most important to set correctly in the camera.
- You can also change object parameters from the Measure menu.

SEE ALSO

For more information about parameters, and how to correctly set emissivity and reflected apparent temperature, see section 31 – Thermographic measurement techniques on page 210.

General

This section describes how to save additional information to an infrared image by using annotations.

The reason for using annotations is to make reporting and post-processing more efficient by providing essential information about the image, such as conditions, photos, sketches, where it was taken, and so on.

SEE

- Section 20.1 – Adding a digital photo on page 99
 - Section 20.2 – Adding a voice annotation on page 100
 - Section 20.4 – Adding an image description on page 104
 - Section 20.3 – Adding a text annotation on page 101
 - Section 20.5 – Adding a sketch on page 105
 - Section 20.6 – Adding an image marker on page 106
-

20.1 Adding a digital photo

General

When you save an infrared image you can also add a digital photo of the object of interest. This digital photo will automatically be associated with the infrared image, which will simplify post-processing and reporting in, for example, FLIR Reporter.

Procedure

Follow this procedure to take a digital photo:

1	To preview an image, push Preview/Save button. This will display the documentation toolbar.
2	On the documentation toolbar, select the  toolbar button and push the joystick.
3	Do one of the following: <ul style="list-style-type: none"> ▪ To take the digital photo, push the Preview/Save button. ▪ To go back to infrared mode, push the joystick

20.2 Adding a voice annotation

General

A voice annotation is an audio recording that is saved in an infrared image.

The voice annotation is recorded using a microphone headset connected to the camera. The headset can be connected using a cable, or using Bluetooth® wireless technology. The recording can be played back in the camera, and in image analysis and reporting software from FLIR Systems.

Procedure

Follow this procedure to add a voice annotation:

1	To preview an image, push the Preview/Save button. This will display the documentation toolbar.
2	On the documentation toolbar, select the voice annotation  toolbar button, using the joystick.
3	Push the joystick. This will display the voice annotation toolbar.
4	Record the voice annotation. Make sure the microphone headset is connected to the camera. For information about the toolbar buttons on the voice annotation toolbar, see section 10.2.4 – Voice annotation toolbar on page 33.
5	To save the voice annotation and close the voice annotation toolbar, select OK and push the joystick.
6	On the documentation toolbar, select Save and push the joystick.

20.3 Adding a text annotation

General

A text annotation can be saved in an infrared image. Using this feature, you can annotate images using a file with predefined text strings.

This feature is a very efficient way of recording information when you are inspecting a large number of similar objects. The idea behind using text annotations is to avoid filling out forms or inspection protocols manually.

Definition of label and value

The concept of *text annotation* is based on two important definitions – *label* and *value*. The following examples explain the difference between the two definitions.

Label (examples)	Value (examples)
Company	Company A Company B Company C
Building	Workshop 1 Workshop 2 Workshop 3
Section	Room 1 Room 2 Room 3
Equipment	Tool 1 Tool 1 Tool 3
Recommendation	Recommendation 1 Recommendation 2 Recommendation 3

Differences between a text annotation and an image description

Text annotations and image descriptions differ in several ways:

- A *text annotation* is a proprietary annotation format from FLIR Systems, and the information cannot be retrieved by other vendors' software. An *image description* uses a standard tag in the JPG file format and can be retrieved by other software.
- The structure of a *text annotation* relies on *information pairs* (label and value), while an *image description* does not. An image description file can have virtually any information structure.

Valid file format The valid file format for a text annotation is *.tcf. A *.tcf file is a text file with one of the following two encodings:

- ANSI encoding (supported in FLIR Reporter)
- UTF-8 encoding (not supported in FLIR Reporter). This encoding must be used for all writing systems outside the ISO 8859-1 (Latin-1) encoding, e.g. Japanese or Cyrillic.

To create a *.tcf file, write your text using a text editor (e.g. Notepad on PCs), save the file with ANSI or UTF-8 encoding. The file must have the suffix *.tcf: add or edit the filename as appropriate. You can also use the text annotation editor in FLIR Reporter to create text annotations.

Maximum number of characters The maximum number of characters in a *.tcf file is 512 characters per label and value, respectively.

Example markup structure This is an example markup structure of a *.tcf file. The words between angled brackets are labels, and the words without angled brackets are values.

```
<Company>
Company A
Company B
Company C
<Building>
Workshop 1
Workshop 2
Workshop 3
<Section>
Room 1
Room 2
Room 3
<Equipment>
Tool 1
Tool 2
Tool 3
<Recommendation>
Recommendation 1
Recommendation 2
Recommendation 3
```

Procedure

Follow this procedure to add a text annotation:

1	To preview an image, push the Preview/Save button. This will display the documentation toolbar.
2	Move the joystick left to select the text annotation  toolbar button.
3	Push the joystick to display the text annotation and image description work area. If the SD Memory Card contains a valid *.tcf file, the text annotation labels will be displayed as a list. For information about the work area, see section 10.1.4 – Text annotation and image description work area on page 25.
4	Move the joystick up/down to select a text annotation label.
5	Push the joystick. This will display a submenu listing all available text annotation values for that label.
6	On the submenu, move the joystick up/down to select the value you want to use. You can also select the keyboard button at the bottom of the submenu if you want to create a value from scratch.
7	Push the joystick. This will close the submenu, and the value you selected will now be displayed to the right of the text annotation label.
8	Repeat Steps 4 to 7 for any other text annotation labels that you want to include in your text annotation.
9	Select the OK button at the bottom of the screen and push the joystick.
10	On the documentation toolbar, select Save and push the joystick. The text annotation is now saved in the image file.

20.4 Adding an image description

General

An image description is a brief textual description that is saved in an infrared image.

The image description can be retrieved from the image file using software from other companies.

Differences between a text annotation and an image description

Image descriptions and text annotations differ in several ways:

- A *text annotation* is a proprietary annotation format from FLIR Systems, and the information cannot be retrieved by other vendors' software. An *image description* uses a standard tag in the JPG file format and can be retrieved by other software.
- The structure of a *text annotation* relies on *information pairs* (label and value), while an *image description* does not. An image description file can have virtually any information structure.

Procedure

Follow this procedure to add an image description:

1	To preview an image, push Preview/Save button. This will display the documentation toolbar.
2	Move the joystick left to select the text annotation  toolbar button.
3	Push the joystick to display the text annotation and image description work area. For information about the work area, see section 10.1.4 – Text annotation and image description work area on page 25.
4	Select the image description tab, using the joystick. This will display a keyboard on the screen.
5	Type your image description by tapping the keyboard buttons using the stylus pen.
6	Select the OK button at the bottom of the screen and push the joystick. The image description is now saved in the image file.
7	On the documentation toolbar, select Save and push the joystick.

20.5

Adding a sketch

General

A sketch is freehand drawing that you create in a sketch work area separate from the infrared image using the stylus pen. You can use the sketch feature to create a simple drawing, write down comments, dimensions, etc.

Procedure

Follow this procedure to add a sketch:

1	To preview an infrared image, push the Preview/Save button.
2	<p>On the documentation toolbar, select the  toolbar button, using the stylus pen. This will display the sketch work area.</p> <p>For information about the work area, see section 10.1.3 – Sketch work area on page 23.</p>
3	In the sketch work area, draw your sketch using the stylus pen. You can change pen color, and erase your sketch using the eraser.
4	To confirm your sketch and leave the sketch work area, select OK .
5	On the documentation toolbar, select Save and push the joystick.

20.6 Adding an image marker

General

An image marker is a line with an arrowhead, pointing to an area of interest in an infrared image.

Procedure

Follow this procedure to add an image marker:

1	To preview an infrared image, push the Preview/Save button.
2	On the documentation toolbar, select the  toolbar button, using the stylus pen.
3	On the image marker toolbar, select the  toolbar button, using the stylus pen. For information about the image marker toolbar, see section 10.2.3 – Image marker toolbar on page 32.
4	To create an image marker, draw a line in the image. The arrowhead will be created at the end of the line that you draw.
5	To save your image marker, select OK.
6	On the documentation toolbar, select Save and push the joystick.

21

Changing settings

21.1

Changing image settings

General

On this tab you can change the following image settings:

- Color palette, i.e. how the infrared image is colored. A different palette can make it easier to analyze an image.
 - Object temperature range, i.e. the temperature range used for measuring objects. You must change the temperature range according to the expected temperature of the object you are inspecting.
-

Procedure

Follow this procedure to change one or more of the aforementioned settings:

1	Push the Setup button.
2	Go to the Image tab.
3	Select the setting that you want to change.
4	Push the joystick.
5	Move the joystick up/down to select a new value.
6	Push the Setup button to confirm the change and leave the setup mode.

21.2 *Changing regional settings*

General

On this tab you can change the following image settings:

- Language
 - Date format (YY-MM-DD, MM/DD/YY, DD/MM/YY)
 - Time format (24 h or AM/PM)
 - Set date and time
 - Distance unit (meters or feet)
 - Temperature unit (°C or °F)
 - Video format (PAL or NTSC).
-

Procedure

Follow this procedure to change one or more of the aforementioned settings:

1	Push the Setup button.
2	Go to the Regional tab.
3	Select the setting that you want to change.
4	Push the joystick.
5	Move the joystick up/down to select a new value.
6	Push the Setup button to confirm the change and leave the setup mode.

21.3 Changing camera settings

General

On this tab you can change the following settings:

- Camera lamp (On/Off)
- Display intensity (High, Medium, Low)
- Click sound (On/Off)
- Alarm sound (On/Off)
- Auto power off (Off/3 min/5 min/10 min/20 min)
- USB mode (Network disk/Mass Storage Device)
- Calibrate touch pad
- Reset to default settings.

Procedure

Follow this procedure to change one or more of the aforementioned settings:

1	Push the Setup button.
2	Go to the Camera tab.
3	Select the setting that you want to change.
4	Push the joystick.
5	Move the joystick up/down to select a new value.
6	Push the Setup button to confirm the change and leave the setup mode.

22

Cleaning the camera

22.1

Camera housing, cables, and other items

Liquids

Use one of these liquids:

- Warm water
 - A weak detergent solution
-

Equipment

A soft cloth

Procedure

Follow this procedure:

1	Soak the cloth in the liquid.
2	Twist the cloth to remove excess liquid.
3	Clean the part with the cloth.

CAUTION

Do not apply solvents or similar liquids to the camera, the cables, or other items. This can cause damage.

22.2 *Infrared lens*

Liquids

Use one of these liquids:

- 96% isopropyl alcohol.
- A commercial lens cleaning liquid with more than 30% isopropyl alcohol.

Equipment

Cotton wool

Procedure

Follow this procedure:

1	Soak the cotton wool in the liquid.
2	Twist the cotton wool to remove excess liquid.
3	Clean the lens one time only and discard the cotton wool.

WARNING

Make sure that you read all applicable MSDS (Material Safety Data Sheets) and warning labels on containers before you use a liquid: the liquids can be dangerous.

CAUTION

- Be careful when you clean the infrared lens. The lens has a delicate anti-reflective coating.
- Do not clean the infrared lens too vigorously. This can damage the anti-reflective coating.

22.3 *Infrared detector*

General Even small amounts of dust on the infrared detector can result in major blemishes in the image. To remove any dust from the detector, follow the procedure below.

- NOTE**
- This section only applies to cameras where removing the lens exposes the infrared detector.
 - In some cases the dust cannot be removed by following this procedure: the infrared detector must be cleaned mechanically. This mechanical cleaning must be carried out by an authorized service partner.
-

CAUTION In Step 2 below, do not use pressurized air from pneumatic air circuits in a workshop, etc., as this air usually contains oil mist to lubricate pneumatic tools.

Procedure Follow this procedure:


1	Remove the lens from the camera.
2	Use pressurized air from a compressed air canister to blow off the dust.

23 Technical data

For technical data, refer to the datasheets on the user documentation CD-ROM that comes with the camera.

Pin configuration
for USB Mini-B
connector


10763203.a1



Pin	Configuration
1	+5 V (out)
2	USB -
3	USB +
4	N/C
5	Ground

**Pin configuration
for microphone
headset connector**


10763503.a1



Pin	Configuration
1	Mic return
2	Headphone +
3	Mic in
4	Headphone –

**Pin configuration
for video
connector**


10763503.a1



Pin	Configuration
1	Audio right
2	Ground
3	Video out
4	Audio left

**Pin configuration
for USB-A
connector**


10763303.a1



Pin	Configuration
1	+5 V (in)
2	USB -
3	USB +
4	Ground

**Pin configuration
for power
connector**

10763403.a1



Pin	Configuration
1	+12 V
2	GND
3	GND

25

Dimensions

25.1


Camera

25.1.1

Camera dimensions

Figure


10760403.a2



25.1.2 Camera dimensions, continued

Figure


10760503:a1



25.1.3 Camera dimensions, continued

Figure


10760603:a1



25.1.4 Camera dimensions, continued (with 30 mm/15° lens)

Figure


10762703.a1



25.1.5 Camera dimensions, continued (with 10 mm/45° lens)

Figure

10762603:a1




25.2

Battery

Figure

10602103.a2



NOTE


Use a clean, dry cloth to remove any water or moisture on the battery before you install it.

25.3

Stand-alone battery charger

Figure

10602203.a3

**NOTE**


Use a clean, dry cloth to remove any water or moisture on the battery before you install it.

25.4

Stand-alone battery charger with the battery

Figure

10602303.a3




NOTE

Use a clean, dry cloth to remove any water or moisture on the battery before you install it.

25.5 Infrared lens (30 mm/15°)

Figure


10762503.a1



25.6 Infrared lens (10 mm/45°)

Figure

10762403.a1



26

Application examples

26.1

Moisture & water damage

General

It is often possible to detect moisture and water damage in a house by using an infrared camera. This is partly because the damaged area has a different heat conduction property and partly because it has a different thermal capacity to store heat than the surrounding material.

NOTE


Many factors can come into play as to how moisture or water damage will appear in an infrared image.

For example, heating and cooling of these parts takes place at different rates depending on the material and the time of day. For this reason, it is important that other methods are used as well to check for moisture or water damage.

Figure

The image below shows extensive water damage on an external wall where the water has penetrated the outer facing because of an incorrectly installed window ledge.

10739503.a1



26.2 *Faulty contact in socket*

General

Depending on the type of connection a socket has, an improperly connected wire can result in local temperature increase. This temperature increase is caused by the reduced contact area between the connection point of the incoming wire and the socket, and can result in an electrical fire.

NOTE


A socket's construction may differ dramatically from one manufacturer to another. For this reason, different faults in a socket can lead to the same typical appearance in an infrared image.

Local temperature increase can also result from improper contact between wire and socket, or from difference in load.

Figure

The image below shows a connection of a cable to a socket where improper contact in the connection has resulted in local temperature increase.

10739603:a1



26.3 Oxidized socket

General

Depending on the type of socket and the environment in which the socket is installed, oxides may occur on the socket's contact surfaces. These oxides can lead to locally increased resistance when the socket is loaded, which can be seen in an infrared image as local temperature increase.

NOTE


A socket's construction may differ dramatically from one manufacturer to another. For this reason, different faults in a socket can lead to the same typical appearance in an infrared image.

Local temperature increase can also result from improper contact between a wire and socket, or from difference in load.

Figure

The image below shows a series of fuses where one fuse has a raised temperature on the contact surfaces against the fuse holder. Because of the fuse holder's blank metal, the temperature increase is not visible there, while it is visible on the fuse's ceramic material.

10739703.a1



26.4 *Insulation deficiencies*

General

Insulation deficiencies may result from insulation losing volume over the course of time and thereby not entirely filling the cavity in a frame wall.

An infrared camera allows you to see these insulation deficiencies because they either have a different heat conduction property than sections with correctly installed insulation, and/or show the area where air is penetrating the frame of the building.


NOTE

When you are inspecting a building, the temperature difference between the inside and outside should be at least 10°C (18°F). Studs, water pipes, concrete columns, and similar components may resemble an insulation deficiency in an infrared image. Minor differences may also occur naturally.

Figure

In the image below, insulation in the roof framing is lacking.. Due to the absence of insulation, air has forced its way into the roof structure, which thus takes on a different characteristic appearance in the infrared image.

10739803.a1



26.5

Draft

General

Draft can be found under baseboards, around door and window casings, and above ceiling trim. This type of draft is often possible to see with an infrared camera, as a cooler airstream cools down the surrounding surface.

NOTE

When you are investigating draft in a house, there should be sub-atmospheric pressure in the house. Close all doors, windows, and ventilation ducts, and allow the kitchen fan to run for a while before you take the infrared images.


An infrared image of draft often shows a typical stream pattern. You can see this stream pattern clearly in the picture below.

Also keep in mind that drafts can be concealed by heat from floor heating circuits.

Figure

The image below shows a ceiling hatch where faulty installation has resulted in a strong draft.

10739903.a1



27 Introduction to building thermography

27.1 *Disclaimer*

27.1.1 Copyright notice

Some sections and/or images appearing in this chapter are copyrighted to the following organizations and companies:

- FORMAS—The Swedish Research Council for Environment, Agricultural Sciences and Spatial Planning, Stockholm, Sweden
- ITC—Infrared Training Center, Boston, MA, United States
- Stockton Infrared Thermographic Services, Inc., Randleman, NC, United States
- Professional Investigative Engineers, Westminster, CO, United States
- United Kingdom Thermography Association (UKTA)

27.1.2 Training & certification

Carrying out building thermography inspections requires substantial training and experience, and may require certification from a national or regional standardization body. This section is provided only as an introduction to building thermography. The user is strongly recommended to attend relevant training courses.

For more information about infrared training, visit the following website:

<http://www.infraredtraining.com>

27.1.3 National or regional building codes

The commented building structures in this chapter may differ in construction from country to country. For more information about construction details and standards of procedure, always consult national or regional building codes.

27.2 *Important note*

All camera functions and features that are described in this section may not be supported by your particular camera configuration.

27.3 Typical field investigations

27.3.1 Guidelines

As will be noted in subsequent sections there are a number of general guidelines the user should take heed of when carrying out building thermography inspection. This section gives a summary of these guidelines.

27.3.1.1 General guidelines

- The emissivity of the majority of building materials fall between 0.85 and 0.95. Setting the emissivity value in the camera to 0.90 can be regarded as a good starting point.
- An infrared inspection alone should never be used as a decision point for further actions. Always verify suspicions and findings using other methods, such as construction drawings, moisture meters, humidity & temperature datalogging, tracer gas testing etc.
- Change level and span to thermally tune the infrared image and reveal more details. The figure below shows the difference between a thermally untuned and a thermally tuned infrared image.




Figure 27.1 LEFT: A thermally untuned infrared image; RIGHT: A thermally tuned infrared image, after having changed level and span.

27.3.1.2 Guidelines for moisture detection, mold detection & detection of water damages

- Building defects related to moisture and water damages may only show up when heat has been applied to the surface, e.g. from the sun.
- The presence of water changes the thermal conductivity and the thermal mass of the building material. It may also change the surface temperature of building material due to evaporative cooling. Thermal conductivity is a material's ability to conduct heat, while thermal mass is its ability to store heat.

- Infrared inspection does not directly detect the presence of mold, rather it may be used to find moisture where mold may develop or has already developed. Mold requires temperatures between +4°C to +38°C (+40°F to +100°F), nutrients and moisture to grow. Humidity levels above 50% can provide sufficient moisture to enable mold to grow.

10556003.a1



Figure 27.2 Microscopic view of mold spore

27.3.1.3 *Guidelines for detection of air infiltration & insulation deficiencies*

- For very accurate camera measurements, take measurements of the temperature and enter this value in the camera.
- It is recommended that there is a difference in pressure between the outside and the inside of the building structure. This facilitates the analysis of the infrared images and reveals deficiencies that would not be visible otherwise. Although a negative pressure of between 10 and 50 Pa is recommended, carrying out the inspection at a lower negative pressure may be acceptable. To do this, close all windows, doors and ventilation ducts and then run the kitchen exhaust fan for some time to reach a negative pressure of 5–10 Pa (applies to residential houses only).
- A difference in temperature between the inside and the outside of 10–15°C (18–27°F) is recommended. Inspections can be carried out at a lower temperature difference, but will make the analysis of the infrared images somewhat more difficult.
- Avoid direct sunlight on a part of a building structure—e.g. a façade—that is to be inspected from the inside. The sunlight will heat the façade which will equalize the temperature differences on the inside and mask deficiencies in the building structure. Spring seasons with low nighttime temperatures ($\pm 0^{\circ}\text{C}$ (+32°F)) and high daytime temperatures (+14°C (+57°F)) are especially risky.

27.3.2 About moisture detection

Moisture in a building structure can originate from several different sources, e.g.:

- External leaks, such as floods, leaking fire hydrants etc.
- Internal leaks, such as freshwater piping, waste water piping etc.
- Condensation, which is humidity in the air falling out as liquid water due to condensation on cold surfaces.
- Building moisture, which is any moisture in the building material prior to erecting the building structure.
- Water remaining from firefighting.

As a non-destructive detection method, using an infrared camera has a number of advantages over other methods, and a few disadvantages:

Advantage	Disadvantage
<ul style="list-style-type: none"> ■ The method is quick. ■ The method is a non-intrusive means of investigation. ■ The method does not require relocation of the occupants. ■ The method features an illustrative visual presentation of findings. ■ The method confirms failure points and moisture migration paths. 	<ul style="list-style-type: none"> ■ The method only detects surface temperature differentials and can not see through walls. ■ The method can not detect subsurface damage, i.e. mold or structural damage.

27.3.3 Moisture detection (1): Low-slope commercial roofs

27.3.3.1 General information

Low-slope commercial roofing is one of the most common roof types for industrial building, such as warehouses, industrial plants, machinery shops etc. Its major advantages over a pitched roof is the lower cost in material and building. However, due to its design where snow and ice will not fall off by itself—as is the case for the majority of pitched roofs—it must be strongly built to support the accumulated weight of both roof structure and any snow, ice and rain.

Although a basic understanding of the construction of low-slope commercial roofs is desirable when carrying out a roof thermography inspection, expert knowledge is not necessary. There is a large number of different design principles for low-slope commercial roofs—both when it comes to material and design—and it would be impossible for the infrared inspection person to know them all. If additional information about a certain roof is needed, the architect or contractor of the building can usually supply the relevant information.

Common causes of roof failure are outlined in the table below (from SPIE Thermosense Proceedings Vol. 371 (1982), p. 177).

Cause	%
Poor workmanship	47.6
Roof traffic	2.6
Poor design	16.7
Trapped moisture	7.8
Materials	8.0
Age & weathering	8.4

Potential leak locations include the following:



- Flashing
- Drains
- Penetrations
- Seams
- Blisters



27.3.3.2 Safety precautions

- Recommend a minimum of two people on a roof, preferably three or more.
- Inspect the underside of the roof for structural integrity prior to walking on it.
- Avoid stepping on blisters that are common on built up bitumen and gravel roofs.
- Have a cell phone or radio available in case of emergency.
- Inform local police and plant security prior to doing nighttime roof survey.

27.3.3.3 Commented building structures

This section includes a few typical examples of moisture problems on low-slope commercial roofs.

Structural drawing	Comment
<p>10553603;a2</p> 	<p>Inadequate sealing of roof membrane around conduit and ventilation ducts leading to local leakage around the conduit or duct.</p>
<p>10553703;a2</p> 	<p>Roof membrane inadequately sealed around roof access hatch.</p>



Structural drawing	Comment
<p>10553803,a2</p> 	<p>Drainage channels located too high and with too low an inclination. Some water will remain in the drainage channel after rain, which may lead to local leakage around the channel.</p>
<p>10553803,a2</p> 	<p>Inadequate sealing between roof membrane and roof outlet leading to local leakage around the roof outlet.</p>

27.3.3.4 *Commented infrared images*

How do you find wet insulation below the surface of the roof? When the surface itself is dry, including any gravel or ballast, a sunny day will warm the entire roof. Early in the evening, if the sky is clear, the roof will begin to cool down by radiation. Because of its higher thermal capacity the wet insulation will stay warmer longer than the dry and will be visible in the infrared camera (see photos below). The technique is particularly effective on roofs having absorbent insulation—such as wood fiber, fiberglass, and perlite—where thermal patterns correlate almost perfectly with moisture.

Infrared inspections of roofs with nonabsorbent insulations, common in many single-slope systems, are more difficult to diagnose because patterns are more diffuse.

This section includes a few typical infrared images of moisture problems on low-slope commercial roofs:

Infrared image	Comment
<p>10554003.a1</p> 	<p>Moisture detection on a roof, recorded during the evening.</p> <p>Since the building material affected by moisture has a higher thermal mass, its temperature decreases slower than surrounding areas.</p>
<p>10554103.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>Water-damaged roofing components and insulation identified from infrared scan from the underside of the built-up roof on a structural concrete tee deck.</p> <p>Affected areas are cooler than the surrounding sound areas, due to conductive and/or thermal capacitive effect.</p>
<p>10554203.a1</p> 	<p>Daytime survey of built-up low-slope commercial roof.</p> <p>Affected areas are cooler than the surrounding dry areas, due to conductive and/or thermal capacitive effect.</p>



27.3.4 Moisture detection (2): Commercial & residential façades



27.3.4.1 General information

Thermography has proven to be invaluable in the assessment of moisture infiltration into commercial and residential façades. Being able to provide a physical illustration of the moisture migration paths is more conclusive than extrapolating moisture meter probe locations and more cost-effective than large intrusive test cuts.

27.3.4.2 Commented building structures


This section includes a few typical examples of moisture problems on commercial and residential façades.

Structural drawing	Comment
<p>10554303.a2</p> 	<p>Pelting rain penetrates the façade due to badly executed bed joints. Moisture builds up in the masonry above the window.</p>
<p>10554403.a2</p> 	<p>Pelting rain hits the window at an angle. Most of the rain runs off the window edge flashing but some finds its way into the masonry where the plaster meets the underside of the flashing.</p>

Structural drawing	Comment
<p>10554503.a2</p>  <p>This diagram illustrates rain hitting a wall at an angle. Blue arrows show water penetrating through a crack in the plaster. The water then flows along the interface between the plaster and the masonry, eventually reaching the interior of the wall. The drawing shows a cross-section of a wall with a window frame, a plaster layer, and a masonry layer.</p>	<p>Rain hits the façade at an angle and penetrates the plaster through cracks. The water then follows the inside of the plaster and leads to frost erosion.</p>
<p>10554603.a2</p>  <p>This diagram illustrates rain splashing on a wall. Blue arrows show water penetrating the plaster and masonry by absorption. The water then flows along the interface between the plaster and the masonry, eventually reaching the interior of the wall. The drawing shows a cross-section of a wall with a window frame, a plaster layer, and a masonry layer.</p>	<p>Rain splashes on the façade and penetrates the plaster and masonry by absorption, which eventually leads to frost erosion.</p>

27.3.4.3 *Commented infrared images*

This section includes a few typical infrared images of moisture problems on commercial & residential façades.

Infrared image	Comment
<p>10554703.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>Improperly terminated and sealed stone veneer to window frame and missing flashings has resulted in moisture infiltration into the wall cavity and interior living space.</p>
<p>10554803.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>Moisture migration into drywall from capillary drive and interior finish components from inadequate clearance and slope of grade from vinyl siding façade on an apartment complex.</p>

27.3.5 **Moisture detection (3): Decks & balconies**



27.3.5.1 *General information*



Although there are differences in design, materials and construction, decks—plaza decks, courtyard decks etc—suffer from the same moisture and leaking problems as low-slope commercial roofs. Improper flashing, inadequately sealed membranes, and insufficient drainage may lead to substantial damage in the building structures below.

Balconies, although smaller in size, require the same care in design, choice of material, and workmanship as any other building structure. Since balconies are usually supported on one side only, moisture leading to corrosion of struts and concrete reinforcement can cause problems and lead to hazardous situations.

27.3.5.2 Commented building structures



This section includes a few typical examples of moisture problems on decks and balconies.

Structural drawing	Comment
<p>10555203.a2</p>  <p>A cross-sectional diagram of a roof or balcony edge. A circular roof outlet is shown. Blue arrows indicate rainwater flowing from the paving stones towards the outlet. However, the membrane is not properly sealed around the outlet, and blue arrows show water leaking through the joint into the structure below.</p>	<p>Improper sealing of paving and membrane to roof outlet, leading to leakage during rain.</p>
<p>10555103.a2</p>  <p>A cross-sectional diagram of a deck-to-wall connection. Blue arrows show rainwater flowing down the side of the deck. At the junction with the wall, there is no flashing or proper waterproofing. Blue arrows indicate water penetrating through the joint into the concrete and insulation layers.</p>	<p>No flashing at deck-to-wall connection, leading to rain penetrating the concrete and insulation.</p>

Structural drawing	Comment
<p>10555003.a2</p> 	<p>Water has penetrated the concrete due to inadequately sized drop apron and has led to concrete disintegration and corrosion of reinforcement.</p> <p>SECURITY RISK!</p>
<p>10554903.a2</p> 	<p>Water has penetrated the plaster and underlying masonry at the point where the handrail is fastened to the wall.</p> <p>SECURITY RISK!</p>

27.3.5.3 *Commented infrared images*

This section includes a few typical infrared images of moisture problems on decks and balconies.

Infrared image	Comment
<p>10555303.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>Improper flashing at balcony-to-wall connections and missing perimeter drainage system resulted in moisture intrusion into the wood framing support structure of the exterior walkway balcony of a loft complex.</p>
<p>10555403.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>A missing composite drainage plane or medium on a below-grade parking garage plaza deck structure resulted in standing water between the structural concrete deck and the plaza wearing surface.</p>

27.3.6 Moisture detection (4): Plumbing breaks & leaks



27.3.6.1 *General information*



Water from plumbing leaks can often lead to severe damage on a building structure. Small leaks may be difficult to detect, but can—over the years—penetrate structural walls and foundations to a degree where the building structure is beyond repair.

Using building thermography at an early stage when plumbing breaks and leaks are suspected can lead to substantial savings on material and labor.

27.3.6.2 Commented infrared images

This section includes a few typical infrared images of plumbing breaks & leaks.

Infrared image	Comment
<p>1055503.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>Moisture migration tracking along steel joist channels inside ceiling of a single family home where a plumbing line had ruptured.</p>
<p>1055503.a1</p>  <p>Courtesy Professional Investigative Engineers</p>	<p>Water from plumbing leak was found to have migrated farther than originally anticipated by the contractor during remediation techniques of cutting back carpet and installing dehumidifiers.</p>

Infrared image	Comment
<p>10555703.a1</p> 	<p>The infrared image of this vinyl-sided 3-floor apartment house clearly shows the path of a serious leak from a washing machine on the third floor, which is completely hidden within the wall.</p>
<p>10555803.a1</p> 	<p>Water leak due to improper sealing between floor drain and tiles.</p>

27.3.7 Air infiltration

27.3.7.1 General information


Due to the wind pressure on a building, temperature differences between the inside and the outside of the building, and the fact that most buildings use exhaust air terminal devices to extract used air from the building, a negative pressure of 2–5 Pa can be expected. When this negative pressure leads to cold air entering the building structure due to deficiencies in building insulation and/or building sealing, we have what is called *air infiltration*. Air infiltration can be expected at joints and seams in the building structure.



Due to the fact that air infiltration creates an air flow of cool air into e.g. a room, it can lead to substantial deterioration of the indoor climate. Air flows as small as 0.15 m/s (0.49 ft./s) are usually noticed by inhabitants, although these air flows may be difficult to detect using ordinary measurement devices.

On an infrared image air infiltration can be identified by its typical ray pattern, which emanates from the point of exit in the building structure—e.g. from behind a skirting strip. Furthermore, areas of air infiltration typically have a lower detected temperature than areas where there is only an insulation deficiency. This is due to the chill factor of the air flow.

27.3.7.2 Commented building structures




This section includes a few typical examples of details of building structures where air infiltration may occur.

Structural drawing	Comment
 <p>10552503.a2</p>	<p>Insulation deficiencies at the eaves of a brickwall house due to improperly installed fiberglass insulation batts.</p> <p>The air infiltration enters the room from behind the cornice.</p>

Structural drawing	Comment
<p data-bbox="112 164 173 175">10552303.a2</p> 	<p data-bbox="568 164 1010 220">Insulation deficiencies in an intermediate flow due to improperly installed fiberglass insulation batts.</p> <p data-bbox="568 228 1010 284">The air infiltration enters the room from behind the cornice.</p>
<p data-bbox="112 643 173 654">10552603.a2</p> 	<p data-bbox="568 643 1010 699">Air infiltration in a concrete floor-over-crawl-space due to cracks in the brick wall façade.</p> <p data-bbox="568 707 1010 762">The air infiltration enters the room beneath the skirting strip.</p>

27.3.7.3 *Commented infrared images*

This section includes a few typical infrared images of details of building structures where air infiltration has occurred.

Infrared image	Comment
<p>10552703.a1</p> 	<p>Air infiltration from behind a skirting strip. Note the typical ray pattern.</p>
<p>10552803.a1</p> 	<p>Air infiltration from behind a skirting strip. Note the typical ray pattern. The white area to the left is a radiator.</p>
<p>10552903.a1</p> 	<p>Air infiltration from behind a skirting strip. Note the typical ray pattern.</p>

27.3.8 Insulation deficiencies

27.3.8.1 General information

Insulation deficiencies do not necessarily lead to air infiltration. If fiberglass insulation batts are improperly installed air pockets will form in the building structure. Since these air pockets have a different thermal conductivity than areas where the insulation batts are properly installed, the air pockets can be detected during a building thermography inspection.


As a rule of thumb, areas with insulation deficiencies typically have higher temperatures than where there is only an air infiltration.



When carrying out building thermography inspections aimed at detecting insulation deficiencies, be aware of the following parts in a building structure, which may look like insulation deficiencies on the infrared image:

- Wooden joists, studs, rafter, beams
- Steel girders and steel beams
- Water piping inside walls, ceilings, floors
- Electrical installations inside walls, ceilings, floors—such as trunking, piping etc.
- Concrete columns inside timber framed walls
- Ventilation ducts & air ducts

27.3.8.2 Commented building structures



This section includes a few typical examples of details of building structures with insulation deficiencies:


Structural drawing	Comment
	<p>Insulation deficiencies (and air infiltration) due to improper installation of insulation batts around an electrical mains supply.</p> <p>This kind of insulation deficiency will show up as dark areas on an infrared image.</p>

Structural drawing	Comment
<p>10553103,a2</p> 	<p>Insulation deficiencies due to improper installation of insulation batts around an attic floor beam. Cool air infiltrates the structure and cools down the inside of the ceiling.</p> <p>This kind of insulation deficiency will show up as dark areas on an infrared image.</p>
<p>10553003,a2</p> 	<p>Insulation deficiencies due to improper installation of insulation batts creating an air pocket on the outside of an inclined ceiling.</p> <p>This kind of insulation deficiency will show up as dark areas on an infrared image.</p>

27.3.8.3 Commented infrared images

This section includes a few typical infrared images of insulation deficiencies.

Infrared image	Comment
<p>10553303;a1</p> 	<p>Insulation deficiencies in an intermediate floor structure. The deficiency may be due to either missing insulation batts or improperly installed insulations batts (air pockets).</p>
<p>10553403;a1</p> 	<p>Improperly installed fiberglass batts in a suspended ceiling.</p>

Infrared image	Comment
<p data-bbox="112 164 168 175">10553503.a1</p> 	<p data-bbox="571 164 1008 268">Insulation deficiencies in an intermediate floor structure. The deficiency may be due to either missing insulation batts or improperly installed insulations batts (air pockets).</p>

27.4 *Theory of building science*

27.4.1 **General information**

The demand for energy-efficient constructions has increased significantly in recent times. Developments in the field of energy, together with the demand for pleasant indoor environments, have resulted in ever-greater significance having to be attached to both the function of a building's thermal insulation and airtightness and the efficiency of its heating and ventilation systems.

Defective insulation and tightness in highly insulated and airtight structures can have a great impact on energy losses. Defects in a building's thermal insulation and airtightness do not merely entail risk of excessive heating and maintenance costs, they also create the conditions for a poor indoor climate.

A building's degree of insulation is often stated in the form of a thermal resistance or a coefficient of thermal transmittance (U value) for the various parts of the building. However, the stated thermal resistance values rarely provide a measure of the actual energy losses in a building. Air leakage from joints and connections that are not airtight and insufficiently filled with insulation often gives rise to considerable deviations from the designed and expected values.

Verification that individual materials and building elements have the promised properties is provided by means of laboratory tests. Completed buildings have to be checked and inspected in order to ensure that their intended insulation and airtightness functions are actually achieved.

In its structural engineering application, thermography is used to study temperature variations over the surfaces of a structure. Variations in the structure's thermal resistance can, under certain conditions, produce temperature variations on its surfaces. Leakage of cold (or warm) air through the structure also affects the variation in surface temperature. This means that insulation defects, thermal bridges and air leaks in a building's enclosing structural components can be located and surveyed.

Thermography itself does not directly show the structure's thermal resistance or airtightness. Where quantification of thermal resistance or airtightness is required, additional measurements have also to be taken. Thermographic analysis of buildings relies on certain prerequisites in terms of temperature and pressure conditions across the structure.

Details, shapes and contrasts in the thermal image can vary quite clearly with changes in any of these parameters. The in-depth analysis and interpretation of thermal images therefore requires thorough knowledge of such aspects as material and structural properties, the effects of climate and the latest measuring techniques. For assessing

the results of measurements, there are special requirements in terms of the skills and experience of those taking the measurements, e.g. by means of authorization by a national or regional standardization body.

27.4.2 The effects of testing and checking

It can be difficult to anticipate how well the thermal insulation and airtightness of a completed building will work. There are certain factors involved in assembling the various components and building elements that can have a considerable impact on the final result. The effects of transport, handling and storage at the site and the way the work is done cannot be calculated in advance. To ensure that the intended function is actually achieved, verification by testing and checking the completed building is required.

Modern insulation technology has reduced the theoretical heat requirement. This does mean, however, that defects that are relatively minor, but at important locations, e.g. leaking joints or incorrectly installed insulation, can have considerable consequences in terms both of heat and comfort. Verification tests, e.g. by means of thermography, have proved their value, from the point of view both of the designer and the contractor and of the developer, the property manager and the user.

- For the designer, the important thing is to find out about the function of various types of structures, so that they can be designed to take into account both working methods and functional requirements. The designer must also know how different materials and combinations of materials function in practice. Effective testing and checking, as well as experiential feedback, can be used to achieve the required development in this area.
- The contractor is keen on more testing and inspection in order to ensure that the structures keep to an expected function that corresponds to established requirements in the regulations issued by authorities and in contractual documents. The contractor wants to know at an early stage of construction about any changes that may be necessary so that systematic defects can be prevented. During construction, a check should therefore be carried out on the first apartments completed in a mass production project. Similar checking then follows as production continues. In this way systematic defects can be prevented and unnecessary costs and future problems can be avoided. This check is of benefit both to manufacturers and to users.
- For the developer and the property manager it is essential that buildings are checked with reference to heat economy, maintenance (damage from moisture or moisture infiltration) and comfort for the occupants (e.g. cooled surfaces and air movements in occupied zones).

- For the user the important thing is that the finished product fulfills the promised requirements in terms of the building's thermal insulation and airtightness. For the individual, buying a house involves a considerable financial commitment, and the purchaser therefore wants to know that any defects in the construction will not involve serious financial consequences or hygiene problems.

The effects of testing and checking a building's insulation and airtightness are partly physiological and partly financial.

The physiological experience of an indoor climatic environment is very subjective, varying according to the particular human body's heat balance and the way the individual experiences temperature. The experience of climate depends on both the indoor air temperature and that of the surrounding surfaces. The speed of movement and moisture content of indoor air are also of some significance. Physiologically, a draft produces the sensation of local cooling of the body's surface caused by

- excessive air movements in the occupied zone with normal air temperature;
- normal air movements in the occupied zone but a room temperature that is too low;
- substantial radiated heat exchange with a cold surface.

It is difficult to assess the quantitative effects of testing and checking a building's thermal insulation.

Investigations have shown that defects found in the thermal insulation and airtightness of buildings cause heat losses that are about 20–30% more than was expected. Monitoring energy consumption before and after remedial measures in relatively large complexes of small houses and in multi-dwelling blocks has also demonstrated this. The figures quoted are probably not representative of buildings in general, since the investigation data cannot be said to be significant for the entire building stock. A cautious assessment however would be that effectively testing and checking a building's thermal insulation and airtightness can result in a reduction in energy consumption of about 10%.

Research has also shown that increased energy consumption associated with defects is often caused by occupants increasing the indoor temperature by one or a few degrees above normal to compensate for the effect of annoying thermal radiation towards cooled surfaces or a sensation of disturbing air movements in a room.

27.4.3 Sources of disruption in thermography

During a thermographic survey, the risk of confusing temperature variations caused by insulation defects with those associated with the natural variation in U values along warm surfaces of a structure is considered slight under normal conditions.

The temperature changes associated with variations in the U value are generally gradual and symmetrically distributed across the surface. Variations of this kind do of course occur at the angles formed by roofs and floors and at the corners of walls.

Temperature changes associated with air leaks or insulation defects are in most cases more evident with characteristically shaped sharp contours. The temperature pattern is usually asymmetrical.

During thermography and when interpreting an infrared image, comparison infrared images can provide valuable information for assessment.

The sources of disruption in thermography that occur most commonly in practice are

- the effect of the sun on the surface being thermographed (sunlight shining in through a window);
- hot radiators with pipes;
- lights directed at, or placed near, the surface being measured;
- air flows (e.g. from air intakes) directed at the surface;
- the effect of moisture deposits on the surface.

Surfaces on which the sun is shining should not be subjected to thermography. If there is a risk of an effect by sunlight, windows should be covered up (closing Venetian blinds). However, be aware that there are building defects or problems (typically moisture problems) that only show up when heat has been applied to the surface, e.g. from the sun.

For more information about moisture detection, see section 27.3.2 – About moisture detection on page 137.

A hot radiator appears as a bright light surface in an infrared image. The surface temperature of a wall next to a radiator is raised, which may conceal any defects present.

For maximum prevention of disruptive effects from hot radiators, these may be shut off a short while before the measurement is taken. However, depending on the construction of the building (low or high mass), these may need to be shut off several hours before a thermographic survey. The room air temperature must not fall so much as to affect the surface temperature distribution on the structure's surfaces. There is little timelag with electric radiators, so they cool down relatively quickly once they have been switched off (20–30 minutes).

Lights placed against walls should be switched off when the infrared image is taken.

During a thermographic survey there should not be any disruptive air flows (e.g. open windows, open valves, fans directed at the surface being measured) that could affect the surfaces being thermographed.

Any wet surfaces, e.g. as a result of surface condensation, have a definite effect on heat transfer at the surface and the surface temperature. Where there is moisture on a surface, there is usually some evaporation which draws off heat, thus lowering the temperature of the surface by several degrees. There is risk of surface condensation at major thermal bridges and insulation defects.

Significant disruptions of the kind described here can normally be detected and eliminated before measuring.

If during thermography it is not possible to shield surfaces being measured from disruptive factors, these must be taken into account when interpreting and evaluating the results. The conditions in which the thermography was carried out should be recorded in detail when each measurement is taken.

27.4.4 Surface temperature and air leaks

Defects in building airtightness due to small gaps in the structure can be detected by measuring the surface temperature. If there is a negative pressure in the building under investigation, air flows into the space through leaks in the building. Cold air flowing in through small gaps in a wall usually lowers the temperature in adjacent areas of the wall. The result is that a cooled surface area with a characteristic shape develops on the inside surface of the wall. Thermography can be used to detect cooled surface areas. Air movements at the wall surface can be measured using an air velocity indicator. If there is a positive pressure inside the building being investigated, warm room air will leak out through gaps in the wall, resulting in locally warm surface areas around the locations of the leaks.

The amount of leakage depends partly on gaps and partly on the differential pressure across the structure.

27.4.4.1 Pressure conditions in a building

The most important causes of differential pressure across a structural element in a building are

- wind conditions around the building;
- the effects of the ventilation system;
- temperature differences between air inside and outside (thermal differential pressure).

The actual pressure conditions inside a building are usually caused by a combination of these factors.

The resultant pressure gradient across the various structural elements can be illustrated by the figure on page 163. The irregular effects of wind on a building means that in practice the pressure conditions may be relatively variable and complicated.

In a steady wind flow, Bernoulli's Law applies:

$$\frac{\rho v^2}{2} + p = \text{constant}$$

where:

ρ	Air density in kg/m ³
v	Wind velocity in m/s
p	Static pressure in Pa

and where:

$$\frac{\rho v^2}{2}$$

denotes the dynamic pressure and p the static pressure. The total of these pressures gives the total pressure.

Wind load against a surface makes the dynamic pressure become a static pressure against the surface. The magnitude of this static pressure is determined by, amongst other things, the shape of the surface and its angle to the wind direction.

The portion of the dynamic pressure that becomes a static pressure on the surface (p_{stat}) is determined by what is known as a stress concentration factor:

$$C = \frac{p_{stat}}{\frac{\rho v^2}{2}}$$

If ρ is 1.23 kg/m³ (density of air at +15°C (+59°F)), this gives the following local pressures in the wind flow:

$$p_{stat} = C \times \frac{\rho v^2}{2} = C \times \frac{v^2}{1.63} \text{ Pa}$$

10551803.a1




Figure 27.3 Distribution of resultant pressures on a building's enclosing surfaces depending on wind effects, ventilation and internal/external temperature difference. 1: Wind direction; T_u : Thermodynamic air temperature outdoors in K; T_i : Thermodynamic air temperature indoors in K.

If the whole of the dynamic pressure becomes static pressure, then $C = 1$. Examples of stress concentration factor distributions for a building with various wind directions are shown in the figure on page 164.

The wind therefore causes an internal negative pressure on the windward side and an internal positive pressure on the leeward side. The air pressure indoors depends on the wind conditions, leaks in the building and how these are distributed in relation to the wind direction. If the leaks in the building are evenly distributed, the internal pressure may vary by $\pm 0.2 p_{\text{stat}}$. If most of the leaks are on the windward side, the internal pressure increases somewhat. In the opposite case, with most of the leaks on the leeward side, the internal pressure falls.

10551903.a1




Figure 27.4 Stress concentration factor (C) distributions for various wind directions and wind velocities (v) relative to a building.

Wind conditions can vary substantially over time and between relatively closely situated locations. In thermography, such variations can have a clear effect on the measurement results.

It has been demonstrated experimentally that the differential pressure on a façade exposed to an average wind force of about 5 m/s (16.3 ft/s) will be about 10 Pa.

Mechanical ventilation results in a constant internal negative or positive pressure (depending on the direction of the ventilation). Research has showed that the negative pressure caused by mechanical extraction (kitchen fans) in small houses is usually between 5 and 10 Pa. Where there is mechanical extraction of ventilation air, e.g. in multi-dwelling blocks, the negative pressure is somewhat greater, 10–50 Pa. Where there is so-called balanced ventilation (mechanically controlled supply and extract air), this is normally adjusted to produce a slight negative pressure inside (3–5 Pa).

The differential pressure caused by temperature differences, the so-called chimney effect (airtightness differences of air at different temperatures) means that there is a negative pressure in the building's lower part and a positive pressure in the upper

part. At a certain height there is a neutral zone where the pressures on the inside and outside are the same, see the figure on page 166. This differential pressure may be described by the relationship:

$$\Delta p = g \times \rho_u \times h \left(1 - \frac{T_u}{T_i} \right) \text{ Pa}$$

Δp	Air pressure differential within the structure in Pa
g	9.81 m/s ²
ρ_u	Air density in kg/m ³
T_u	Thermodynamic air temperature outdoors in K
T_i	Thermodynamic air temperature indoors in K
h	Distance from the neutral zone in meters

If $\rho_u = 1.29 \text{ kg/m}^3$ (density of air at a temperature of 273 K and $\approx 100 \text{ kPa}$), this produces:

$$\Delta p \approx 13 \times h \left(1 - \frac{T_u}{T_i} \right)$$

With a difference of $+25^\circ\text{C}$ ($+77^\circ\text{F}$) between the ambient internal and external temperatures, the result is a differential pressure difference within the structure of about 1 Pa/m difference in height (= 3.28 Pa/ft.).

10552003,a1




Figure 27.5 Distribution of pressures on a building with two openings and where the external temperature is lower than the internal temperature. 1: Neutral zone; 2: Positive pressure; 3: Negative pressure; **h**: Distance from the neutral zone in meters.

The position of the neutral zone may vary, depending on any leaks in the building. If the leaks are evenly distributed vertically, this zone will be about halfway up the building. If more of the leaks are in the lower part of the building, the neutral zone will move downwards. If more of the leaks are in the upper part, it will move upwards. Where a chimney opens above the roof, this has a considerable effect on the position of the neutral zone, and the result may be a negative pressure throughout the building. This situation most commonly occurs in small buildings.

In a larger building, such as a tall industrial building, with leaks at doors and any windows in the lower part of the building, the neutral zone is about one-third of the way up the building.

27.4.5 Measuring conditions & measuring season

The foregoing may be summarized as follows as to the requirements with regard to measuring conditions when carrying out thermographic imaging of buildings.

Thermographic imaging is done in such a way that the disruptive influence from external climatic factors is as slight as possible. The imaging process is therefore carried out indoors, i.e. where a building is heated, the structure's warm surfaces are examined.

Outdoor thermography is only used to obtain reference measurements of larger façade surfaces. In certain cases, e.g. where the thermal insulation is very bad or where there is an internal positive pressure, outdoor measurements may be useful. Even when investigating the effects of installations located within the building's climatic envelope, there may be justification for thermographic imaging from outside the building.

The following conditions are recommended:

- The air temperature difference within the relevant part of the building must be at least +10°C (+18°F) for a number of hours before thermographic imaging and for as long as the procedure takes. For the same period, the ambient temperature difference must not vary by more than $\pm 30\%$ of the difference when the thermographic imaging starts. During the thermographic imaging, the indoor ambient temperature should not change by more than $\pm 2^\circ\text{C}$ ($\pm 3.6^\circ\text{F}$).
- For a number of hours prior before thermographic imaging and as long as it continues, no influencing sunlight may fall upon the relevant part of the building.
- Negative pressure within the structure $\approx 10\text{--}50$ Pa.
- When conducting thermographic imaging in order to locate only air leaks in the building's enclosing sections, the requirements in terms of measuring conditions may be lower. A difference of 5°C (9°F) between the inside and outside ambient temperatures ought to be sufficient for detecting such defects. To be able to detect air leaks, certain requirements must however be made with regard to the differential pressure; about 10 Pa should be sufficient.

27.4.6 Interpretation of infrared images

The main purpose of thermography is to locate faults and defects in thermal insulation in exterior walls and floor structures and to determine their nature and extent. The measuring task can also be formulated in such a way that the aim of the thermography is to confirm whether or not the wall examined has the promised insulation and airtightness characteristics. The 'promised thermal insulation characteristics' for the wall according to the design can be converted into an expected surface temperature distribution for the surface under investigation if the measuring conditions at the time when the measurements are taken are known.

In practice the method involves the following:

Laboratory or field tests are used to produce an expected temperature distribution in the form of typical or comparative infrared images for common wall structures, comprising both defect-free structures and structures with in-built defects.

Examples of typical infrared images are shown in section 27.3 – Typical field investigations on page 135.

If infrared images of structural sections taken during field measurements are intended for use as comparison infrared images, then the structure's composition, the way it was built, and the measurement conditions at the time the infrared image was taken must be known in detail and documented.

In order, during thermography, to be able to comment on the causes of deviations from the expected results, the physical, metrological and structural engineering prerequisites must be known.

The interpretation of infrared images taken during field measurements may be described in brief as follows:

A comparison infrared image for a defect-free structure is selected on the basis of the wall structure under investigation and the conditions under which the field measurement was taken. An infrared image of the building element under investigation is then compared with the selected infrared image. Any deviation that cannot be explained by the design of the structure or the measurement conditions is noted as a suspected insulation defect. The nature and extent of the defect is normally determined using comparison infrared images showing various defects.

If no suitable comparison infrared image is available, evaluation and assessment are done on the basis of experience. This requires more precise reasoning during the analysis.

When assessing an infrared image, the following should be looked at:

- Uniformity of brightness in infrared images of surface areas where there are no thermal bridges
- Regularity and occurrence of cooled surface areas, e.g. at studding and corners
- Contours and characteristic shapes in the cooled surface area
- Measured temperature differences between the structure's normal surface temperature and the selected cooled surface area
- Continuity and uniformity of the isotherm curve on the surface of the structure. In the camera software the isotherm function is called **Isotherm** or **Color alarm**, depending on camera model.

Deviations and irregularities in the appearance of the infrared image often indicate insulation defects. There may obviously be considerable variations in the appearance of infrared images of structures with insulation defects. Certain types of insulation defects have a characteristic shape on the infrared image.

Section 27.3 – Typical field investigations on page 135 shows examples of interpretations of infrared images.

When taking infrared images of the same building, the infrared images from different areas should be taken with the same settings on the infrared camera, as this makes comparison of the various surface areas easier.

27.4.7 Humidity & dew point

27.4.7.1 *Relative & absolute humidity*

Humidity can be expressed in two different ways—either as *relative humidity* or as *absolute humidity*. Relative humidity is expressed in percent of how much water a certain volume of air can hold at a certain temperature, while absolute humidity is expressed in percent water by weight of material. The latter way to express humidity is common when measuring humidity in wood and other building materials.

The higher the temperature of air, the larger the amount of water this certain volume of air can hold.

27.4.7.2 *Definition of dew point*

Dew point is the temperature at which the humidity in a certain volume of air will condense as liquid water.

27.4.8 Excerpt from Technical Note ‘Assessing thermal bridging and insulation continuity’ (UK example)

27.4.8.1 *Credits*

This Technical Note was produced by a working group including expert thermographers, and research consultants. Additional consultation with other persons and organisations results in this document being widely accepted by all sides of industries.

The contents of this Technical Note is reproduced with kind permission from, and fully copyrighted to, United Kingdom Thermography Association (UKTA).

UK Thermography Association
c/o British Institute of Nondestructive Testing
1 Spencer Parade
Northampton NN1 5AA
United Kingdom

Tel: +44 (0)1604 630124

Fax: +44 (0)1604 231489

27.4.8.2 Introduction

Over the last few years the equipment, applications, software, and understanding connected with thermography have all developed at an astonishing rate. As the technology has gradually become integrated into mainstream practises, a corresponding demand for application guides, standards and thermography training has arisen.

The UKTA is publishing this technical note in order to establish a consistent approach to quantifying the results for a 'Continuity of Thermal Insulation' examination. It is intended that specifiers should refer to this document as a guide to satisfying the requirement in the Building Regulations, therefore enabling the qualified thermographer to issue a pass or fail report.

27.4.8.3 Background information

Thermography can detect surface temperature variations as small as 0.1 K and graphic images can be produced that visibly illustrate the distribution of temperature on building surfaces.

Variations in the thermal properties of building structures, such as poorly fitted or missing sections of insulation, cause variations in surface temperature on both sides of the structure. They are therefore visible to the thermographer. However, many other factors such as local heat sources, reflections and air leakage can also cause surface temperature variations.

The professional judgement of the thermographer is usually required to differentiate between real faults and other sources of temperature variation. Increasingly, thermographers are asked to justify their assessment of building structures and, in the absence of adequate guidance, it can be difficult to set definite levels for acceptable or unacceptable variation in temperature.

The current Standard for thermal imaging of building fabric in the UK is BS EN 13187:1999 (BS EN 13187:1999, Thermal Performance of Buildings—Qualitative detection of thermal properties in building envelopes—Infrared method (ISO 6781:1983 modified). However, this leaves interpretation of the thermal image to the professional expertise of the thermographer and provides little guidance on the demarcation between acceptable and unacceptable variations. Guidance on the appearance of a range of thermal anomalies can be found in BINDT Guides to thermal imaging (Infrared Thermography Handbook; Volume 1, Principles and Practise, Norman Walker, ISBN 0903132338, Volume 2, Applications, A. N. Nowicki, ISBN 090313232X, BINDT, 2005).

27.4.8.3.1 Requirements

A thermographic survey to demonstrate continuity of insulation, areas of thermal bridging and compliance with Building Regulations should include the following:

- Thermal anomalies.
- Differentiate between real thermal anomalies, where temperature differences are caused by deficiencies in thermal insulation, and those that occur through confounding factors such as localised differences in air movement, reflection and emissivity.
- Quantify affected areas in relation to the total insulated areas.
- State whether the anomalies and the building thermal insulation as a whole are acceptable.

27.4.8.4 *Quantitative appraisal of thermal anomalies*

A thermographic survey will show differences in apparent temperature of areas within the field of view. To be useful, however, it must systematically detect all the apparent defects; assess them against a predetermined set of criteria; reliably discount those anomalies that are not real defects; evaluate those that are real defects, and report the results to the client.

27.4.8.4.1 *Selection of critical temperature parameter*

The BRE information Paper IP17/01 (Information Paper IP17/01, Assessing the Effects of Thermal Bridging at Junctions and Around Openings. Tim Ward, BRE, 2001) provides useful guidance on minimum acceptable internal surface temperatures and appropriate values of Critical Surface Temperature Factor, f_{CRsi} . The use of a surface temperature factor allows surveys under any thermal conditions to show areas that are at risk of condensation or mould growth under design conditions.

The actual surface temperature will depend greatly on the temperatures inside and outside at the time of the survey, but a ‘Surface Temperature Factor’ (f_{Rsi}) has been devised that is independent of the absolute conditions. It is a ratio of temperature drop across the building fabric to the total temperature drop between inside and outside air.

For internal surveys: $f_{Rsi} = (T_{si} - T_e)/(T_i - T_e)$

T_{si} = internal surface temperature

T_i = internal air temperature

T_e = external air temperature

A value for f_{CRsi} of 0.75 is considered appropriate across new building as the upper end usage is not a factor considered in testing for ‘Continuity of Insulation’, or ‘Thermal Bridging’. However, when considering refurbished or extended buildings, for example swimming pools, internal surveys may need to account for unusual circumstances.

27.4.8.4.2 Alternative method using only surface temperatures

There are strong arguments for basing thermographic surveys on surface temperatures alone, with no need to measure air temperature.

- Stratification inside the building makes reference to air internal temperatures very difficult. Is it mean air temperature, low level, high level or temperature at the level of the anomaly and how far from the wall should it be measured?
- Radiation effects, such as radiation to the night sky, make use of external air temperature difficult. It is not unusual for the outside surface of building fabric to be below air temperature because of radiation to the sky which may be as low as -50°C (-58°F). This can be seen with the naked eye by the fact that dew and frost often appear on building surfaces even when the air temperature does not drop below the dewpoint.
- It should be noted that the concept of U values is based on 'environmental temperatures' on each side of the structure. This is neglected by many inexperienced analysts.
- The two temperatures that are firmly related to the transfer of heat through building fabric (and any solid) are the surface temperatures on each side.
- Therefore, by referring to surface temperatures the survey is more repeatable.
- The surface temperatures used are the averages of surface temperatures on the same material in an area near the anomaly on the inside and the outside of the fabric. Together with the temperature of the anomaly, a threshold level can be set dependent on these temperatures using the critical surface temperature factor.
- These arguments do not obviate the need for the thermographer to beware of reflections of objects at unusual temperatures in the background facing the building fabric surfaces.
- The thermographer should also use a comparison between external faces facing different directions to determine whether there is residual heat from solar gain affecting the external surfaces.
- External surveys should not be conducted on a surface where $T_{\text{si}} - T_{\text{so}}$ on the face is more than 10% greater than $T_{\text{si}} - T_{\text{so}}$ on the north or nearest to north face.
- For a defect that causes a failure under the 0.75 condition of IP17/01 the critical surface factors are 0.78 on the inside surface and 0.93 on the outside surface.

The table below shows the internal and external surface temperatures at an anomaly which would lead to failure under IP17/01. It also shows the deterioration in thermal insulation that is necessary to cause this.

Example for lightweight built-up cladding with defective insulation	Good area	Failing area
Outside temperature in $^{\circ}\text{C}$	0	0
Inside surface temperature in $^{\circ}\text{C}$	19.1	15.0

Example for lightweight built-up cladding with defective insulation	Good area	Failing area
Outside surface temperature in °C	0.3	1.5
Surface factor from IP17/01	0.95	0.75
Critical external surface temperature factor, after IP17/01		0.92
Insulation thickness to give this level of performance, mm	80	5.1
Local U value W/m ² K	0.35	1.92
UKTA TN1 surface factor		0.78
UKTA TN1 surface factor outside		0.93

Notes to the table

1 Values of surface resistances taken from ADL2 2001, are:

- Inside surface 0.13 m²K/W
- Outside surface 0.04 m²K/W

These originate from BS EN ISO 6946 (BN EN ISO 6946:1997 Building components and building elements - Thermal resistance and thermal transmittance - Calculation method).

- 2 Thermal insulation used here is assumed to have a conductivity of 0.03 W/m K.
- 3 The difference in temperature between an anomaly and the good areas is 1.2 degrees on the outside and 4.1 degrees on the inside.
- 4 The UKTA TN1 surface temperature factor for internal surveys is:

$$F_{si} = (T_{sia} - T_{so}) / (T_{si} - T_{so})$$

where:

T_{sia} = internal surface temperature at anomaly

T_{so} = external surface temperature (good area)

T_{si} = internal surface temperature (good area)

5 The UKTA TN1 surface temperature factor for external surveys is:

$$F_{so} = (T_{soa} - T_{si}) / (T_{so} - T_{si})$$

where T_{soa} = external surface temperature at anomaly

27.4.8.4.3 Selecting maximum acceptable defect area

The allowable area of defect is a quality control issue. It can be argued that there should be no area on which condensation, mould growth or defective insulation will occur and any such anomalies should be included in the report. However, a commonly used value of 0.1% of the building exposed surface area is generally accepted as the maximum combined defect area allowable to comply with the Building Regulations. This represents one square metre in every thousand.

27.4.8.4.4 *Measuring surface temperature*

Measurement of surface temperature is the function of the infrared imaging system. The trained thermographer will recognise, account for and report on the variation of emissivity and reflectivity of the surfaces under consideration.

27.4.8.4.5 *Measuring area of the defects*

Measurement of defect area can be performed by pixel counting in the thermal analysis software or most spreadsheet packages provided that:

- the distance from camera to object is accurately measured probably using a laser measurement system,
- the target distance should take into account the IFOV of the imaging system,
- any angular change between the camera and the object surface from the perpendicular is accounted for.

Buildings consist of numerous construction features that are not conducive to quantitative surveys including windows, roof lights, luminaries, heat emitters, cooling equipment, service pipes and electrical conductors. However, the joints and connections between these objects and the building envelope should be considered as part of the survey.

27.4.8.5 *Conditions and equipment*

To achieve best results from a thermal insulation survey it is important to consider the environmental conditions and to use the most appropriate thermographic technique for the task.

Thermal anomalies will only present themselves to the thermographer where temperature differences exist and environmental phenomena are accounted for. As a minimum, the following conditions should be complied with:

- Temperature differences across the building fabric to be greater than 10°C (18°F).
- Internal air to ambient air temperature difference to be greater than 5°C (9°F) for the last twentyfour hours before survey.
- External air temperature to be within $\pm 3^{\circ}\text{C}$ ($\pm 5.4^{\circ}\text{F}$) for duration of survey and for the previous hour.
- External air temperature to be within $\pm 10^{\circ}\text{C}$ ($\pm 18^{\circ}\text{F}$) for the preceding twentyfour hours.

In addition, external surveys should also comply with the following:

- Necessary surfaces free from direct solar radiation and the residual effects of past solar radiation. This can be checked by comparing the surface temperatures of opposite sides of the building.
- No precipitation either just prior to or during the survey.
- Ensure all building surfaces to be inspected are dry.

- Wind speed to be less than 10 metres / second (19.5 kn.).

As well as temperature, there are other environmental conditions that should also be taken into account when planning a thermographic building survey. External inspections, for example, may be influenced by radiation emissions and reflections from adjacent buildings or a cold clear sky, and even more significantly the heating effect that the sun may have on surface.

Additionally, where background temperatures differ from air temperatures either internally or externally by more than 5 K, then background temperatures should be measured on all effected surfaces to allow surface temperature to be measured with sufficient accuracy.

27.4.8.6 *Survey and analysis*

The following provides some operational guidance to the thermographic operator.

The survey must collect sufficient thermographic information to demonstrate that all surfaces have been inspected in order that all thermal anomalies are reported and evaluated.

Initially, environmental data must be collected, as with any thermographic survey including:

- Internal temperature in the region of the anomaly.
- External temperature in the region of the anomaly.
- Emissivity of the surface.
- Background temperature.
- Distance from the surface.

By interpolation, determine the threshold temperature to be used.

- For internal surveys the threshold surface temperature (T_{sia}) is $T_{sia} = f_{si}(T_{si} - T_{so}) + T_{so}$. The thermographer will be looking for evidence of surface temperature below this threshold.
- For external surveys the threshold temperature (T_{soa}) is $T_{soa} = f_{so}(T_{so} - T_{si}) + T_{si}$. The thermographer will be looking for evidence of surface temperature above this threshold.

Images of anomalies must be captured in such a way that they are suitable for analysis:

- The image is square to any features of the wall or roof.
- The viewing angle is nearly perpendicular to the surface being imaged. Interfering sources of infrared radiation such as lights, heat emitters, electric conductors, reflective elements are minimised.

The method of analysis will depend somewhat on analysis software used, but the key stages are as follows:

Produce an image of each anomaly or cluster of anomalies.

- Use a software analysis tool to enclose the anomalous area within the image, taking care not to include construction details that are to be excluded.
- Calculate the area below the threshold temperature for internal surveys or above the threshold temperature for external surveys. This is the defect area. Some anomalies that appeared to be defects at the time of the survey may not show defect areas at this stage.
- Add the defect areas from all the images $\sum A_d$.
- Calculate the total area of exposed building fabric. This is the surface area of all the walls and roof. It is conventional to use the external surface area. For a simple shape building this is calculated from overall width, length and height.
 $A_t = (2h(L + w)) + (Lw)$
- Identify the critical defect area A_c . Provisionally this is set at one thousandth or 0.1% of the total surface area.
 $A_c = A_t/1000$
- If $\sum A_d < A_c$ the building as a whole can be considered to have 'reasonably continuous' insulation.

27.4.8.7 Reporting

Reports should certificate a pass/fail result, comply with customers requirements and as a minimum include the information required by BSEN 13187. The following data is normally required so that survey can be repeated following remedial action.

- Background to the objective and principles of the test.
- Location, orientation, date and time of survey.
- A unique identifying reference.
- Thermographer's name and qualifications.
- Type of construction.
- Weather conditions, wind speed and direction, last precipitation, sunshine, degree of cloud cover.
- Ambient temperatures inside and outside before, at the beginning of survey and the time of each image. Air temperature and radiant temperature should be recorded.
- Statement of any deviation from relevant test requirements.
- Equipment used, last calibration date, any known defects.
- Name, affiliation and qualifications of tester.
- Type, extent and position of each observed defect.
- Results of any supplementary measurements and investigations.
- Reports should be indexed and archived by thermographers.

27.4.8.7.1 Considerations and limitations

The choice between internal and external surveys will depend on:

- Access to the surface. Buildings where both the internal and the external surfaces are obscured, e.g., by false ceilings racking or materials stacked against walls may not be amenable to this type of survey.
- Location of the thermal insulation. Surveys are usually more effective from the side nearest to the thermal insulation.
- Location of heavyweight materials. Surveys are usually less effective from the side nearest to the heavyweight material.
- The purpose of the survey. If the survey aims to show risk of condensation and mould growth it should be internal.
- Location of glass, bare metal or other materials that may be highly reflective. Surveys are usually less effective on highly reflective surfaces.
- A defect will usually produce a smaller temperature difference on the outside of a wall exposed to external air movement. However, missing or defective insulation near the external surface can often be more readily identified externally.

28 Introduction to thermographic inspections of electrical installations

28.1 *Important note*

All camera functions and features that are described in this section may not be supported by your particular camera configuration.

Electrical regulations differ from country to country. For that reason, the electrical procedures described in this section may not be the standard of procedure in your particular country. Also, in many countries carrying out electrical inspections requires formal qualification. Always consult national or regional electrical regulations.

28.2 *General information*

28.2.1 **Introduction**

Today, thermography is a well-established technique for the inspection of electrical installations. This was the first and still is the largest. the largest application of thermography. The infrared camera itself has gone through an explosive development and we can say that today, the 8th generation of thermographic systems is available. It all began in 1964, more than 40 years ago. The technique is now established throughout the whole world. Industrialized countries as well as developing countries have adopted this technique.

Thermography, in conjunction with vibration analysis, has over the latest decades been the main method for fault diagnostics in the industry as a part of the preventive maintenance program. The great advantage with these methods is that it is not only possible to carry out the inspection on installations in operation; normal working condition is in fact a prerequisite for a correct measurement result, so the ongoing production process is not disturbed. Thermographic inspection of electrical installations are used in three main areas:

- Power generation
- Power transmission
- Power distribution, that is, industrial use of electrical energy.

The fact that these controls are carried out under normal operation conditions has created a natural division between these groups. The power generation companies measure during the periods of high load. These periods vary from country to country

and for the climatic zones. The measurement periods may also differ depending on the type of plant to be inspected, whether they are hydroelectric, nuclear, coal-based or oil-based plants.

In the industry the inspections are—at least in Nordic countries with clear seasonal differences—carried out during spring or autumn or before longer stops in the operation. Thus, repairs are made when the operation is stopped anyway. However, this seems to be the rule less and less, which has led to inspections of the plants under varying load and operating conditions.

28.2.2 General equipment data

The equipment to be inspected has a certain temperature behavior that should be known to the thermographer before the inspection takes place. In the case of electrical equipment, the physical principle of why faults show a different temperature pattern because of increased resistance or increased electrical current is well known.

However, it is useful to remember that, in some cases, for example solenoids, ‘overheating’ is natural and does not correspond to a developing defect. In other cases, like the connections in electrical motors, the overheating might depend on the fact that the healthy part is taking the entire load and therefore becomes overheated.

A similar example is shown in section 28.5.7 – Overheating in one part as a result of a fault in another on page 194.

Defective parts of electrical equipment can therefore both indicate overheating and be cooler than the normal ‘healthy’ components. It is necessary to be aware of what to expect by getting as much information as possible about the equipment before it is inspected.

The general rule is, however, that a hot spot is caused by a probable defect. The temperature and the load of that specific component at the moment of inspection will give an indication of how serious the fault is and can become in other conditions.

Correct assessment in each specific case demands detailed information about the thermal behavior of the components, that is, we need to know the maximum allowed temperature of the materials involved and the role the component plays in the system.

Cable insulations, for example, lose their insulation properties above a certain temperature, which increases the risk of fire.

In the case of breakers, where the temperature is too high, parts can melt and make it impossible to open the breaker, thereby destroying its functionality.

The more the IR camera operator knows about the equipment that he or she is about to inspect, the higher the quality of the inspection. But it is virtually impossible for an IR thermographer to have detailed knowledge about all the different types of equipment that can be controlled. It is therefore common practice that a person responsible for the equipment is present during the inspection.

28.2.3 Inspection

The preparation of the inspection should include the choice of the right type of report. It is often necessary to use complementary equipment such as ampere meters in order to measure the current in the circuits where defects were found. An anemometer is necessary if you want to measure the wind speed at inspection of outdoor equipment.

Automatic functions help the IR operator to visualize an IR image of the components with the right contrast to allow easy identification of a fault or a hot spot. It is almost impossible to miss a hot spot on a scanned component. A measurement function will also automatically display the hottest spot within an area in the image or the difference between the maximum temperature in the chosen area and a reference, which can be chosen by the operator, for example the ambient temperature.

10712703.a3




Figure 28.1 An infrared and a visual image of a power line isolator

When the fault is clearly identified and the IR thermographer has made sure that it is not a reflection or a naturally occurring hot spot, the collection of the data starts, which will allow the correct reporting of the fault. The emissivity, the identification of the component, and the actual working conditions, together with the measured temperature, will be used in the report. In order to make it easy to identify the component a visual photo of the defect is often taken.

28.2.4 Classification & reporting

Reporting has traditionally been the most time-consuming part of the IR survey. A one-day inspection could result in one or two days' work to report and classify the found defects. This is still the case for many thermographers, who have chosen not to use the advantages that computers and modern reporting software have brought to IR condition monitoring.

The classification of the defects gives a more detailed meaning that not only takes into account the situation at the time of inspection (which is certainly of great importance), but also the possibility to normalize the over-temperature to standard load and ambient temperature conditions.

An over-temperature of +30°C (+86°F) is certainly a significant fault. But if that over-temperature is valid for one component working at 100% load and for another at 50% load, it is obvious that the latter will reach a much higher temperature should its load increase from 50% to 100%. Such a standard can be chosen by the plant's circumstances. Very often, however, temperatures are predicted for 100% load. A standard makes it easier to compare the faults over time and thus to make a more complete classification.

28.2.5 Priority

Based on the classification of the defects, the maintenance manager gives the defects a repair priority. Very often, the information gathered during the infrared survey is put together with complementary information on the equipment collected by other means such as vibration monitoring, ultrasound or the preventive maintenance scheduled.

Even if the IR inspection is quickly becoming the most used method of collecting information about electrical components safely with the equipment under normal operating conditions, there are many other sources of information the maintenance or the production manager has to consider.

The priority of repair should therefore not be a task for the IR camera operator in the normal case. If a critical situation is detected during the inspection or during the classification of the defects, the attention of the maintenance manager should of course be drawn to it, but the responsibility for determining the urgency of the repair should be his.

28.2.6 Repair

To repair the known defects is the most important function of preventive maintenance. However, to assure production at the right time or at the right cost can also be important goals for a maintenance group. The information provided by the infrared survey can be used to improve the repair efficiency as well as to reach the other goals with a calculated risk.

To monitor the temperature of a known defect that can not be repaired immediately for instance because spare parts are not available, can often pay for the cost of inspection a thousandfold and sometimes even for the IR camera. To decide not to repair known defects to save on maintenance costs and avoid unnecessary downtime is also another way of using the information from the IR survey in a productive way.

However, the most common result of the identification and classification of the detected faults is a recommendation to repair immediately or as soon as it is practically possible. It is important that the repair crew is aware of the physical principles for the identification of defects. If a defect shows a high temperature and is in a critical situation, it is very common that the repair personnel expect to find a highly corroded component. It should also come as no surprise to the repair crew that a connection, which is usually healthy, can give the same high temperatures as a corroded one if it has come loose. These misinterpretations are quite common and risk putting in doubt the reliability of the infrared survey.

28.2.7 Control

A repaired component should be controlled as soon as possible after the repair. It is not efficient to wait for the next scheduled IR survey in order to combine a new inspection with the control of the repaired defects. The statistics on the effect of the repair show that up to a third of the repaired defects still show overheating. That is the same as saying that those defects present a potential risk of failure.

To wait until the next scheduled IR survey represents an unnecessary risk for the plant.

Besides increasing the efficiency of the maintenance cycle (measured in terms of lower risk for the plant) the immediate control of the repair work brings other advantages to the performance of the repair crew itself.

When a defect still shows overheating after the repair, the determination of the cause of overheating improves the repair procedure, helps choose the best component suppliers and detect design shortcomings on the electrical installation. The crew rapidly sees the effect of the work and can learn quickly both from successful repairs and from mistakes.

Another reason to provide the repair crew with an IR instrument is that many of the defects detected during the IR survey are of low gravity. Instead of repairing them, which consumes maintenance and production time, it can be decided to keep these defects under control. Therefore the maintenance personnel should have access to their own IR equipment.

It is common to note on the report form the type of fault observed during the repair as well as the action taken. These observations make an important source of experience that can be used to reduce stock, choose the best suppliers or to train new maintenance personnel.

28.3 Measurement technique for thermographic inspection of electrical installations

28.3.1 How to correctly set the equipment

A thermal image may show high temperature variations:




Figure 28.2 Temperature variations in a fusebox

In the images above, the fuse to the right has a maximum temperature of +61°C (+142°F), whereas the one to the left is maximum +32°C (+90°F) and the one in the middle somewhere in between. The three images are different inasmuch as the temperature scale enhances only one fuse in each image. However, it is the same image and all the information about all three fuses is there. It is only a matter of setting the temperature scale values.

28.3.2 Temperature measurement

Some cameras today can automatically find the highest temperature in the image. The image below shows how it looks to the operator.




Figure 28.3 An infrared image of a fusebox where the maximum temperature is displayed

The maximum temperature in the area is +62.2°C (+144.0°F). The spot meter shows the exact location of the hot spot. The image can easily be stored in the camera memory.

The correct temperature measurement depends, however, not only on the function of the evaluation software or the camera. It may happen that the actual fault is, for example, a connection, which is hidden from the camera in the position it happens

to be in for the moment. It might be so that you measure heat, which has been conducted over some distance, whereas the ‘real’ hot spot is hidden from you. An example is shown in the image below.

10717603.a3




Figure 28.4 A hidden hot spot inside a box

Try to choose different angles and make sure that the hot area is seen in its full size, that is, that it is not disappearing behind something that might hide the hottest spot. In this image, the hottest spot of what the camera can ‘see’, is +83°C (+181°F), where the operating temperature on the cables below the box is +60°C (+140°F). However, the real hot spot is most probably hidden inside the box, see the in yellow encircled area. This fault is reported as a +23.0°C (+41.4°F) excess temperature, but the real problem is probably essentially hotter.

Another reason for underestimating the temperature of an object is bad focusing. It is very important that the hot spot found is in focus. See the example below.

10717403.a2




Figure 28.5 LEFT: A hot spot in focus; RIGHT: A hot spot out of focus

In the left image, the lamp is in focus. Its average temperature is +64°C (+147°F). In the right image, the lamp is out of focus, which will result in only +51°C (+124°F) as the average temperature.

28.3.3 Comparative measurement

For thermographic inspections of electrical installations a special method is used, which is based on comparison of different objects, so-called *measurement with a reference*. This simply means that you compare the three phases with each other. This method needs systematic scanning of the three phases in parallel in order to assess whether a point differs from the normal temperature pattern.

A normal temperature pattern means that current carrying components have a given operation temperature shown in a certain color (or gray tone) on the display, which is usually identical for all three phases under symmetrical load. Minor differences in the color might occur in the current path, for example, at the junction of two different materials, at increasing or decreasing conductor areas or on circuit breakers where the current path is encapsulated.

The image below shows three fuses, the temperatures of which are very close to each other. The inserted isotherm actually shows less than +2°C (+3.6°F) temperature difference between the phases.

Different colors are usually the result if the phases are carrying an unsymmetrical load. This difference in colors does not represent any overheating since this does not occur locally but is spread along the whole phase.

10713203.a3




Figure 28.6 An isotherm in an infrared image of a fusebox

A 'real' hot spot, on the other hand, shows a rising temperature as you look closer to the source of the heat. See the image below, where the profile (line) shows a steadily increasing temperature up to about +93°C (+199°F) at the hot spot.

10713303.a4




Figure 28.7 A profile (line) in an infrared image and a graph displaying the increasing temperature

28.3.4 Normal operating temperature

Temperature measurement with thermography usually gives the absolute temperature of the object. In order to correctly assess whether the component is too hot, it is necessary to know its operating temperature, that is, its normal temperature if we consider the load and the temperature of its environment.

As the direct measurement will give the absolute temperature—which must be considered as well (as most components have an upper limit to their absolute temperatures)—it is necessary to calculate the expected operating temperature given the load and the ambient temperature. Consider the following definitions:

- **Operating temperature:** the absolute temperature of the component. It depends on the current load and the ambient temperature. It is always higher than the ambient temperature.
- **Excess temperature (overheating):** the temperature difference between a properly working component and a faulty one.

The excess temperature is found as the difference between the temperature of a 'normal' component and the temperature of its neighbor. It is important to compare the same points on the different phases with each other.

As an example, see the following image taken from indoor equipment:

10713403.a4



Figure 28.8 An infrared image of indoor electrical equipment (1).

The two left phases are considered as normal, whereas the right phase shows a very clear excess temperature. Actually, the operating temperature of the left phase is +68°C (+154°F), that is, quite a substantial temperature, whereas the faulty phase to the right shows a temperature of +86°C (+187°F). This means an excess temperature of +18°C (+33°F), that is, a fault that has to be attended to quickly.

For practical reasons, the (normal, expected) operating temperature of a component is taken as the temperature of the components in at least two out of three phases, provided that you consider them to be working normally.. The ‘most normal’ case is of course that all three phases have the same or at least almost the same temperature. The operating temperature of outdoor components in substations or power lines is usually only 1°C or 2°C above the air temperature (1.8°F or 3.6°F). In indoor substations, the operating temperatures vary a lot more.

This fact is clearly shown by the image below as well. Here the left phase is the one, which shows an excess temperature. The operating temperature, taken from the two ‘cold’ phases, is +66°C (+151°F). The faulty phase shows a temperature of +127°C (+261°F), which has to be attended to without delay.



Figure 28.9 An infrared image of indoor electrical equipment (2).

28.3.5 Classification of faults

Once a faulty connection is detected, corrective measures may be necessary—or may not be necessary for the time being. In order to recommend the most appropriate action the following criteria should be evaluated:

- Load during the measurement
- Even or varying load
- Position of the faulty part in the electrical installation
- Expected future load situation
- Is the excess temperature measured directly on the faulty spot or indirectly through conducted heat caused by some fault inside the apparatus?

Excess temperatures measured directly on the faulty part are usually divided into three categories relating to 100% of the maximum load.

I	< 5°C (9°F)	The start of the overheat condition. This must be carefully monitored.
II	5–30°C (9–54°F)	Developed overheating. It must be repaired as soon as possible (but think about the load situation before a decision is made).
III	>30°C (54°F)	Acute overheating. Must be repaired immediately (but think about the load situation before a decision is made).

28.4 Reporting


Nowadays, thermographic inspections of electrical installations are probably, without exception, documented and reported by the use of a report program. These programs, which differ from one manufacturer to another, are usually directly adapted to the cameras and will thus make reporting very quick and easy.

The program, which has been used for creating the report page shown below, is called FLIR Reporter. It is adapted to several types of infrared cameras from FLIR Systems.

A professional report is often divided into two sections:

- Front pages, with facts about the inspection, such as:
 - Who the client is, for example, customer's company name and contact person
 - Location of the inspection: site address, city, and so on
 - Date of inspection
 - Date of report
 - Name of thermographer
 - Signature of thermographer
 - Summary or table of contents
- Inspection pages containing IR images to document and analyze thermal properties or anomalies.
 - Identification of the inspected object:
 - What is the object: designation, name, number, and so on
 - Photo
 - IR image. When collecting IR images there are some details to consider:
 - Optical focus
 - Thermal adjustment of the scene or the problem (level & span)
 - Composition: proper observation distance and viewing angle.
 - Comment
 - Is there an anomaly or not?
 - Is there a reflection or not?
 - Use a measurement tool—spot, area or isotherm—to quantify the problem. Use the simplest tool possible; a profile graph is almost never needed in electrical reports.

10719603.a3

	THERMOGRAPHY INSPECTION for FLIR Systems AB	Date: 2005-10-10 Sign: _____ Contract. : 1708																												
Photograph																														
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>Place</td><td colspan="2">Building 1</td></tr> <tr><td>Localization</td><td colspan="2">Right panel, group 2</td></tr> <tr><td>Equipment</td><td colspan="2">Fuse</td></tr> <tr><td>Model / type</td><td colspan="2">BBC LHBN 250</td></tr> <tr><td>Phase / ID</td><td colspan="2">Supply for Panel 8</td></tr> <tr><td>Room temperature °C</td><td colspan="2">15</td></tr> <tr><td colspan="3" style="text-align: center;">Status</td></tr> <tr><td colspan="3" style="text-align: center;">Over heated</td></tr> </table>		Place	Building 1		Localization	Right panel, group 2		Equipment	Fuse		Model / type	BBC LHBN 250		Phase / ID	Supply for Panel 8		Room temperature °C	15		Status			Over heated						
Place	Building 1																													
Localization	Right panel, group 2																													
Equipment	Fuse																													
Model / type	BBC LHBN 250																													
Phase / ID	Supply for Panel 8																													
Room temperature °C	15																													
Status																														
Over heated																														
Thermogram																														
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>Temp. Spot 1</td><td colspan="2">34 °C</td></tr> <tr><td>Temp. Spot 2</td><td colspan="2">17 °C</td></tr> <tr><td colspan="3" style="text-align: center;">TEMPERATURE DIFF</td></tr> <tr><td colspan="3" style="text-align: center;">17 °C</td></tr> <tr><td>Phase</td><td>L1</td><td>L2</td><td>L3</td></tr> <tr><td>Load (A)</td><td>45</td><td>47</td><td>47</td></tr> <tr><td>Rated load</td><td colspan="3">250</td></tr> <tr><td>Fault class</td><td colspan="3" style="text-align: center;">2</td></tr> </table>		Temp. Spot 1	34 °C		Temp. Spot 2	17 °C		TEMPERATURE DIFF			17 °C			Phase	L1	L2	L3	Load (A)	45	47	47	Rated load	250			Fault class	2		
Temp. Spot 1	34 °C																													
Temp. Spot 2	17 °C																													
TEMPERATURE DIFF																														
17 °C																														
Phase	L1	L2	L3																											
Load (A)	45	47	47																											
Rated load	250																													
Fault class	2																													
Comment																														
Disconnect cable, clean contact surfaces. Check for connectivity between cable shoe and lead. Replace any defective component. Assemble according to directions with correct torque. Note that load is only 18%. Calculated temperature rise at 50% load would be approximately 104°C. [$T_{50} = (T_1 - T_2) * (125/45)^{1.6} + T_2$]																														
Corrected																														
Measure taken: _____		Date: _____																												
Sign: _____		Sign.: _____																												

Side 1

Figure 28.10 A report example

28.5 Different types of hot spots in electrical installations

28.5.1 Reflections

The thermographic camera sees any radiation that enters the lens, not only originating from the object that you are looking at, but also radiation that comes from other sources and has been reflected by the target. Most of the time, electrical components are like mirrors to the infrared radiation, even if it is not obvious to the eye. Bare metal parts are particularly shiny, whereas painted, plastic or rubber insulated parts are mostly not. In the image below, you can clearly see a reflection from the thermographer. This is of course not a hot spot on the object. A good way to find out if what you see is a reflection or not, is for you to move. Look at the target from a different angle and watch the ‘hot spot.’ If it moves when you do, it is a reflection.

Measuring temperature of mirror like details is not possible. The object in the images below has painted areas which are well suited for temperature measurement. The material is copper, which is a very good heat conductor. This means that temperature variation over the surface is small.

10717503.a2




Figure 28.11 Reflections in an object

28.5.2 Solar heating

The surface of a component with a high emissivity, for example, a breaker, can on a hot summer day be heated up to quite considerable temperatures by irradiation from the sun. The image shows a circuit breaker, which has been heated by the sun.

10713903.a3




Figure 28.12 An infrared image of a circuit breaker

28.5.3 Inductive heating

10713903.a3




Figure 28.13 An infrared image of hot stabilizing weights

Eddy currents can cause a hot spot in the current path. In cases of very high currents and close proximity of other metals, this has in some cases caused serious fires. This type of heating occurs in magnetic material around the current path, such as metallic bottom plates for bushing insulators. In the image above, there are stabilizing weights, through which a high current is running. These metal weights, which are made of a slightly magnetic material, will not conduct any current but are exposed to the alternating magnetic fields, which will eventually heat up the weight. The overheating in the image is less than $+5^{\circ}\text{C}$ ($+9^{\circ}\text{F}$). This, however, need not necessarily always be the case.

28.5.4 Load variations

3-phase systems are the norm in electric utilities. When looking for overheated places, it is easy to compare the three phases directly with each other, for example, cables, breakers, insulators. An even load per phase should result in a uniform temperature pattern for all three phases. A fault may be suspected in cases where the temperature of one phase differs considerably from the remaining two. However, you should always make sure that the load is indeed evenly distributed. Looking at fixed ampere meters or using a clip-on ampere meter (up to 600 A) will tell you.

10714003.a3




Figure 28.14 Examples of infrared images of load variations

The image to the left shows three cables next to each other. They are so far apart that they can be regarded as thermally insulated from each other. The one in the middle is colder than the others. Unless two phases are faulty and overheated, this is a typical example of a very unsymmetrical load. The temperature spreads evenly along the cables, which indicates a load-dependent temperature increase rather than a faulty connection.

The image to the right shows two bundles with very different loads. In fact, the bundle to the right carries next to no load. Those which carry a considerable current load, are about 5°C (9°F) hotter than those which do not. No fault to be reported in these examples.

28.5.5 Varying cooling conditions

10714103.a3




Figure 28.15 An infrared image of bundled cables

When, for example, a number of cables are bundled together it can happen that the resulting poor cooling of the cables in the middle can lead to them reaching very high temperatures. See the image above.

The cables to the right in the image do not show any overheating close to the bolts. In the vertical part of the bundle, however, the cables are held together very tightly, the cooling of the cables is poor, the convection can not take the heat away, and the cables are notably hotter, actually about 5°C (9°F) above the temperature of the better cooled part of the cables.

28.5.6 Resistance variations

Overheating can have many origins. Some common reasons are described below.

Low contact pressure can occur when mounting a joint, or through wear of the material, for example, decreasing spring tension, worn threads in nuts and bolts, even too much force applied at mounting. With increasing loads and temperatures, the yield point of the material is exceeded and the tension weakens.

The image to the left below shows a bad contact due to a loose bolt. Since the bad contact is of very limited dimensions, it causes overheating only in a very small spot from which the heat is spread evenly along the connecting cable. Note the lower emissivity of the screw itself, which makes it look slightly colder than the insulated—and thereby it has a high emissivity—cable insulation.

The image to the right shows another overheating situation, this time again due to a loose connection. It is an outdoor connection, hence it is exposed to the cooling effect of the wind and it is likely that the overheating would have shown a higher temperature, if mounted indoors.

10714203.a3




Figure 28.16 LEFT: An infrared image showing bad contact due to a loose bolt; RIGHT: A loose outdoor connection, exposed to the wind cooling effect.

28.5.7 Overheating in one part as a result of a fault in another

Sometimes, overheating can appear in a component although that component is OK. The reason is that two conductors share the load. One of the conductors has an increased resistance, but the other is OK. Thus, the faulty component carries a lower load, whereas the fresh one has to take a higher load, which may be too high and which causes the increased temperature. See the image.

10714303.a3




Figure 28.17 Overheating in a circuit breaker

The overheating of this circuit breaker is most probably caused by bad contact in the near finger of the contactor. Thus, the far finger carries more current and gets hotter. The component in the infrared image and in the photo is not the same, however, it is similar).

28.6 *Disturbance factors at thermographic inspection of electrical installations*

During thermographic inspections of different types of electrical installations, disturbance factors such as wind, distance to object, rain or snow often influence the measurement result.

28.6.1 Wind

During outdoor inspection, the cooling effect of the wind should be taken into account. An overheating measured at a wind velocity of 5 m/s (10 knots) will be approximately twice as high at 1 m/s (2 knots). An excess temperature measured at 8 m/s (16 knots) will be 2.5 times as high at 1 m/s (2 knots). This correction factor, which is based on empirical measurements, is usually applicable up to 8 m/s (16 knots).

There are, however, cases when you have to inspect even if the wind is stronger than 8 m/s (16 knots). There are many windy places in the world, islands, mountains, and so on but it is important to know that overheated components found would have shown a considerably higher temperature at a lower wind speed. The empirical correction factor can be listed.

Wind speed (m/s)	Wind speed (knots)	Correction factor
1	2	1
2	4	1.36
3	6	1.64
4	8	1.86
5	10	2.06
6	12	2.23
7	14	2.40
8	16	2.54

The measured overheating multiplied by the correction factor gives the excess temperature with no wind, that is, at 1 m/s (2 knots).

28.6.2 Rain and snow

Rain and snow also have a cooling effect on electrical equipment. Thermographic measurement can still be conducted with satisfactory results during light snowfall with dry snow and light drizzle, respectively. The image quality will deteriorate in heavy

snow or rain and reliable measurement is no longer possible. This is mainly because a heavy snowfall as well as heavy rain is impenetrable to infrared radiation and it is rather the temperature of the snowflakes or raindrops that will be measured.

28.6.3 Distance to object

This image is taken from a helicopter 20 meters (66 ft.) away from this faulty connection. The distance was incorrectly set to 1 meter (3 ft.) and the temperature was measured to +37.9°C (+100.2°F). The measurement value after changing the distance to 20 meters (66 ft.), which was done afterwards, is shown in the image to the right, where the corrected temperature is +38.8°C (+101.8°F). The difference is not too crucial, but may take the fault into a higher class of seriousness. So the distance setting must definitely not be neglected.




Figure 28.18 LEFT: Incorrect distance setting; RIGHT: Correct distance setting

The images below show the temperature readings from a blackbody at +85°C (+185°F) at increasing distances.




Figure 28.19 Temperature readings from a blackbody at +85°C (+185°F) at increasing distances

The measured average temperatures are, from left to right, +85.3°C (+185.5°F), +85.3°C (+185.5°F), +84.8°C (+184.6°F), +84.8°C (+184.6°F), +84.8°C (+184.6°F) and +84.3°C (+183.7°F) from a blackbody at +85°C (+185°F). The thermograms are taken with a 12° lens. The distances are 1, 2, 3, 4, 5 and 10 meters (3, 7, 10, 13, 16 and 33 ft.). The correction for the distance has been meticulously set and works, because the object is big enough for correct measurement.

28.6.4 Object size

The second series of images below shows the same but with the normal 24° lens. Here, the measured average temperatures of the blackbody at +85°C (+185°F) are: +84.2°C (+183.6°F), +83.7°C (+182.7°F), +83.3°C (+181.9°F), +83.3°C (+181.9°F), +83.4°C (+181.1°F) and +78.4°C (+173.1°F).

The last value, (+78.4°C (+173.1°F)), is the maximum temperature as it was not possible to place a circle inside the now very small blackbody image. Obviously, it is not possible to measure correct values if the object is too small. Distance was properly set to 10 meters (33 ft.).



Figure 28.20 Temperature readings from a blackbody at +85°C (+185°F) at increasing distances (24° lens)

The reason for this effect is that there is a smallest object size, which gives correct temperature measurement. This smallest size is indicated to the user in all FLIR Systems cameras. The image below shows what you see in the viewfinder of camera model 695. The spot meter has an opening in its middle, more easily seen in the detail to the right. The size of the object has to be bigger than that opening or some radiation from its closest neighbors, which are much colder, will come into the measurement

as well, strongly lowering the reading. In the above case, where we have a point-shaped object, which is much hotter than the surroundings, the temperature reading will be too low.




Figure 28.21 Image from the viewfinder of a ThermaCAM 695

This effect is due to imperfections in the optics and to the size of the detector elements. It is typical for all infrared cameras and can not be avoided.

28.7 *Practical advice for the thermographer*

Working in a practical way with a camera, you will discover small things that make your job easier. Here are five of them to start with.

28.7.1 **From cold to hot**

You have been out with the camera at +5°C (+41°F). To continue your work, you now have to perform the inspection indoors. If you wear glasses, you are used to having to wipe off condensed water, or you will not be able to see anything. The same thing happens with the camera. To measure correctly, you should wait until the camera has become warm enough for the condensation to evaporate. This will also allow for the internal temperature compensation system to adjust to the changed condition.

28.7.2 **Rain showers**

If it starts raining you should not perform the inspection because the water will drastically change the surface temperature of the object that you are measuring. Nevertheless, sometimes you need to use the camera even under rain showers or splashes. Protect your camera with a simple transparent polyethylene plastic bag. Correction for the attenuation which is caused by the plastic bag can be made by adjusting the object distance until the temperature reading is the same as without the plastic cover. Some camera models have a separate **External optics transmission** entry.

28.7.3 **Emissivity**

You have to determine the emissivity for the material, which you are measuring. Mostly, you will not find the value in tables. Use optical black paint, that is, Nextel Black Velvet. Paint a small piece of the material you are working with. The emissivity of the optical paint is normally 0.94. Remember that the object has to have a temperature, which is different—usually higher—than the ambient temperature. The larger the difference the better the accuracy in the emissivity calculation. The difference should be at least 20°C (36°F). Remember that there are other paints that support very high temperatures up to +800°C (+1472°F). The emissivity may, however, be lower than that of optical black.

Sometimes you can not paint the object that you are measuring. In this case you can use a tape. A thin tape for which you have previously determined the emissivity will work in most cases and you can remove it afterwards without damaging the object of your study. Pay attention to the fact that some tapes are semi-transparent and thus are not very good for this purpose. One of the best tapes for this purpose is Scotch electrical tape for outdoor and sub-zero conditions.

28.7.4 Reflected apparent temperature

You are in a measurement situation where there are several hot sources that influence your measurement. You need to have the right value for the reflected apparent temperature to input into the camera and thus get the best possible correction. Do it in this way: set the emissivity to 1.0. Adjust the camera lens to near focus and, looking in the opposite direction away from the object, save one image. With the area or the isotherm, determine the most probable value of the average of the image and use that value for your input of reflected apparent temperature.

28.7.5 Object too far away

Are you in doubt that the camera you have is measuring correctly at the actual distance? A rule of thumb for your lens is to multiply the IFOV by 3. (IFOV is the detail of the object seen by one single element of the detector). Example: 25 degrees correspond to about 437 mrad. If your camera has a 120×120 pixel image, IFOV becomes $437/120 = 3.6$ mrad (3.6 mm/m) and your spot size ratio is about $1000/(3 \times 3.6) = 92:1$. This means that at a distance of 9.2 meters (30.2 ft.), your target has to be at least about 0.1 meter or 100 mm wide (3.9"). Try to work on the safe side by coming closer than 9 meters (30 ft.). At 7–8 meters (23–26 ft.), your measurement should be correct.

China, France, Germany, Great Britain, Hong Kong, Italy, Japan, Korea, Sweden, and the USA—together with a worldwide network of agents and distributors—support our international customer base.

FLIR Systems is at the forefront of innovation in the infrared camera industry. We anticipate market demand by constantly improving our existing cameras and developing new ones. The company has set milestones in product design and development such as the introduction of the first battery-operated portable camera for industrial inspections, and the first uncooled infrared camera, to mention just two innovations.

10722703.a2



Figure 29.2 LEFT: Thermovision® Model 661 from 1969. The camera weighed approximately 25 kg (55 lb.), the oscilloscope 20 kg (44 lb.), and the tripod 15 kg (33 lb.). The operator also needed a 220 VAC generator set, and a 10 L (2.6 US gallon) jar with liquid nitrogen. To the left of the oscilloscope the Polaroid attachment (6 kg/13 lb.) can be seen. **RIGHT:** FLIR i7 from 2009. Weight: 0.34 kg (0.75 lb.), including the battery.

FLIR Systems manufactures all vital mechanical and electronic components of the camera systems itself. From detector design and manufacturing, to lenses and system electronics, to final testing and calibration, all production steps are carried out and supervised by our own engineers. The in-depth expertise of these infrared specialists ensures the accuracy and reliability of all vital components that are assembled into your infrared camera.

29.1 *More than just an infrared camera*

At FLIR Systems we recognize that our job is to go beyond just producing the best infrared camera systems. We are committed to enabling all users of our infrared camera systems to work more productively by providing them with the most powerful

camera–software combination. Especially tailored software for predictive maintenance, R & D, and process monitoring is developed in-house. Most software is available in a wide variety of languages.

We support all our infrared cameras with a wide variety of accessories to adapt your equipment to the most demanding infrared applications.

29.2 *Sharing our knowledge*

Although our cameras are designed to be very user-friendly, there is a lot more to thermography than just knowing how to handle a camera. Therefore, FLIR Systems has founded the Infrared Training Center (ITC), a separate business unit, that provides certified training courses. Attending one of the ITC courses will give you a truly hands-on learning experience.

The staff of the ITC are also there to provide you with any application support you may need in putting infrared theory into practice.

29.3 *Supporting our customers*

FLIR Systems operates a worldwide service network to keep your camera running at all times. If you discover a problem with your camera, local service centers have all the equipment and expertise to solve it within the shortest possible time. Therefore, there is no need to send your camera to the other side of the world or to talk to someone who does not speak your language.

29.4 *A few images from our facilities*

10401303.a1




Figure 29.3 LEFT: Development of system electronics; RIGHT: Testing of an FPA detector

10401403,a1




Figure 29.4 LEFT: Diamond turning machine; **RIGHT:** Lens polishing

10401503,a1



Figure 29.5 LEFT: Testing of infrared cameras in the climatic chamber; **RIGHT:** Robot used for camera testing and calibration

Term or expression	Explanation
absorption (absorption factor)	The amount of radiation absorbed by an object relative to the received radiation. A number between 0 and 1.
atmosphere	The gases between the object being measured and the camera, normally air.
autoadjust	A function making a camera perform an internal image correction.
autopalette	The IR image is shown with an uneven spread of colors, displaying cold objects as well as hot ones at the same time.
blackbody	Totally non-reflective object. All its radiation is due to its own temperature.
blackbody radiator	An IR radiating equipment with blackbody properties used to calibrate IR cameras.
calculated atmospheric transmission	A transmission value computed from the temperature, the relative humidity of air and the distance to the object.
cavity radiator	A bottle shaped radiator with an absorbing inside, viewed through the bottleneck.
color temperature	The temperature for which the color of a blackbody matches a specific color.
conduction	The process that makes heat diffuse into a material.
continuous adjust	A function that adjusts the image. The function works all the time, continuously adjusting brightness and contrast according to the image content.
convection	Convection is a heat transfer mode where a fluid is brought into motion, either by gravity or another force, thereby transferring heat from one place to another.
dual isotherm	An isotherm with two color bands, instead of one.
emissivity (emissivity factor)	The amount of radiation coming from an object, compared to that of a blackbody. A number between 0 and 1.
emittance	Amount of energy emitted from an object per unit of time and area (W/m^2)
environment	Objects and gases that emit radiation towards the object being measured.
estimated atmospheric transmission	A transmission value, supplied by a user, replacing a calculated one

Term or expression	Explanation
external optics	Extra lenses, filters, heat shields etc. that can be put between the camera and the object being measured.
filter	A material transparent only to some of the infrared wavelengths.
FOV	Field of view: The horizontal angle that can be viewed through an IR lens.
FPA	Focal plane array: A type of IR detector.
graybody	An object that emits a fixed fraction of the amount of energy of a blackbody for each wavelength.
IFOV	Instantaneous field of view: A measure of the geometrical resolution of an IR camera.
image correction (internal or external)	A way of compensating for sensitivity differences in various parts of live images and also of stabilizing the camera.
infrared	Non-visible radiation, having a wavelength from about 2–13 μm .
IR	infrared
isotherm	A function highlighting those parts of an image that fall above, below or between one or more temperature intervals.
isothermal cavity	A bottle-shaped radiator with a uniform temperature viewed through the bottleneck.
Laser LocatIR	An electrically powered light source on the camera that emits laser radiation in a thin, concentrated beam to point at certain parts of the object in front of the camera.
laser pointer	An electrically powered light source on the camera that emits laser radiation in a thin, concentrated beam to point at certain parts of the object in front of the camera.
level	The center value of the temperature scale, usually expressed as a signal value.
manual adjust	A way to adjust the image by manually changing certain parameters.
NETD	Noise equivalent temperature difference. A measure of the image noise level of an IR camera.
noise	Undesired small disturbance in the infrared image
object parameters	A set of values describing the circumstances under which the measurement of an object was made, and the object itself (such as emissivity, reflected apparent temperature, distance etc.)
object signal	A non-calibrated value related to the amount of radiation received by the camera from the object.

Term or expression	Explanation
palette	The set of colors used to display an IR image.
pixel	Stands for <i>picture element</i> . One single spot in an image.
radiance	Amount of energy emitted from an object per unit of time, area and angle ($W/m^2/sr$)
radiant power	Amount of energy emitted from an object per unit of time (W)
radiation	The process by which electromagnetic energy, is emitted by an object or a gas.
radiator	A piece of IR radiating equipment.
range	The current overall temperature measurement limitation of an IR camera. Cameras can have several ranges. Expressed as two blackbody temperatures that limit the current calibration.
reference temperature	A temperature which the ordinary measured values can be compared with.
reflection	The amount of radiation reflected by an object relative to the received radiation. A number between 0 and 1.
relative humidity	Relative humidity represents the ratio between the current water vapour mass in the air and the maximum it may contain in saturation conditions.
saturation color	The areas that contain temperatures outside the present level/span settings are colored with the saturation colors. The saturation colors contain an 'overflow' color and an 'underflow' color. There is also a third red saturation color that marks everything saturated by the detector indicating that the range should probably be changed.
span	The interval of the temperature scale, usually expressed as a signal value.
spectral (radiant) emittance	Amount of energy emitted from an object per unit of time, area and wavelength ($W/m^2/\mu m$)
temperature difference, or difference of temperature.	A value which is the result of a subtraction between two temperature values.
temperature range	The current overall temperature measurement limitation of an IR camera. Cameras can have several ranges. Expressed as two blackbody temperatures that limit the current calibration.
temperature scale	The way in which an IR image currently is displayed. Expressed as two temperature values limiting the colors.
thermogram	infrared image

Term or expression	Explanation
transmission (or transmittance) factor	Gases and materials can be more or less transparent. Transmission is the amount of IR radiation passing through them. A number between 0 and 1.
transparent isotherm	An isotherm showing a linear spread of colors, instead of covering the highlighted parts of the image.
visual	Refers to the video mode of a IR camera, as opposed to the normal, thermographic mode. When a camera is in video mode it captures ordinary video images, while thermographic images are captured when the camera is in IR mode.

31 Thermographic measurement techniques

31.1 *Introduction*

An infrared camera measures and images the emitted infrared radiation from an object. The fact that radiation is a function of object surface temperature makes it possible for the camera to calculate and display this temperature.

However, the radiation measured by the camera does not only depend on the temperature of the object but is also a function of the emissivity. Radiation also originates from the surroundings and is reflected in the object. The radiation from the object and the reflected radiation will also be influenced by the absorption of the atmosphere.

To measure temperature accurately, it is therefore necessary to compensate for the effects of a number of different radiation sources. This is done on-line automatically by the camera. The following object parameters must, however, be supplied for the camera:

- The emissivity of the object
- The reflected apparent temperature
- The distance between the object and the camera
- The relative humidity
- Temperature of the atmosphere

31.2 *Emissivity*

The most important object parameter to set correctly is the emissivity which, in short, is a measure of how much radiation is emitted from the object, compared to that from a perfect blackbody of the same temperature.

Normally, object materials and surface treatments exhibit emissivity ranging from approximately 0.1 to 0.95. A highly polished (mirror) surface falls below 0.1, while an oxidized or painted surface has a higher emissivity. Oil-based paint, regardless of color in the visible spectrum, has an emissivity over 0.9 in the infrared. Human skin exhibits an emissivity 0.97 to 0.98.

Non-oxidized metals represent an extreme case of perfect opacity and high reflexivity, which does not vary greatly with wavelength. Consequently, the emissivity of metals is low – only increasing with temperature. For non-metals, emissivity tends to be high, and decreases with temperature.

31.2.1 Finding the emissivity of a sample

31.2.1.1 Step 1: Determining reflected apparent temperature

Use one of the following two methods to determine reflected apparent temperature:

31.2.1.1.1 Method 1: Direct method

- 1** Look for possible reflection sources, considering that the incident angle = reflection angle ($a = b$).

10588903:a1




Figure 31.1 1 = Reflection source

- 2** If the reflection source is a spot source, modify the source by obstructing it using a piece of cardboard.

10589103:a2




Figure 31.2 1 = Reflection source

3 Measure the radiation intensity (= apparent temperature) from the reflecting source using the following settings:

- Emissivity: 1.0
- D_{obj} : 0

You can measure the radiation intensity using one of the following two methods:

10589003:a2




Figure 31.3 1 = Reflection source

Note: Using a thermocouple to measure reflected apparent temperature is not recommended for two important reasons:

- A thermocouple does not measure radiation intensity
- A thermocouple requires a very good thermal contact to the surface, usually by gluing and covering the sensor by a thermal isolator.

31.2.1.1.2 Method 2: Reflector method

1	Crumble up a large piece of aluminum foil.
2	Uncrumble the aluminum foil and attach it to a piece of cardboard of the same size.
3	Put the piece of cardboard in front of the object you want to measure. Make sure that the side with aluminum foil points to the camera.
4	Set the emissivity to 1.0.

- 5 Measure the apparent temperature of the aluminum foil and write it down.




Figure 31.4 Measuring the apparent temperature of the aluminum foil

31.2.1.2 Step 2: Determining the emissivity

1	Select a place to put the sample.
2	Determine and set reflected apparent temperature according to the previous procedure.
3	Put a piece of electrical tape with known high emissivity on the sample.
4	Heat the sample at least 20 K above room temperature. Heating must be reasonably even.
5	Focus and auto-adjust the camera, and freeze the image.
6	Adjust Level and Span for best image brightness and contrast.
7	Set emissivity to that of the tape (usually 0.97).
8	Measure the temperature of the tape using one of the following measurement functions: <ul style="list-style-type: none"> ■ Isotherm (helps you to determine both the temperature and how evenly you have heated the sample) ■ Spot (simpler) ■ Box Avg (good for surfaces with varying emissivity).
9	Write down the temperature.
10	Move your measurement function to the sample surface.
11	Change the emissivity setting until you read the same temperature as your previous measurement.
12	Write down the emissivity.

Note:

- Avoid forced convection
- Look for a thermally stable surrounding that will not generate spot reflections
- Use high quality tape that you know is not transparent, and has a high emissivity you are certain of
- This method assumes that the temperature of your tape and the sample surface are the same. If they are not, your emissivity measurement will be wrong.

31.3 *Reflected apparent temperature*

This parameter is used to compensate for the radiation reflected in the object. If the emissivity is low and the object temperature relatively far from that of the reflected it will be important to set and compensate for the reflected apparent temperature correctly.

31.4 *Distance*

The distance is the distance between the object and the front lens of the camera. This parameter is used to compensate for the following two facts:

- That radiation from the target is absorbed by the atmosphere between the object and the camera.
- That radiation from the atmosphere itself is detected by the camera.

31.5 *Relative humidity*

The camera can also compensate for the fact that the transmittance is also dependent on the relative humidity of the atmosphere. To do this set the relative humidity to the correct value. For short distances and normal humidity the relative humidity can normally be left at a default value of 50%.

31.6 *Other parameters*

In addition, some cameras and analysis programs from FLIR Systems allow you to compensate for the following parameters:

- Atmospheric temperature – *i.e.* the temperature of the atmosphere between the camera and the target
- External optics temperature – *i.e.* the temperature of any external lenses or windows used in front of the camera
- External optics transmittance – *i.e.* the transmission of any external lenses or windows used in front of the camera

32 History of infrared technology

Before the year 1800, the existence of the infrared portion of the electromagnetic spectrum wasn't even suspected. The original significance of the infrared spectrum, or simply 'the infrared' as it is often called, as a form of heat radiation is perhaps less obvious today than it was at the time of its discovery by Herschel in 1800.

10398703.a1



Figure 32.1 Sir William Herschel (1738–1822)

The discovery was made accidentally during the search for a new optical material. Sir William Herschel – Royal Astronomer to King George III of England, and already famous for his discovery of the planet Uranus – was searching for an optical filter material to reduce the brightness of the sun's image in telescopes during solar observations. While testing different samples of colored glass which gave similar reductions in brightness he was intrigued to find that some of the samples passed very little of the sun's heat, while others passed so much heat that he risked eye damage after only a few seconds' observation.

Herschel was soon convinced of the necessity of setting up a systematic experiment, with the objective of finding a single material that would give the desired reduction in brightness as well as the maximum reduction in heat. He began the experiment by actually repeating Newton's prism experiment, but looking for the heating effect rather than the visual distribution of intensity in the spectrum. He first blackened the bulb of a sensitive mercury-in-glass thermometer with ink, and with this as his radiation detector he proceeded to test the heating effect of the various colors of the spectrum formed on the top of a table by passing sunlight through a glass prism. Other thermometers, placed outside the sun's rays, served as controls.

As the blackened thermometer was moved slowly along the colors of the spectrum, the temperature readings showed a steady increase from the violet end to the red end. This was not entirely unexpected, since the Italian researcher, Landriani, in a similar experiment in 1777 had observed much the same effect. It was Herschel,

however, who was the first to recognize that there must be a point where the heating effect reaches a maximum, and that measurements confined to the visible portion of the spectrum failed to locate this point.

10398903.a1



Figure 32.2 Marsilio Landriani (1746–1815)

Moving the thermometer into the dark region beyond the red end of the spectrum, Herschel confirmed that the heating continued to increase. The maximum point, when he found it, lay well beyond the red end – in what is known today as the ‘infrared wavelengths’.

When Herschel revealed his discovery, he referred to this new portion of the electromagnetic spectrum as the ‘thermometrical spectrum’. The radiation itself he sometimes referred to as ‘dark heat’, or simply ‘the invisible rays’. Ironically, and contrary to popular opinion, it wasn’t Herschel who originated the term ‘infrared’. The word only began to appear in print around 75 years later, and it is still unclear who should receive credit as the originator.

Herschel’s use of glass in the prism of his original experiment led to some early controversies with his contemporaries about the actual existence of the infrared wavelengths. Different investigators, in attempting to confirm his work, used various types of glass indiscriminately, having different transparencies in the infrared. Through his later experiments, Herschel was aware of the limited transparency of glass to the newly-discovered thermal radiation, and he was forced to conclude that optics for the infrared would probably be doomed to the use of reflective elements exclusively (i.e. plane and curved mirrors). Fortunately, this proved to be true only until 1830, when the Italian investigator, Melloni, made his great discovery that naturally occurring rock salt (NaCl) – which was available in large enough natural crystals to be made into lenses and prisms – is remarkably transparent to the infrared. The result was that rock salt became the principal infrared optical material, and remained so for the next hundred years, until the art of synthetic crystal growing was mastered in the 1930’s.

10399103.a1



Figure 32.3 Macedonio Melloni (1798–1854)

Thermometers, as radiation detectors, remained unchallenged until 1829, the year Nobili invented the thermocouple. (Herschel's own thermometer could be read to $0.2\text{ }^{\circ}\text{C}$ ($0.036\text{ }^{\circ}\text{F}$), and later models were able to be read to $0.05\text{ }^{\circ}\text{C}$ ($0.09\text{ }^{\circ}\text{F}$)). Then a breakthrough occurred; Melloni connected a number of thermocouples in series to form the first thermopile. The new device was at least 40 times as sensitive as the best thermometer of the day for detecting heat radiation – capable of detecting the heat from a person standing three meters away.

The first so-called 'heat-picture' became possible in 1840, the result of work by Sir John Herschel, son of the discoverer of the infrared and a famous astronomer in his own right. Based upon the differential evaporation of a thin film of oil when exposed to a heat pattern focused upon it, the thermal image could be seen by reflected light where the interference effects of the oil film made the image visible to the eye. Sir John also managed to obtain a primitive record of the thermal image on paper, which he called a 'thermograph'.

10399003.a2



Figure 32.4 Samuel P. Langley (1834–1906)

The improvement of infrared-detector sensitivity progressed slowly. Another major breakthrough, made by Langley in 1880, was the invention of the bolometer. This consisted of a thin blackened strip of platinum connected in one arm of a Wheatstone bridge circuit upon which the infrared radiation was focused and to which a sensitive galvanometer responded. This instrument is said to have been able to detect the heat from a cow at a distance of 400 meters.

An English scientist, Sir James Dewar, first introduced the use of liquefied gases as cooling agents (such as liquid nitrogen with a temperature of $-196\text{ }^{\circ}\text{C}$ ($-320.8\text{ }^{\circ}\text{F}$)) in low temperature research. In 1892 he invented a unique vacuum insulating container in which it is possible to store liquefied gases for entire days. The common ‘thermos bottle’, used for storing hot and cold drinks, is based upon his invention.

Between the years 1900 and 1920, the inventors of the world ‘discovered’ the infrared. Many patents were issued for devices to detect personnel, artillery, aircraft, ships – and even icebergs. The first operating systems, in the modern sense, began to be developed during the 1914–18 war, when both sides had research programs devoted to the military exploitation of the infrared. These programs included experimental systems for enemy intrusion/detection, remote temperature sensing, secure communications, and ‘flying torpedo’ guidance. An infrared search system tested during this period was able to detect an approaching airplane at a distance of 1.5 km (0.94 miles), or a person more than 300 meters (984 ft.) away.

The most sensitive systems up to this time were all based upon variations of the bolometer idea, but the period between the two wars saw the development of two revolutionary new infrared detectors: the image converter and the photon detector. At first, the image converter received the greatest attention by the military, because it enabled an observer for the first time in history to literally ‘see in the dark’. However, the sensitivity of the image converter was limited to the near infrared wavelengths, and the most interesting military targets (i.e. enemy soldiers) had to be illuminated by infrared search beams. Since this involved the risk of giving away the observer’s position to a similarly-equipped enemy observer, it is understandable that military interest in the image converter eventually faded.

The tactical military disadvantages of so-called ‘active’ (i.e. search beam-equipped) thermal imaging systems provided impetus following the 1939–45 war for extensive secret military infrared-research programs into the possibilities of developing ‘passive’ (no search beam) systems around the extremely sensitive photon detector. During this period, military secrecy regulations completely prevented disclosure of the status of infrared-imaging technology. This secrecy only began to be lifted in the middle of the 1950’s, and from that time adequate thermal-imaging devices finally began to be available to civilian science and industry.

33 Theory of thermography

33.1 Introduction

The subjects of infrared radiation and the related technique of thermography are still new to many who will use an infrared camera. In this section the theory behind thermography will be given.

33.2 The electromagnetic spectrum

The electromagnetic spectrum is divided arbitrarily into a number of wavelength regions, called *bands*, distinguished by the methods used to produce and detect the radiation. There is no fundamental difference between radiation in the different bands of the electromagnetic spectrum. They are all governed by the same laws and the only differences are those due to differences in wavelength.

10067803.a1




Figure 33.1 The electromagnetic spectrum. 1: X-ray; 2: UV; 3: Visible; 4: IR; 5: Microwaves; 6: Radiowaves.

Thermography makes use of the infrared spectral band. At the short-wavelength end the boundary lies at the limit of visual perception, in the deep red. At the long-wavelength end it merges with the microwave radio wavelengths, in the millimeter range.

The infrared band is often further subdivided into four smaller bands, the boundaries of which are also arbitrarily chosen. They include: the *near infrared* (0.75–3 μm), the *middle infrared* (3–6 μm), the *far infrared* (6–15 μm) and the *extreme infrared* (15–100

μm). Although the wavelengths are given in μm (micrometers), other units are often still used to measure wavelength in this spectral region, e.g. nanometer (nm) and Ångström (Å).

The relationships between the different wavelength measurements is:

$$10\,000\ \text{Å} = 1\,000\ \text{nm} = 1\ \mu = 1\ \mu\text{m}$$

33.3 *Blackbody radiation*

A blackbody is defined as an object which absorbs all radiation that impinges on it at any wavelength. The apparent misnomer *black* relating to an object emitting radiation is explained by Kirchhoff's Law (after *Gustav Robert Kirchhoff*, 1824–1887), which states that a body capable of absorbing all radiation at any wavelength is equally capable in the emission of radiation.

10398803.a1



Figure 33.2 Gustav Robert Kirchhoff (1824–1887)

The construction of a blackbody source is, in principle, very simple. The radiation characteristics of an aperture in an isotherm cavity made of an opaque absorbing material represents almost exactly the properties of a blackbody. A practical application of the principle to the construction of a perfect absorber of radiation consists of a box that is light tight except for an aperture in one of the sides. Any radiation which then enters the hole is scattered and absorbed by repeated reflections so only an infinitesimal fraction can possibly escape. The blackness which is obtained at the aperture is nearly equal to a blackbody and almost perfect for all wavelengths.

By providing such an isothermal cavity with a suitable heater it becomes what is termed a *cavity radiator*. An isothermal cavity heated to a uniform temperature generates blackbody radiation, the characteristics of which are determined solely by the temperature of the cavity. Such cavity radiators are commonly used as sources of radiation in temperature reference standards in the laboratory for calibrating thermographic instruments, such as a FLIR Systems camera for example.

If the temperature of blackbody radiation increases to more than 525°C (977°F), the source begins to be visible so that it appears to the eye no longer black. This is the incipient red heat temperature of the radiator, which then becomes orange or yellow as the temperature increases further. In fact, the definition of the so-called *color temperature* of an object is the temperature to which a blackbody would have to be heated to have the same appearance.

Now consider three expressions that describe the radiation emitted from a blackbody.

33.3.1 Planck's law

10399203.a1



Figure 33.3 Max Planck (1858–1947)

Max Planck (1858–1947) was able to describe the spectral distribution of the radiation from a blackbody by means of the following formula:

$$W_{\lambda b} = \frac{2\pi hc^2}{\lambda^5 \left(e^{hc/\lambda kT} - 1 \right)} \times 10^{-6} [\text{Watt} / \text{m}^2, \mu\text{m}]$$

where:

$W_{\lambda b}$	Blackbody spectral radiant emittance at wavelength λ .
c	Velocity of light = 3×10^8 m/s
h	Planck's constant = 6.6×10^{-34} Joule sec.
k	Boltzmann's constant = 1.4×10^{-23} Joule/K.
T	Absolute temperature (K) of a blackbody.
λ	Wavelength (μm).

⊖ The factor 10^{-6} is used since spectral emittance in the curves is expressed in Watt/m², μm.

Planck's formula, when plotted graphically for various temperatures, produces a family of curves. Following any particular Planck curve, the spectral emittance is zero at $\lambda = 0$, then increases rapidly to a maximum at a wavelength λ_{\max} and after passing it approaches zero again at very long wavelengths. The higher the temperature, the shorter the wavelength at which maximum occurs.

10327103,a4




Figure 33.4 Blackbody spectral radiant emittance according to Planck's law, plotted for various absolute temperatures. **1:** Spectral radiant emittance (W/cm² × 10³(μm)); **2:** Wavelength (μm)

33.3.2 Wien's displacement law

By differentiating Planck's formula with respect to λ , and finding the maximum, we have:

$$\lambda_{\max} = \frac{2898}{T} [\mu m]$$

This is Wien's formula (after *Wilhelm Wien*, 1864–1928), which expresses mathematically the common observation that colors vary from red to orange or yellow as the temperature of a thermal radiator increases. The wavelength of the color is the same as the wavelength calculated for λ_{\max} . A good approximation of the value of λ_{\max} for a given blackbody temperature is obtained by applying the rule-of-thumb $3\,000/T$

μm . Thus, a very hot star such as Sirius (11 000 K), emitting bluish-white light, radiates with the peak of spectral radiant emittance occurring within the invisible ultraviolet spectrum, at wavelength $0.27 \mu\text{m}$.

10399403.a1




Figure 33.5 Wilhelm Wien (1864–1928)

The sun (approx. 6 000 K) emits yellow light, peaking at about $0.5 \mu\text{m}$ in the middle of the visible light spectrum.

At room temperature (300 K) the peak of radiant emittance lies at $9.7 \mu\text{m}$, in the far infrared, while at the temperature of liquid nitrogen (77 K) the maximum of the almost insignificant amount of radiant emittance occurs at $38 \mu\text{m}$, in the extreme infrared wavelengths.




Figure 33.6 Planckian curves plotted on semi-log scales from 100 K to 1000 K. The dotted line represents the locus of maximum radiant emittance at each temperature as described by Wien's displacement law. 1: Spectral radiant emittance ($\text{W}/\text{cm}^2 (\mu\text{m})$); 2: Wavelength (μm).

33.3.3 Stefan-Boltzmann's law

By integrating Planck's formula from $\lambda = 0$ to $\lambda = \infty$, we obtain the total radiant emittance (W_b) of a blackbody:

$$W_b = \sigma T^4 \text{ [Watt}/\text{m}^2]$$

This is the Stefan-Boltzmann formula (after *Josef Stefan*, 1835–1893, and *Ludwig Boltzmann*, 1844–1906), which states that the total emissive power of a blackbody is proportional to the fourth power of its absolute temperature. Graphically, W_b represents the area below the Planck curve for a particular temperature. It can be shown that the radiant emittance in the interval $\lambda = 0$ to λ_{max} is only 25% of the total, which represents about the amount of the sun's radiation which lies inside the visible light spectrum.

10399303.a1



Figure 33.7 Josef Stefan (1835–1893), and Ludwig Boltzmann (1844–1906)

Using the Stefan-Boltzmann formula to calculate the power radiated by the human body, at a temperature of 300 K and an external surface area of approx. 2 m², we obtain 1 kW. This power loss could not be sustained if it were not for the compensating absorption of radiation from surrounding surfaces, at room temperatures which do not vary too drastically from the temperature of the body – or, of course, the addition of clothing.

33.3.4 Non-blackbody emitters

So far, only blackbody radiators and blackbody radiation have been discussed. However, real objects almost never comply with these laws over an extended wavelength region – although they may approach the blackbody behavior in certain spectral intervals. For example, a certain type of white paint may appear perfectly *white* in the visible light spectrum, but becomes distinctly *gray* at about 2 μm, and beyond 3 μm it is almost *black*.

There are three processes which can occur that prevent a real object from acting like a blackbody: a fraction of the incident radiation α may be absorbed, a fraction ρ may be reflected, and a fraction τ may be transmitted. Since all of these factors are more or less wavelength dependent, the subscript λ is used to imply the spectral dependence of their definitions. Thus:

- The spectral absorptance α_λ = the ratio of the spectral radiant power absorbed by an object to that incident upon it.
- The spectral reflectance ρ_λ = the ratio of the spectral radiant power reflected by an object to that incident upon it.
- The spectral transmittance τ_λ = the ratio of the spectral radiant power transmitted through an object to that incident upon it.

The sum of these three factors must always add up to the whole at any wavelength, so we have the relation:

$$\alpha_\lambda + \rho_\lambda + \tau_\lambda = 1$$

For opaque materials $\tau_\lambda = 0$ and the relation simplifies to:

$$\alpha_\lambda + \rho_\lambda = 1$$

Another factor, called the emissivity, is required to describe the fraction ε of the radiant emittance of a blackbody produced by an object at a specific temperature. Thus, we have the definition:

The spectral emissivity ε_λ = the ratio of the spectral radiant power from an object to that from a blackbody at the same temperature and wavelength.

Expressed mathematically, this can be written as the ratio of the spectral emittance of the object to that of a blackbody as follows:

$$\varepsilon_\lambda = \frac{W_{\lambda o}}{W_{\lambda b}}$$

Generally speaking, there are three types of radiation source, distinguished by the ways in which the spectral emittance of each varies with wavelength.

- A blackbody, for which $\varepsilon_\lambda = \varepsilon = 1$
- A graybody, for which $\varepsilon_\lambda = \varepsilon = \text{constant less than } 1$
- A selective radiator, for which ε varies with wavelength

According to Kirchhoff's law, for any material the spectral emissivity and spectral absorptance of a body are equal at any specified temperature and wavelength. That is:

$$\varepsilon_\lambda = \alpha_\lambda$$

From this we obtain, for an opaque material (since $\alpha_\lambda + \rho_\lambda = 1$):

$$\varepsilon_\lambda + \rho_\lambda = 1$$

For highly polished materials ε_λ approaches zero, so that for a perfectly reflecting material (*i.e.* a perfect mirror) we have:

$$\rho_\lambda = 1$$

For a graybody radiator, the Stefan-Boltzmann formula becomes:

$$W = \varepsilon \sigma T^4 \text{ [Watt/m}^2\text{]}$$

This states that the total emissive power of a graybody is the same as a blackbody at the same temperature reduced in proportion to the value of ε from the graybody.

10401203,a2




Figure 33.8 Spectral radiant emittance of three types of radiators. 1: Spectral radiant emittance; 2: Wavelength; 3: Blackbody; 4: Selective radiator; 5: Graybody.

10327303,a4




Figure 33.9 Spectral emissivity of three types of radiators. 1: Spectral emissivity; 2: Wavelength; 3: Blackbody; 4: Graybody; 5: Selective radiator.

33.4 *Infrared semi-transparent materials*

Consider now a non-metallic, semi-transparent body – let us say, in the form of a thick flat plate of plastic material. When the plate is heated, radiation generated within its volume must work its way toward the surfaces through the material in which it is partially absorbed. Moreover, when it arrives at the surface, some of it is reflected back into the interior. The back-reflected radiation is again partially absorbed, but

some of it arrives at the other surface, through which most of it escapes; part of it is reflected back again. Although the progressive reflections become weaker and weaker they must all be added up when the total emittance of the plate is sought. When the resulting geometrical series is summed, the effective emissivity of a semi-transparent plate is obtained as:

$$\varepsilon_{\lambda} = \frac{(1 - \rho_{\lambda})(1 - \tau_{\lambda})}{1 - \rho_{\lambda}\tau_{\lambda}}$$

When the plate becomes opaque this formula is reduced to the single formula:

$$\varepsilon_{\lambda} = 1 - \rho_{\lambda}$$

This last relation is a particularly convenient one, because it is often easier to measure reflectance than to measure emissivity directly.

34 The measurement formula

As already mentioned, when viewing an object, the camera receives radiation not only from the object itself. It also collects radiation from the surroundings reflected via the object surface. Both these radiation contributions become attenuated to some extent by the atmosphere in the measurement path. To this comes a third radiation contribution from the atmosphere itself.

This description of the measurement situation, as illustrated in the figure below, is so far a fairly true description of the real conditions. What has been neglected could for instance be sun light scattering in the atmosphere or stray radiation from intense radiation sources outside the field of view. Such disturbances are difficult to quantify, however, in most cases they are fortunately small enough to be neglected. In case they are not negligible, the measurement configuration is likely to be such that the risk for disturbance is obvious, at least to a trained operator. It is then his responsibility to modify the measurement situation to avoid the disturbance e.g. by changing the viewing direction, shielding off intense radiation sources etc.

Accepting the description above, we can use the figure below to derive a formula for the calculation of the object temperature from the calibrated camera output.




Figure 34.1 A schematic representation of the general thermographic measurement situation. 1: Surroundings; 2: Object; 3: Atmosphere; 4: Camera

Assume that the received radiation power W from a blackbody source of temperature T_{source} on short distance generates a camera output signal U_{source} that is proportional to the power input (power linear camera). We can then write (Equation 1):

$$U_{source} = CW(T_{source})$$

or, with simplified notation:

$$U_{source} = CW_{source}$$

where C is a constant.

Should the source be a graybody with emittance ε , the received radiation would consequently be εW_{source} .

We are now ready to write the three collected radiation power terms:

1 – *Emission from the object* = $\varepsilon\tau W_{obj}$, where ε is the emittance of the object and τ is the transmittance of the atmosphere. The object temperature is T_{obj} .

2 – *Reflected emission from ambient sources* = $(1 - \varepsilon)\tau W_{refl}$, where $(1 - \varepsilon)$ is the reflectance of the object. The ambient sources have the temperature T_{refl} .

It has here been assumed that the temperature T_{refl} is the same for all emitting surfaces within the halfsphere seen from a point on the object surface. This is of course sometimes a simplification of the true situation. It is, however, a necessary simplification in order to derive a workable formula, and T_{refl} can – at least theoretically – be given a value that represents an efficient temperature of a complex surrounding.

Note also that we have assumed that the emittance for the surroundings = 1. This is correct in accordance with Kirchoff's law: All radiation impinging on the surrounding surfaces will eventually be absorbed by the same surfaces. Thus the emittance = 1. (Note though that the latest discussion requires the complete sphere around the object to be considered.)

3 – *Emission from the atmosphere* = $(1 - \tau)\tau W_{atm}$, where $(1 - \tau)$ is the emittance of the atmosphere. The temperature of the atmosphere is T_{atm} .

The total received radiation power can now be written (Equation 2):

$$W_{tot} = \varepsilon\tau W_{obj} + (1 - \varepsilon)\tau W_{refl} + (1 - \tau)W_{atm}$$

We multiply each term by the constant C of Equation 1 and replace the CW products by the corresponding U according to the same equation, and get (Equation 3):

$$U_{tot} = \varepsilon\tau U_{obj} + (1 - \varepsilon)\tau U_{refl} + (1 - \tau)U_{atm}$$

Solve Equation 3 for U_{obj} (Equation 4):

$$U_{obj} = \frac{1}{\varepsilon\tau} U_{tot} - \frac{1-\varepsilon}{\varepsilon} U_{refl} - \frac{1-\tau}{\varepsilon\tau} U_{atm}$$

This is the general measurement formula used in all the FLIR Systems thermographic equipment. The voltages of the formula are:

Figure 34.2 Voltages

U_{obj}	Calculated camera output voltage for a blackbody of temperature T_{obj} i.e. a voltage that can be directly converted into true requested object temperature.
U_{tot}	Measured camera output voltage for the actual case.
U_{refl}	Theoretical camera output voltage for a blackbody of temperature T_{refl} according to the calibration.
U_{atm}	Theoretical camera output voltage for a blackbody of temperature T_{atm} according to the calibration.

The operator has to supply a number of parameter values for the calculation:

- the object emittance ε ,
- the relative humidity,
- T_{atm}
- object distance (D_{obj})
- the (effective) temperature of the object surroundings, or the reflected ambient temperature T_{refl} , and
- the temperature of the atmosphere T_{atm}

This task could sometimes be a heavy burden for the operator since there are normally no easy ways to find accurate values of emittance and atmospheric transmittance for the actual case. The two temperatures are normally less of a problem provided the surroundings do not contain large and intense radiation sources.

A natural question in this connection is: How important is it to know the right values of these parameters? It could though be of interest to get a feeling for this problem already here by looking into some different measurement cases and compare the relative magnitudes of the three radiation terms. This will give indications about when it is important to use correct values of which parameters.

The figures below illustrates the relative magnitudes of the three radiation contributions for three different object temperatures, two emittances, and two spectral ranges: SW and LW. Remaining parameters have the following fixed values:

- $\tau = 0.88$
- $T_{refl} = +20^{\circ}\text{C} (+68^{\circ}\text{F})$
- $T_{atm} = +20^{\circ}\text{C} (+68^{\circ}\text{F})$

It is obvious that measurement of low object temperatures are more critical than measuring high temperatures since the 'disturbing' radiation sources are relatively much stronger in the first case. Should also the object emittance be low, the situation would be still more difficult.

We have finally to answer a question about the importance of being allowed to use the calibration curve above the highest calibration point, what we call extrapolation. Imagine that we in a certain case measure $U_{\text{tot}} = 4.5$ volts. The highest calibration point for the camera was in the order of 4.1 volts, a value unknown to the operator. Thus, even if the object happened to be a blackbody, i.e. $U_{\text{obj}} = U_{\text{tot}}$, we are actually performing extrapolation of the calibration curve when converting 4.5 volts into temperature.

Let us now assume that the object is not black, it has an emittance of 0.75, and the transmittance is 0.92. We also assume that the two second terms of Equation 4 amount to 0.5 volts together. Computation of U_{obj} by means of Equation 4 then results in $U_{\text{obj}} = 4.5 / 0.75 / 0.92 - 0.5 = 6.0$. This is a rather extreme extrapolation, particularly when considering that the video amplifier might limit the output to 5 volts! Note, though, that the application of the calibration curve is a theoretical procedure where no electronic or other limitations exist. We trust that if there had been no signal limitations in the camera, and if it had been calibrated far beyond 5 volts, the resulting curve would have been very much the same as our real curve extrapolated beyond 4.1 volts, provided the calibration algorithm is based on radiation physics, like the FLIR Systems algorithm. Of course there must be a limit to such extrapolations.

10400603,a2




Figure 34.3 Relative magnitudes of radiation sources under varying measurement conditions (SW camera). **1:** Object temperature; **2:** Emittance; **Obj:** Object radiation; **Refl:** Reflected radiation; **Atm:** atmosphere radiation. Fixed parameters: $\tau = 0.88$; $T_{\text{refl}} = 20^{\circ}\text{C} (+68^{\circ}\text{F})$; $T_{\text{atm}} = 20^{\circ}\text{C} (+68^{\circ}\text{F})$.

10400703,a2




Figure 34.4 Relative magnitudes of radiation sources under varying measurement conditions (LW camera). **1:** Object temperature; **2:** Emittance; **Obj:** Object radiation; **Refl:** Reflected radiation; **Atm:** atmosphere radiation. Fixed parameters: $\tau = 0.88$; $T_{\text{refl}} = 20^{\circ}\text{C}$ (+68°F); $T_{\text{atm}} = 20^{\circ}\text{C}$ (+68°F).

35 Emissivity tables

This section presents a compilation of emissivity data from the infrared literature and measurements made by FLIR Systems.

35.1 References

1	Mikaél A. Bramson: <i>Infrared Radiation, A Handbook for Applications</i> , Plenum press, N.Y.
2	William L. Wolfe, George J. Zissis: <i>The Infrared Handbook</i> , Office of Naval Research, Department of Navy, Washington, D.C.
3	Madding, R. P.: <i>Thermographic Instruments and systems</i> . Madison, Wisconsin: University of Wisconsin – Extension, Department of Engineering and Applied Science.
4	William L. Wolfe: <i>Handbook of Military Infrared Technology</i> , Office of Naval Research, Department of Navy, Washington, D.C.
5	Jones, Smith, Probert: <i>External thermography of buildings...</i> , Proc. of the Society of Photo-Optical Instrumentation Engineers, vol.110, Industrial and Civil Applications of Infrared Technology, June 1977 London.
6	Paljak, Pettersson: <i>Thermography of Buildings</i> , Swedish Building Research Institute, Stockholm 1972.
7	Vlcek, J: <i>Determination of emissivity with imaging radiometers and some emissivities at $\lambda = 5 \mu\text{m}$</i> . Photogrammetric Engineering and Remote Sensing.
8	Kern: <i>Evaluation of infrared emission of clouds and ground as measured by weather satellites</i> , Defence Documentation Center, AD 617 417.
9	Öhman, Claes: <i>Emittansmätningar med AGEMA E-Box</i> . Teknisk rapport, AGEMA 1999. (Emittance measurements using AGEMA E-Box. Technical report, AGEMA 1999.)
10	Mattei, S., Tang-Kwor, E: <i>Emissivity measurements for Nextel Velvet coating 811-21 between -36°C AND 82°C</i> .
11	Lohrengel & Todtenhaupt (1996)
12	ITC Technical publication 32.
13	ITC Technical publication 29.

35.2 Important note about the emissivity tables

The emissivity values in the table below are recorded using a shortwave (SW) camera. The values should be regarded as recommendations only and used with caution.

35.3 Tables

Figure 35.1 T: Total spectrum; **SW:** 2–5 μm ; **LW:** 8–14 μm , **LLW:** 6.5–20 μm ; **1:** Material; **2:** Specification; **3:** Temperature in $^{\circ}\text{C}$; **4:** Spectrum; **5:** Emissivity; **6:** Reference

1	2	3	4	5	6
3M type 35	Vinyl electrical tape (several colors)	< 80	LW	Ca. 0.96	13
3M type 88	Black vinyl electrical tape	< 105	LW	Ca. 0.96	13
3M type 88	Black vinyl electrical tape	< 105	MW	< 0.96	13
3M type Super 33+	Black vinyl electrical tape	< 80	LW	Ca. 0.96	13
Aluminum	anodized, black, dull	70	LW	0.95	9
Aluminum	anodized, black, dull	70	SW	0.67	9
Aluminum	anodized, light gray, dull	70	LW	0.97	9
Aluminum	anodized, light gray, dull	70	SW	0.61	9
Aluminum	anodized sheet	100	T	0.55	2
Aluminum	as received, plate	100	T	0.09	4
Aluminum	as received, sheet	100	T	0.09	2
Aluminum	cast, blast cleaned	70	LW	0.46	9
Aluminum	cast, blast cleaned	70	SW	0.47	9
Aluminum	dipped in HNO_3 , plate	100	T	0.05	4
Aluminum	foil	27	3 μm	0.09	3
Aluminum	foil	27	10 μm	0.04	3
Aluminum	oxidized, strongly	50–500	T	0.2–0.3	1
Aluminum	polished	50–100	T	0.04–0.06	1
Aluminum	polished, sheet	100	T	0.05	2
Aluminum	polished plate	100	T	0.05	4

1	2	3	4	5	6
Aluminum	roughened	27	3 μm	0.28	3
Aluminum	roughened	27	10 μm	0.18	3
Aluminum	rough surface	20–50	T	0.06–0.07	1
Aluminum	sheet, 4 samples differently scratched	70	LW	0.03–0.06	9
Aluminum	sheet, 4 samples differently scratched	70	SW	0.05–0.08	9
Aluminum	vacuum deposited	20	T	0.04	2
Aluminum	weathered, heavily	17	SW	0.83–0.94	5
Aluminum bronze		20	T	0.60	1
Aluminum hydroxide	powder		T	0.28	1
Aluminum oxide	activated, powder		T	0.46	1
Aluminum oxide	pure, powder (alumina)		T	0.16	1
Asbestos	board	20	T	0.96	1
Asbestos	fabric		T	0.78	1
Asbestos	floor tile	35	SW	0.94	7
Asbestos	paper	40–400	T	0.93–0.95	1
Asbestos	powder		T	0.40–0.60	1
Asbestos	slate	20	T	0.96	1
Asphalt paving		4	LLW	0.967	8
Brass	dull, tarnished	20–350	T	0.22	1
Brass	oxidized	70	SW	0.04–0.09	9
Brass	oxidized	70	LW	0.03–0.07	9
Brass	oxidized	100	T	0.61	2
Brass	oxidized at 600°C	200–600	T	0.59–0.61	1
Brass	polished	200	T	0.03	1
Brass	polished, highly	100	T	0.03	2

1	2	3	4	5	6
Brass	rubbed with 80-grit emery	20	T	0.20	2
Brass	sheet, rolled	20	T	0.06	1
Brass	sheet, worked with emery	20	T	0.2	1
Brick	alumina	17	SW	0.68	5
Brick	common	17	SW	0.86–0.81	5
Brick	Dinas silica, glazed, rough	1100	T	0.85	1
Brick	Dinas silica, refractory	1000	T	0.66	1
Brick	Dinas silica, unglazed, rough	1000	T	0.80	1
Brick	firebrick	17	SW	0.68	5
Brick	fireclay	20	T	0.85	1
Brick	fireclay	1000	T	0.75	1
Brick	fireclay	1200	T	0.59	1
Brick	masonry	35	SW	0.94	7
Brick	masonry, plastered	20	T	0.94	1
Brick	red, common	20	T	0.93	2
Brick	red, rough	20	T	0.88–0.93	1
Brick	refractory, corundum	1000	T	0.46	1
Brick	refractory, magnesite	1000–1300	T	0.38	1
Brick	refractory, strongly radiating	500–1000	T	0.8–0.9	1
Brick	refractory, weakly radiating	500–1000	T	0.65–0.75	1
Brick	silica, 95% SiO ₂	1230	T	0.66	1
Brick	sillimanite, 33% SiO ₂ , 64% Al ₂ O ₃	1500	T	0.29	1

1	2	3	4	5	6
Brick	waterproof	17	SW	0.87	5
Bronze	phosphor bronze	70	LW	0.06	9
Bronze	phosphor bronze	70	SW	0.08	9
Bronze	polished	50	T	0.1	1
Bronze	porous, rough	50–150	T	0.55	1
Bronze	powder		T	0.76–0.80	1
Carbon	candle soot	20	T	0.95	2
Carbon	charcoal powder		T	0.96	1
Carbon	graphite, filed surface	20	T	0.98	2
Carbon	graphite powder		T	0.97	1
Carbon	lampblack	20–400	T	0.95–0.97	1
Chipboard	untreated	20	SW	0.90	6
Chromium	polished	50	T	0.10	1
Chromium	polished	500–1000	T	0.28–0.38	1
Clay	fired	70	T	0.91	1
Cloth	black	20	T	0.98	1
Concrete		20	T	0.92	2
Concrete	dry	36	SW	0.95	7
Concrete	rough	17	SW	0.97	5
Concrete	walkway	5	LLW	0.974	8
Copper	commercial, bur-nished	20	T	0.07	1
Copper	electrolytic, careful-ly polished	80	T	0.018	1
Copper	electrolytic, pol-ished	–34	T	0.006	4
Copper	molten	1100–1300	T	0.13–0.15	1
Copper	oxidized	50	T	0.6–0.7	1
Copper	oxidized, black	27	T	0.78	4

1	2	3	4	5	6
Copper	oxidized, heavily	20	T	0.78	2
Copper	oxidized to blackness		T	0.88	1
Copper	polished	50–100	T	0.02	1
Copper	polished	100	T	0.03	2
Copper	polished, commercial	27	T	0.03	4
Copper	polished, mechanical	22	T	0.015	4
Copper	pure, carefully prepared surface	22	T	0.008	4
Copper	scraped	27	T	0.07	4
Copper dioxide	powder		T	0.84	1
Copper oxide	red, powder		T	0.70	1
Ebonite			T	0.89	1
Emery	coarse	80	T	0.85	1
Enamel		20	T	0.9	1
Enamel	lacquer	20	T	0.85–0.95	1
Fiber board	hard, untreated	20	SW	0.85	6
Fiber board	masonite	70	LW	0.88	9
Fiber board	masonite	70	SW	0.75	9
Fiber board	particle board	70	LW	0.89	9
Fiber board	particle board	70	SW	0.77	9
Fiber board	porous, untreated	20	SW	0.85	6
Gold	polished	130	T	0.018	1
Gold	polished, carefully	200–600	T	0.02–0.03	1
Gold	polished, highly	100	T	0.02	2
Granite	polished	20	LLW	0.849	8
Granite	rough	21	LLW	0.879	8
Granite	rough, 4 different samples	70	LW	0.77–0.87	9

1	2	3	4	5	6
Granite	rough, 4 different samples	70	SW	0.95–0.97	9
Gypsum		20	T	0.8–0.9	1
Ice: See Water					
Iron, cast	casting	50	T	0.81	1
Iron, cast	ingots	1000	T	0.95	1
Iron, cast	liquid	1300	T	0.28	1
Iron, cast	machined	800–1000	T	0.60–0.70	1
Iron, cast	oxidized	38	T	0.63	4
Iron, cast	oxidized	100	T	0.64	2
Iron, cast	oxidized	260	T	0.66	4
Iron, cast	oxidized	538	T	0.76	4
Iron, cast	oxidized at 600°C	200–600	T	0.64–0.78	1
Iron, cast	polished	38	T	0.21	4
Iron, cast	polished	40	T	0.21	2
Iron, cast	polished	200	T	0.21	1
Iron, cast	unworked	900–1100	T	0.87–0.95	1
Iron and steel	cold rolled	70	LW	0.09	9
Iron and steel	cold rolled	70	SW	0.20	9
Iron and steel	covered with red rust	20	T	0.61–0.85	1
Iron and steel	electrolytic	22	T	0.05	4
Iron and steel	electrolytic	100	T	0.05	4
Iron and steel	electrolytic	260	T	0.07	4
Iron and steel	electrolytic, carefully polished	175–225	T	0.05–0.06	1
Iron and steel	freshly worked with emery	20	T	0.24	1
Iron and steel	ground sheet	950–1100	T	0.55–0.61	1
Iron and steel	heavily rusted sheet	20	T	0.69	2

1	2	3	4	5	6
Iron and steel	hot rolled	20	T	0.77	1
Iron and steel	hot rolled	130	T	0.60	1
Iron and steel	oxidized	100	T	0.74	1
Iron and steel	oxidized	100	T	0.74	4
Iron and steel	oxidized	125–525	T	0.78–0.82	1
Iron and steel	oxidized	200	T	0.79	2
Iron and steel	oxidized	1227	T	0.89	4
Iron and steel	oxidized	200–600	T	0.80	1
Iron and steel	oxidized strongly	50	T	0.88	1
Iron and steel	oxidized strongly	500	T	0.98	1
Iron and steel	polished	100	T	0.07	2
Iron and steel	polished	400–1000	T	0.14–0.38	1
Iron and steel	polished sheet	750–1050	T	0.52–0.56	1
Iron and steel	rolled, freshly	20	T	0.24	1
Iron and steel	rolled sheet	50	T	0.56	1
Iron and steel	rough, plane surface	50	T	0.95–0.98	1
Iron and steel	rusted, heavily	17	SW	0.96	5
Iron and steel	rusted red, sheet	22	T	0.69	4
Iron and steel	rusty, red	20	T	0.69	1
Iron and steel	shiny, etched	150	T	0.16	1
Iron and steel	shiny oxide layer, sheet,	20	T	0.82	1
Iron and steel	wrought, carefully polished	40–250	T	0.28	1
Iron galvanized	heavily oxidized	70	LW	0.85	9
Iron galvanized	heavily oxidized	70	SW	0.64	9
Iron galvanized	sheet	92	T	0.07	4
Iron galvanized	sheet, burnished	30	T	0.23	1
Iron galvanized	sheet, oxidized	20	T	0.28	1

1	2	3	4	5	6
Iron tinned	sheet	24	T	0.064	4
Krylon Ultra-flat black 1602	Flat black	Room temperature up to 175	LW	Ca. 0.96	12
Krylon Ultra-flat black 1602	Flat black	Room temperature up to 175	MW	Ca. 0.97	12
Lacquer	3 colors sprayed on Aluminum	70	LW	0.92–0.94	9
Lacquer	3 colors sprayed on Aluminum	70	SW	0.50–0.53	9
Lacquer	Aluminum on rough surface	20	T	0.4	1
Lacquer	bakelite	80	T	0.83	1
Lacquer	black, dull	40–100	T	0.96–0.98	1
Lacquer	black, matte	100	T	0.97	2
Lacquer	black, shiny, sprayed on iron	20	T	0.87	1
Lacquer	heat-resistant	100	T	0.92	1
Lacquer	white	40–100	T	0.8–0.95	1
Lacquer	white	100	T	0.92	2
Lead	oxidized, gray	20	T	0.28	1
Lead	oxidized, gray	22	T	0.28	4
Lead	oxidized at 200°C	200	T	0.63	1
Lead	shiny	250	T	0.08	1
Lead	unoxidized, polished	100	T	0.05	4
Lead red		100	T	0.93	4
Lead red, powder		100	T	0.93	1
Leather	tanned		T	0.75–0.80	1
Lime			T	0.3–0.4	1
Magnesium		22	T	0.07	4
Magnesium		260	T	0.13	4

1	2	3	4	5	6
Magnesium		538	T	0.18	4
Magnesium	polished	20	T	0.07	2
Magnesium powder			T	0.86	1
Molybdenum		600–1000	T	0.08–0.13	1
Molybdenum		1500–2200	T	0.19–0.26	1
Molybdenum	filament	700–2500	T	0.1–0.3	1
Mortar		17	SW	0.87	5
Mortar	dry	36	SW	0.94	7
Nextel Velvet 811-21 Black	Flat black	–60–150	LW	> 0.97	10 and 11
Nichrome	rolled	700	T	0.25	1
Nichrome	sandblasted	700	T	0.70	1
Nichrome	wire, clean	50	T	0.65	1
Nichrome	wire, clean	500–1000	T	0.71–0.79	1
Nichrome	wire, oxidized	50–500	T	0.95–0.98	1
Nickel	bright matte	122	T	0.041	4
Nickel	commercially pure, polished	100	T	0.045	1
Nickel	commercially pure, polished	200–400	T	0.07–0.09	1
Nickel	electrolytic	22	T	0.04	4
Nickel	electrolytic	38	T	0.06	4
Nickel	electrolytic	260	T	0.07	4
Nickel	electrolytic	538	T	0.10	4
Nickel	electroplated, polished	20	T	0.05	2
Nickel	electroplated on iron, polished	22	T	0.045	4
Nickel	electroplated on iron, unpolished	20	T	0.11–0.40	1

1	2	3	4	5	6
Nickel	electroplated on iron, unpolished	22	T	0.11	4
Nickel	oxidized	200	T	0.37	2
Nickel	oxidized	227	T	0.37	4
Nickel	oxidized	1227	T	0.85	4
Nickel	oxidized at 600°C	200–600	T	0.37–0.48	1
Nickel	polished	122	T	0.045	4
Nickel	wire	200–1000	T	0.1–0.2	1
Nickel oxide		500–650	T	0.52–0.59	1
Nickel oxide		1000–1250	T	0.75–0.86	1
Oil, lubricating	0.025 mm film	20	T	0.27	2
Oil, lubricating	0.050 mm film	20	T	0.46	2
Oil, lubricating	0.125 mm film	20	T	0.72	2
Oil, lubricating	film on Ni base: Ni base only	20	T	0.05	2
Oil, lubricating	thick coating	20	T	0.82	2
Paint	8 different colors and qualities	70	LW	0.92–0.94	9
Paint	8 different colors and qualities	70	SW	0.88–0.96	9
Paint	Aluminum, various ages	50–100	T	0.27–0.67	1
Paint	cadmium yellow		T	0.28–0.33	1
Paint	chrome green		T	0.65–0.70	1
Paint	cobalt blue		T	0.7–0.8	1
Paint	oil	17	SW	0.87	5
Paint	oil, black flat	20	SW	0.94	6
Paint	oil, black gloss	20	SW	0.92	6
Paint	oil, gray flat	20	SW	0.97	6
Paint	oil, gray gloss	20	SW	0.96	6
Paint	oil, various colors	100	T	0.92–0.96	1

1	2	3	4	5	6
Paint	oil based, average of 16 colors	100	T	0.94	2
Paint	plastic, black	20	SW	0.95	6
Paint	plastic, white	20	SW	0.84	6
Paper	4 different colors	70	LW	0.92–0.94	9
Paper	4 different colors	70	SW	0.68–0.74	9
Paper	black		T	0.90	1
Paper	black, dull		T	0.94	1
Paper	black, dull	70	LW	0.89	9
Paper	black, dull	70	SW	0.86	9
Paper	blue, dark		T	0.84	1
Paper	coated with black lacquer		T	0.93	1
Paper	green		T	0.85	1
Paper	red		T	0.76	1
Paper	white	20	T	0.7–0.9	1
Paper	white, 3 different glosses	70	LW	0.88–0.90	9
Paper	white, 3 different glosses	70	SW	0.76–0.78	9
Paper	white bond	20	T	0.93	2
Paper	yellow		T	0.72	1
Plaster		17	SW	0.86	5
Plaster	plasterboard, untreated	20	SW	0.90	6
Plaster	rough coat	20	T	0.91	2
Plastic	glass fibre laminate (printed circ. board)	70	LW	0.91	9
Plastic	glass fibre laminate (printed circ. board)	70	SW	0.94	9

1	2	3	4	5	6
Plastic	polyurethane isolation board	70	LW	0.55	9
Plastic	polyurethane isolation board	70	SW	0.29	9
Plastic	PVC, plastic floor, dull, structured	70	LW	0.93	9
Plastic	PVC, plastic floor, dull, structured	70	SW	0.94	9
Platinum		17	T	0.016	4
Platinum		22	T	0.03	4
Platinum		100	T	0.05	4
Platinum		260	T	0.06	4
Platinum		538	T	0.10	4
Platinum		1000–1500	T	0.14–0.18	1
Platinum		1094	T	0.18	4
Platinum	pure, polished	200–600	T	0.05–0.10	1
Platinum	ribbon	900–1100	T	0.12–0.17	1
Platinum	wire	50–200	T	0.06–0.07	1
Platinum	wire	500–1000	T	0.10–0.16	1
Platinum	wire	1400	T	0.18	1
Porcelain	glazed	20	T	0.92	1
Porcelain	white, shiny		T	0.70–0.75	1
Rubber	hard	20	T	0.95	1
Rubber	soft, gray, rough	20	T	0.95	1
Sand			T	0.60	1
Sand		20	T	0.90	2
Sandstone	polished	19	LLW	0.909	8
Sandstone	rough	19	LLW	0.935	8
Silver	polished	100	T	0.03	2
Silver	pure, polished	200–600	T	0.02–0.03	1

1	2	3	4	5	6
Skin	human	32	T	0.98	2
Slag	boiler	0–100	T	0.97–0.93	1
Slag	boiler	200–500	T	0.89–0.78	1
Slag	boiler	600–1200	T	0.76–0.70	1
Slag	boiler	1400–1800	T	0.69–0.67	1
Snow: See Water					
Soil	dry	20	T	0.92	2
Soil	saturated with water	20	T	0.95	2
Stainless steel	alloy, 8% Ni, 18% Cr	500	T	0.35	1
Stainless steel	rolled	700	T	0.45	1
Stainless steel	sandblasted	700	T	0.70	1
Stainless steel	sheet, polished	70	LW	0.14	9
Stainless steel	sheet, polished	70	SW	0.18	9
Stainless steel	sheet, untreated, somewhat scratched	70	LW	0.28	9
Stainless steel	sheet, untreated, somewhat scratched	70	SW	0.30	9
Stainless steel	type 18-8, buffed	20	T	0.16	2
Stainless steel	type 18-8, oxidized at 800°C	60	T	0.85	2
Stucco	rough, lime	10–90	T	0.91	1
Styrofoam	insulation	37	SW	0.60	7
Tar			T	0.79–0.84	1
Tar	paper	20	T	0.91–0.93	1
Tile	glazed	17	SW	0.94	5
Tin	burnished	20–50	T	0.04–0.06	1
Tin	tin-plated sheet iron	100	T	0.07	2

1	2	3	4	5	6
Titanium	oxidized at 540°C	200	T	0.40	1
Titanium	oxidized at 540°C	500	T	0.50	1
Titanium	oxidized at 540°C	1000	T	0.60	1
Titanium	polished	200	T	0.15	1
Titanium	polished	500	T	0.20	1
Titanium	polished	1000	T	0.36	1
Tungsten		200	T	0.05	1
Tungsten		600–1000	T	0.1–0.16	1
Tungsten		1500–2200	T	0.24–0.31	1
Tungsten	filament	3300	T	0.39	1
Varnish	flat	20	SW	0.93	6
Varnish	on oak parquet floor	70	LW	0.90–0.93	9
Varnish	on oak parquet floor	70	SW	0.90	9
Wallpaper	slight pattern, light gray	20	SW	0.85	6
Wallpaper	slight pattern, red	20	SW	0.90	6
Water	distilled	20	T	0.96	2
Water	frost crystals	–10	T	0.98	2
Water	ice, covered with heavy frost	0	T	0.98	1
Water	ice, smooth	–10	T	0.96	2
Water	ice, smooth	0	T	0.97	1
Water	layer >0.1 mm thick	0–100	T	0.95–0.98	1
Water	snow		T	0.8	1
Water	snow	–10	T	0.85	2
Wood		17	SW	0.98	5
Wood		19	LLW	0.962	8
Wood	ground		T	0.5–0.7	1

1	2	3	4	5	6
Wood	pine, 4 different samples	70	LW	0.81–0.89	9
Wood	pine, 4 different samples	70	SW	0.67–0.75	9
Wood	planed	20	T	0.8–0.9	1
Wood	planed oak	20	T	0.90	2
Wood	planed oak	70	LW	0.88	9
Wood	planed oak	70	SW	0.77	9
Wood	plywood, smooth, dry	36	SW	0.82	7
Wood	plywood, untreated	20	SW	0.83	6
Wood	white, damp	20	T	0.7–0.8	1
Zinc	oxidized at 400°C	400	T	0.11	1
Zinc	oxidized surface	1000–1200	T	0.50–0.60	1
Zinc	polished	200–300	T	0.04–0.05	1
Zinc	sheet	50	T	0.20	1

A note on the technical production of this publication

This publication was produced using XML—the *eXtensible Markup Language*. For more information about XML, please visit <http://www.w3.org/XML/>

A note on the typeface used in this publication

This publication was typeset using Swiss 721, which is Bitstream's pan-European version of the Helvetica™ typeface. Helvetica™ was designed by Max Miedinger (1910–1980).

List of effective files

20235103.xml a24
20235203.xml a21
20235303.xml a18
20236703.xml a49
20237103.xml a10
20238503.xml a9
20238703.xml b8
20250403.xml a20
20254903.xml a63
20257003.xml a40
20257103.xml a17
20257303.xml a32
20273203.xml a13
20275203.xml a14
20279803.xml a7
20281003.xml a1
20283703.xml a10
20283803.xml a4
20283903.xml a4
20284003.xml a11
20284103.xml a12
20284203.xml a10
20284303.xml a7
20284403.xml a9
20284503.xml a8
20284703.xml a7
20284803.xml a4
20284903.xml a19
20285003.xml a2
20285103.xml a5
20285203.xml a3
20287303.xml a9
20288603.xml a3
20288703.xml a4
20292403.xml a5
20294903.xml a4
20295003.xml a10
20295303.xml a1
R110.rcp a6
config.xml a5



Corporate Headquarters

FLIR Systems, Inc.
27700 SW Parkway Avenue
Wilsonville, OR 97070
USA

Telephone: +1-800-727-3547
Website: <http://www.flir.com>